



June 6, 2023

Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center – Building 107 Air and Wipe Sampling Evaluation Addendum  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the above referenced environmental sampling activities. The following is our report.

## **INTRODUCTION**

As requested, Burns & McDonnell conducted area air sampling and wipe sampling for the presence of seven (7) RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver within the occupied areas of the first floor of building 107 of the Goodfellow Federal Center located at 4300 Goodfellow Boulevard in St. Louis, Missouri. The purpose of the investigation was to provide ongoing sampling data to monitor conditions at the site. This report serves as an addendum to the *Goodfellow Federal Center – Building 107 Air and Wipe Sampling Evaluation*, dated December 27, 2021.

## **SAMPLING METHODOLOGY**

Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination* and ASTM Standard D6966: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Determination of Metals*. ASTM Standards E1728 and D6966 are consistent with the methodology described in the Housing and Urban Development Guidelines-Appendix 13.1 and 40 CFR 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

A representative surface area of approximately one square foot (1 SF) was measured and delineated. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth "S" pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container.



Diane Czarnecki  
Facilities Management Division  
June 6, 2023  
Page 2

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer ( $\mu\text{m}$ ) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration.

All samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals. Air samples were analyzed by Inductively Coupled Plasma (ICP) according to NIOSH method 7300. Wipe samples were analyzed according to Environmental Protection Agency (EPA) method SW846-3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.

#### **SAMPLE SUMMARY AND RESULTS**

Air and wipe samples were collected on April 19, 2023, by Justin Arnold of OCCU-TEC.

One (1) air sample was collected on April 19, 2023. The sample was collected on the 1<sup>st</sup> floor, room 134. All analytes were below laboratory reporting limits. The complete air sampling laboratory report from EHS is included as Appendix A.

One (1) wipe sample was collected on April 19, 2023 on the 1<sup>st</sup> floor, room 134, north window. Barium was detected at a concentration of 2.2  $\mu\text{g}/\text{sq. ft}$ , below the clean area limit of 3,094  $\mu\text{g}/\text{sq. ft}$ . Lead was detected at a concentration of 2.1  $\mu\text{g}/\text{sq. ft}$ , below the clean area limit of 10  $\mu\text{g}/\text{sq. ft}$ . All other analytes were below laboratory reporting limits. The complete wipe sampling laboratory report from EHS is included in Appendix B.

#### **LIMITATIONS**

The scope of this assessment was limited in nature. Burns & McDonnell collected samples from a representative number of surfaces in an effort to minimize cost while providing a general overview of site conditions. Sample locations do not encompass all surfaces at the site. Additionally, samples were only analyzed for a select number of potential contaminants. Burns & McDonnell is not responsible for potential contaminants not identified in this report.

Burns & McDonnell appreciates the opportunity to work for GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.



Diane Czarnecki  
Facilities Management Division  
June 6, 2023  
Page 3

Sincerely,

(b) (6)

Matt Shanahan, CHMM  
Project Manager

Attachments:

- Appendix A – Air Sampling Laboratory Report
- Appendix B – Wipe Sampling Laboratory Report

Information in Appendices A and B are not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or [r6environmental@gsa.gov](mailto:r6environmental@gsa.gov).

**APPENDIX A – AIR SAMPLING LABORATORY REPORT**



Environmental Hazards Services, L.L.C.  
 7469 Whitepine Rd  
 Richmond, VA 23237  
 Telephone: 800.347.4010

## Air Metals Analysis Report

Client: Burns & McDonnell Engineering  
 9400 Ward Pkwy.  
 Kansas City, MO 64114

Report Number: 23-04-03133  
 Received Date: 04/21/2023  
 Reported Date: 04/27/2023

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Client Number:  
26-3514

Fax Number:  
816-822-3494

# Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
23-04-03133-001	107-A-01	04/24/2023	Arsenic (As)	647.5	<0.15	<0.24	
			Barium (Ba)		<0.15	<0.24	
			Cadmium (Cd)		<0.030	<0.047	
			Chromium (Cr)		<0.75	<1.2	
			Lead (Pb)		<0.15	<0.24	
			Selenium (Se)		<0.75	<1.2	
			Silver (Ag)		<0.15	<0.24	
23-04-03133-002	107-A-02	04/24/2023	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 23-04-03133

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	------------------------------------	--------------

Sample Narratives:

Method: NIOSH 7300M  
Analyst: Carlos Gonzalez

(b) (6)

Reviewed By Authorized Signatory:

*Tasha Eaddy*  
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C.

LEGEND            ug = microgram                            ug/m<sup>3</sup> = micrograms per cubic meter  
                         mL = milliliter                                L= Liters

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Pg 1 of 1

Company Name		Burns & McDonnell				Account #		26-3514		
Company Address		9400 Ward Parkway				City/State/Zip		Kansas City, MO 64114		
Phone		314-302-4661				Email		alanstaett@burnsmcd.com		
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd								
PO Number		168765				Collected By				
Turn-Around Time		<input checked="" type="checkbox"/> 5 DAY <input type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead								

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES			
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate	Vol.	AREA <small>Circle The Unit of Measurement Used</small>		
																Mins.	L/min.	Total Liters		cm or (in)	
1	107-W-01	4-19-23 0615							Ag, As, Ba, Cd, Cr, Pb, Se												12 x 12
2	107-W-02	4-19-23 0619							X												- x -
3																					x
4	107-A-01	4-19-23 0607-1017							X						250	2.59	647.5			x	
5	107-A-02	4-19-23 0645							X						NA	NA	NA			x	
6																				x	
7																				x	
8																				x	
9																				x	
10																				x	
11																				x	
12																				x	
13																				x	
14																				x	
15																				x	

Released By:	Justin Arnold	Date:	04-20-2023	Time:	15:30
Signature:	(b) (6)				


LAB USE ONLY - BELOW THIS LINE

Received By: H. Humphrey

Signature: (b) (6)

Date: 4/21/23 Time: 12:41  AM  PM

23-04-03133



Due Date:  
04/28/2023  
(Friday)  
EL                      MM-L

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

**APPENDIX B – WIPE SAMPLING LABORATORY REPORT**





Environmental Hazards Services, L.L.C.  
 7469 Whitepine Rd  
 Richmond, VA 23237  
 Telephone: 800.347.4010

## Wipe Metals Analysis Report

Client: Burns & McDonnell Engineering  
 9400 Ward Pkwy.  
 Kansas City, MO 64114

Report Number: 23-04-03131  
 Received Date: 04/21/2023  
 Analyzed Date: 04/24/2023  
 Reported Date: 04/27/2023

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Client Number:  
 26-3514

# Laboratory Results

Fax Number:  
 816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
23-04-03131-001	107-W-1	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	2.19	2.2	
		Cadmium (Cd)	1.00	<0.100	<0.10	
		Chromium (Cr)	1.00	<1.00	<1.0	
		Lead (Pb)	1.00	2.06	2.1	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	
23-04-03131-002	107-W-2	Arsenic (As)		<2.50	---	
		Barium (Ba)		<0.500	---	
		Cadmium (Cd)		<0.100	---	
		Chromium (Cr)		<1.00	---	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 23-04-03131

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Lead (Pb)		<0.500	---	
		Selenium (Se)		<2.50	---	
		Silver (Ag)		<0.500	---	

## Sample Narratives:

Analyst: Carlos Gonzalez

Method: EPA SW846 3050B/6010D

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit based on a 50mL volume. The reporting limit for Lead is 0.5ug.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C.

Legend                      ug = microgram                      ug/ft<sup>2</sup> = micrograms per square foot  
   mL = milliliter                      ft<sup>2</sup> = square foot

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Pg 1 of 1

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	alanstaett@burnsmcd.com

Project Name / Testing Address: **GFC / 4300 Goodfellow Blvd**

PO Number: **168765**      Collected By: \_\_\_\_\_

Turn-Around Time:     5 DAY     3 DAY     2 DAY     1 DAY     SAME DAY OR WEEKEND - Must Call Ahead

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES  AREA Circle The Unit of Measurement Used cm or (in)
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time Mins.	Flow Rate l/min.	
1	107-W-01	4-19-23 06:15							Ag, As, Ba, Cd, Cr, Pb, Se									12 x 12
2	107-W-02	4-19-23 06:19							X									X
3																		X
4	107-A-01	4-19-23 06:07-10:17							X						250	2.59	641.5	X
5	107-A-02	4-19-23 06:45							X						NA	NA	NA	X
6																		X
7																		X
8																		X
9																		X
10																		X
11																		X
12																		X
13																		X
14																		X
15																		X

Released By: Justin Arnold      Date: 04-20-2023      Time: 15:30

Signature: (b) (6)

LAB USE ONLY - BELOW THIS LINE

Received By: H. Humphrey

Signature: (b) (6)

Date: 4/21/23 Time: 12:41     AM     PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

23-04-03131

Due Date:  
**04/28/2023**  
(Friday)  
EL                      MM-L