



July 13, 2021

Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center  
Metals in Settled Dust Sampling – Building 110  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 110 located at the Goodfellow Federal Center (GFC) in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

## **INTRODUCTION**

Per historical use and previous characterization, Burns & McDonnell was contracted to perform settled dust sampling for the analysis of seven (7) of the Resource Conservation and Recovery Act (RCRA) target metals (arsenic, barium, cadmium, chromium, lead, selenium, and silver) from various surfaces within buildings. The purpose of this testing was to further characterize the presence and concentration of target metals in common tenant-occupied areas of the building.

The proposed sampling scheme, the number of samples, the sample distribution and general methodology was developed by GSA and Burns & McDonnell. Specific sample locations were determined by sampling personnel while on-site.

Settled dust wipe sampling at Bldg. 110 was conducted on June 23, 2021 by Emily Ahlemeyer and Ashley Anstaett of Burns & McDonnell.

## **METALS IN SETTLED DUST SAMPLING**

Metals in settled dust sampling was conducted primarily within tenant-occupied areas. Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination* and ASTM Standard D6966: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Determination of Metals*. ASTM Standards E1728 and D6966 are consistent with the methodology described in the Housing and

Diane Czarnecki  
Facilities Management Division  
July 13, 2021  
Page 2

Urban Development Guidelines-Appendix 13.1 and 40 CFR 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed by building occupants. A representative surface area of approximately one square foot (1 SF) was measured and delineated with plastic templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth "S" pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container. Dust wipe samples were submitted to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for Inductively Coupled Plasma (ICP) analysis of metals analysis using Environmental Protection Agency (EPA) method SW846 3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Laboratory Accreditation Program (LAP) identification number LAP-100420.

Whereas the Occupational Safety and Health Administration (OSHA) has not established regulatory limits for surface concentrations of metals, the OSHA Technical Manual Section II: Chapter 2 (III.A) describes a method for calculating "housekeeping" standards, as recommended acceptable surface limits. Brookhaven's IH75190 procedure uses the housekeeping standards to derive a lower, "clean area limit" for non-operational areas that can be accessed or contacted without special training or precautions. Burns & McDonnell calculated clean area limits for metals not included in the Brookhaven procedure, specifically barium, chromium (total), selenium and silver. Wipe results were compared to the Brookhaven procedure's clean area limits for each metal.

Results of the dust wipe samples collected from the building indicate that 18 of the 22 samples contained concentrations of target metals above laboratory reporting limits. The following table identifies the range of results for each of the seven metals that were analyzed. Samples with a "<" sign indicate that the results were below the lab's reportable limit.

Diane Czarnecki  
 Facilities Management Division  
 July 13, 2021  
 Page 3

**Table 1. Summary of Dust Wipe Results**

Analyte	Lowest Concentration <sup>(a)</sup> (µg/sq. ft) <sup>(b)</sup>	Highest Concentration <sup>(a)</sup> (µg/sq. ft) <sup>(b)</sup>	Clean Area Limit <sup>(c)</sup> µg/sq. ft <sup>(b)</sup>
Silver	<0.5	1.3	62
Arsenic	<2.5	<2.5	62
Barium	<0.5	46.0	3,094
Cadmium	<0.1	6.5	31
Chromium (Total)	<1.0	25.0	3,094
Lead	<0.5	73.0	10 <sup>(d)</sup>
Selenium	<2.5	<2.5	1,236

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit.
- (b) µg/sq. ft = micrograms per square foot of surface area.
- (c) Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [PEL (µg/m<sup>3</sup>) x 10 m<sup>3</sup>/100cm<sup>2</sup>] / 15.
- (d) Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

Of the 18 samples that had detectable levels of one or more analytes, 3 of them exceeded the clean area limit.

1. A sample taken from the floor in the janitorial closet by column F2 on the second floor had 72 µg/ft<sup>2</sup> of lead.
2. A sample taken from the top of the mini refrigerator in the Goodwill laundry room had 73 µg/ft<sup>2</sup> of lead.
3. A sample taken from the work station with the vice in the ICE JV warehouse area had 44 µg/ft<sup>2</sup> of lead.

Burns & McDonnell appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.



Diane Czarnecki  
Facilities Management Division  
July 13, 2021  
Page 4

Sincerely,

(b) (6)

Matt Shanahan, CHMM  
Project Manager

Attachments:  
Appendix A – Sample Summary Table  
Appendix B – Laboratory Analysis Report

Information in Appendices A and B is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or [r6environmental@gsa.gov](mailto:r6environmental@gsa.gov).

**APPENDIX A – SAMPLE SUMMARY TABLE**

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-01	2nd floor, MWTC training room	Podium surface	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.75	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-02	2nd floor, column J11	Desk 2300A in office	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.52	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-03	2nd floor, column F2	Floor in janitorial closet	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	46	µg/ft <sup>2</sup>	3,094
			Cadmium	0.70	µg/ft <sup>2</sup>	31
			Chromium	17	µg/ft <sup>2</sup>	3,094
			Lead	72	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-04	2nd floor, column J8	Desk in office	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.77	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-05	2nd floor, common area	Break room counter	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	< 0.50	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-06	2nd floor, column F13	Shelf above desk 2405A	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	1.4	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-07	2nd floor, common area	Break room floor	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.68	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-08	2nd floor, column F2	IT closet, floor sample	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.66	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-09	2nd floor, northwest office	Floor outlet panel	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	1.7	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	0.70	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62



**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-10	1st floor, column J3	Window sill	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	1.2	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-11	1st floor, northwest stairwell	Floor sample	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	15	µg/ft <sup>2</sup>	3,094
			Cadmium	0.10	µg/ft <sup>2</sup>	31
			Chromium	1.5	µg/ft <sup>2</sup>	3,094
			Lead	4.8	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-12	1st floor, break room	Desk top	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.59	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-13	1st floor, column F15	Table by refrigerator	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	< 0.50	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-14	Field blank	--	Arsenic	< 2.50	µg/ft <sup>2</sup>	62
			Barium	< 0.500	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.100	µg/ft <sup>2</sup>	31
			Chromium	< 1.00	µg/ft <sup>2</sup>	3,094
			Lead	< 0.500	µg/ft <sup>2</sup>	10
			Selenium	< 2.50	µg/ft <sup>2</sup>	1,236
			Silver	< 0.500	µg/ft <sup>2</sup>	62
110-W-15	Field blank	--	Arsenic	< 2.50	µg/ft <sup>2</sup>	62
			Barium	< 0.500	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.100	µg/ft <sup>2</sup>	31
			Chromium	< 1.00	µg/ft <sup>2</sup>	3,094
			Lead	< 0.500	µg/ft <sup>2</sup>	10
			Selenium	< 2.50	µg/ft <sup>2</sup>	1,236
			Silver	< 0.500	µg/ft <sup>2</sup>	62

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-16	ICE JV warehouse	Break area table	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	3.1	µg/ft <sup>2</sup>	3,094
			Cadmium	0.18	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	3.5	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-17	ICE JV office	Floor in reception area	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	1.3	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	1.4	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-18	ICE JV conference room	Conference table	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.84	µg/ft <sup>2</sup>	3,094
			Cadmium	0.58	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	1.3	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-19	Goodwill break room	Floor sample	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.74	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-20	Goodwill laundry room	Top of mini refrigerator	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	41	µg/ft <sup>2</sup>	3,094
			Cadmium	3.0	µg/ft <sup>2</sup>	31
			Chromium	17	µg/ft <sup>2</sup>	3,094
			Lead	73	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	1.3	µg/ft <sup>2</sup>	62
110-W-21	Goodwill office	Floor sample	Arsenic	< 2.5	µg	--
			Barium	1.8	µg	--
			Cadmium	< 0.10	µg	--
			Chromium	< 1.0	µg	--
			Lead	1.8	µg	--
			Selenium	< 2.5	µg	--
			Silver	< 0.50	µg	--

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-22	ICE JV warehouse	Work station with vice	Arsenic	< 2.5	µg	62
			Barium	46	µg	3,094
			Cadmium	6.5	µg	31
			Chromium	25	µg	3,094
			Lead	44	µg	10
			Selenium	< 2.5	µg	1,236
			Silver	0.75	µg	62

\* Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [ $\mu\text{g}/\text{m}^3$ ] x  $10 \text{ m}^3/100\text{cm}^2$ ] / 15. Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

\*\* Indicates results at or above the Clean Area Limit

**APPENDIX B – LABORATORY ANALYSIS REPORT**



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Wipe Metals Analysis Report

**Client:** Burns & McDonnell Engineering  
9400 Ward Pkwy.  
Kansas City, MO 64114

**Report Number:** 21-06-04540

**Received Date:** 06/29/2021

**Analyzed Date:** 07/07/2021

**Reported Date:** 07/07/2021

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

**Client Number:**  
26-3514

# Laboratory Results

**Fax Number:**  
816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
21-06-04540-001	110-W-01	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.750	0.75	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-002	110-W-02	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.525	0.52	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 21-06-04540

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-003	110-W-03	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	45.8	46	L01
		Cadmium (Cd)	1.00	0.705	0.70	L01
		Chromium (Cr)	1.00	16.9	17	L01
		Lead (Pb)	1.00	72.1	72	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-004	110-W-04	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.770	0.77	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-005	110-W-05	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	<0.500	<0.50	L01



# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 21-06-04540

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-006	110-W-06	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.38	1.4	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-007	110-W-07	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.680	0.68	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 21-06-04540

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
21-06-04540-008	110-W-08	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.665	0.66	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-009	110-W-09	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.73	1.7	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	0.700	0.70	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-010	110-W-10	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.16	1.2	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 21-06-04540

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-011	110-W-11	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	15.3	15	L01
		Cadmium (Cd)	1.00	0.105	0.10	L01
		Chromium (Cr)	1.00	1.53	1.5	L01
		Lead (Pb)	1.00	4.76	4.8	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-012	110-W-12	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.590	0.59	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	0.505	0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-013	110-W-13	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	<0.500	<0.50	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 21-06-04540

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-014	110-W-14	Arsenic (As)		<2.50	---	L01
		Barium (Ba)		<0.500	---	L01
		Cadmium (Cd)		<0.100	---	L01
		Chromium (Cr)		<1.00	---	L01
		Lead (Pb)		<0.500	---	L01
		Selenium (Se)		<2.50	---	L01
		Silver (Ag)		<0.500	---	L01
21-06-04540-015	110-W-15	Arsenic (As)		<2.50	---	L01
		Barium (Ba)		<0.500	---	L01
		Cadmium (Cd)		<0.100	---	L01
		Chromium (Cr)		<1.00	---	L01
		Lead (Pb)		<0.500	---	L01
		Selenium (Se)		<2.50	---	L01
		Silver (Ag)		<0.500	---	L01
21-06-04540-016	110-W-16	Arsenic (As)	1.00	<2.50	<2.5	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 21-06-04540

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Barium (Ba)	1.00	3.09	3.1	L01
		Cadmium (Cd)	1.00	0.180	0.18	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	3.54	3.5	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-017	110-W-17	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.32	1.3	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	1.37	1.4	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-018	110-W-18	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.845	0.84	L01
		Cadmium (Cd)	1.00	0.575	0.58	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	1.30	1.3	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 21-06-04540

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-019	110-W-19	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.745	0.74	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-020	110-W-20	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	41.1	41	L01
		Cadmium (Cd)	1.00	3.02	3.0	L01
		Chromium (Cr)	1.00	17.1	17	L01
		Lead (Pb)	1.00	72.6	73	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	1.26	1.3	L01
21-06-04540-021	110-W-21	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.76	1.8	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 21-06-04540

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Lead (Pb)	1.00	1.83	1.8	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
21-06-04540-022	110-W-22	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	46.0	46	L01
		Cadmium (Cd)	1.00	6.52	6.5	L01
		Chromium (Cr)	1.00	25.3	25	L01
		Lead (Pb)	1.00	43.5	44	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	0.750	0.75	L01

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-06-04540

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
-------------------	----------------------	----------	------------------------------	------------------	-------------------------------------	--------------

Sample Narratives:

L01: The reporting limit for arsenic for all samples is 2.5 ug.

**Analyst:** Kailee Guthrie

**Method:** Mercury (Hg): EPA SW846 7471B

All other metals: EPA SW846 3050B/6010D

(b) (6)

Reviewed By Authorized Signatory:

*Tasha Eaddy*

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 50mL volume. The reporting limit for Cadmium is 0.10ug, Barium, Lead and Silver are 0.50ug, Arsenic and Chromium are 1.0ug, and Selenium is 2.5ug.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

Legend	ug = microgram	ug/ft <sup>2</sup> = micrograms per square foot
	mL = milliliter	ft <sup>2</sup> = square foot



# Metals Chain of Custody Form

Company Name: <b>Burns &amp; McDonnell</b>		Account #: <b>26-3514</b>	
Company Address: <b>9400 Ward Parkway</b>		City/State/Zip: <b>Kansas City, MO 64114</b>	
Phone: <b>314-302-4661</b>		Email: <b>eaahlemeyer@burnsmcd.com</b>	
Project Name / Testing Address: <b>GFC / 4300 Goodfellow Blvd</b>			
PO Number: <b>108705</b>	Collected By: <b>Emily Anlemeyer &amp; Ashley Anstaett</b>		
Turn-Around Time: <input checked="" type="checkbox"/> 3 DAY	<input type="checkbox"/> 2 DAY	<input type="checkbox"/> 1 DAY	<input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES AREA <small>Circle The Unit of Measurement Used</small> cm or (in)	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate		Vol.
																Mins.	L/min.		Total Liters
1	110-W-01	6/23/21 0704							Ag, As, Ba, Cd, Cr, Pb, Se										12 x 12
2	110-W-02																	12 x 12	
3	110-W-03		1337															12 x 12	
4	110-W-04		1346															12 x 12	
5	110-W-05		1351															12 x 12	
6	110-W-06		1352															12 x 12	
7	110-W-07		1400															12 x 12	
8	110-W-08		1403															12 x 12	
9	110-W-09		1409															12 x 12	
10	110-W-10		1414															12 x 12	
11	110-W-11		1420															12 x 12	
12	110-W-12		1425															12 x 12	
13	110-W-13		1430															12 x 12	
14	110-W-14		1435															NA x NA	
15	110-W-15		1435															NA x NA	

Released By: <b>Emily Anlemeyer</b>	Date: <b>6/25/21</b>	Time: <b>1600</b>
Signature: <b>(b) (6)</b>		

LAB USE ONLY - BELOW THIS LINE


Received By: **Stone**  
 Signature: **(b) (6)**  
 Date: **6/29/21** Time: **11:50**  AM  PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

21-06-04540



Due Date:  
**07/02/2021**  
(Friday)  
EL MM-L

# Metals Chain of Custody Form

Company Name	Account #
Company Address	City/State/Zip
Phone	Email
Project Name / Testing Address	
PO Number	Collected By
Turn-Around Time	

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES AREA Circle The Unit of Measurement Used cm or (in)	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate		Vol.
																Mins.	L/min.		Total Liters
1	110-W-16	6/23/21 1440							Ag, As, Ba, Cd, Cr, Pb, Se										12 x 12
2	110-W-17																		12 x 12
3	110-W-18																		12 x 12
4	110-W-19																		12 x 12
5	110-W-20																		12 x 12
6	110-W-21																		12 x 12
7	110-W-22																		12 x 12
8																			x
9																	x		
10																	x		
11																	x		
12																	x		
13																	x		
14																	x		
15																	x		

Released By: Emily Anlemeyer	Date: 6/25/21	Time: 1600
Signature: (b) (6)		

LAB USE ONLY - BELOW THIS LINE

Received By: TStone

Signature: (b) (6)

Date: 6/29/21 Time: 11:50  AM  PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

4540

EHS

Laboratories

Attach Laboratory Label Here