

Asset Number	Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2944394	1/15/2024	12:18 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944395	1/15/2024	12:19 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944392	1/15/2024	12:25 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐			0.48
2944391	1/15/2024	12:26 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944393	1/15/2024	12:27 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944380	1/15/2024	12:40 AM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	☑	☐	1.8		
2944378	1/15/2024	12:45 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944377	1/15/2024	12:45 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐			0.48
2944376	1/15/2024	12:46 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944369	1/15/2024	12:56 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944368	1/15/2024	12:57 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944365	1/15/2024	1:05 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944364	1/15/2024	1:06 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944363	1/15/2024	1:09 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944362	1/15/2024	1:10 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐			0.48
2944361	1/15/2024	1:11 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944350	1/15/2024	1:19 AM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	☑	☐	2.2		
2944338	1/15/2024	1:28 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944339	1/15/2024	1:29 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944347	1/15/2024	1:35 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐			0.48
2944346	1/15/2024	1:36 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944348	1/15/2024	1:37 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944334	1/15/2024	1:48 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944335	1/15/2024	1:49 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944410	1/15/2024	1:57 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	☑	☐	1.24		
2944332	1/15/2024	2:16 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐			0.48
2944331	1/15/2024	2:17 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944333	1/15/2024	2:23 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944322	1/15/2024	2:30 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	☑	☐	1.9		
2944318	1/15/2024	2:37 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944316	1/15/2024	2:39 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944309	1/15/2024	2:53 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944308	1/15/2024	2:54 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944191	1/15/2024	2:56 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944305	1/15/2024	3:01 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944304	1/15/2024	3:02 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944303	1/15/2024	3:06 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944302	1/15/2024	3:07 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐			0.48
2944301	1/15/2024	3:08 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944291	1/15/2024	3:20 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	☑	☐	1.9		
2944289	1/15/2024	3:24 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944288	1/15/2024	3:26 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐			0.48
2944280	1/15/2024	3:37 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944279	1/15/2024	3:38 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944275	1/15/2024	3:42 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944273	1/15/2024	3:47 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944272	1/15/2024	3:48 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐			0.48
2944271	1/15/2024	3:49 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944262	1/15/2024	4:05 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	☑	☐	1.7		
2944258	1/15/2024	4:09 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944257	1/15/2024	4:11 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐			0.48
2944249	1/15/2024	4:24 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944248	1/15/2024	4:26 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944237	1/15/2024	4:41 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944236	1/15/2024	4:43 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944235	1/15/2024	4:45 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944234	1/15/2024	4:47 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐			0.48
2944233	1/15/2024	4:48 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944240	1/15/2024	4:55 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	☑	☐	1.8		
2944218	1/15/2024	5:03 AM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	☑	☐	1.9		
2944215	1/15/2024	5:06 AM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐			0.48
2944214	1/15/2024	5:09 AM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944213	1/15/2024	5:11 AM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	☑	☐			0.48
2944212	1/15/2024	5:12 AM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐			0.48
2944211	1/15/2024	5:13 AM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐			0.48
2944202	1/15/2024	5:28 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944201	1/15/2024	5:30 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944413	1/15/2024	12:20 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	☑	☐			0.48
2944190	1/15/2024	3:10 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐			0.48
2944189	1/15/2024	3:10 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48
2944182	1/15/2024	3:30 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐			0.48
2944181	1/15/2024	3:30 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐			0.48

2944177	1/15/2024	3:40 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐				0.48
2944176	1/15/2024	3:50 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐				0.48
2944175	1/15/2024	3:50 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐				0.48
2944174	1/15/2024	3:50 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐				0.48
2944158	1/15/2024	4:15 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐				0.48
2944157	1/15/2024	4:15 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐				0.48
2944156	1/15/2024	4:25 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐				0.48
2944155	1/15/2024	4:25 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐				0.48
2944154	1/15/2024	4:25 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐				0.48
2944147	1/15/2024	4:45 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐				0.48
2944146	1/15/2024	4:45 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐				0.48
2944136	1/15/2024	4:45 PM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	☑	☐				
2944145	1/15/2024	4:56 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐				0.48
2944144	1/15/2024	4:56 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐				0.48
2944143	1/15/2024	4:56 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐				0.48
2944105	1/15/2024	5:17 PM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	☑	☐				0.48
2944103	1/15/2024	5:37 PM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	☑	☐			2.00	
2944100	1/15/2024	5:47 PM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	☑	☐			3.75	
2944082	1/15/2024	5:57 PM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	☑	☐				0.48
2944081	1/15/2024	5:57 PM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	☑	☐				0.48
2944070	1/15/2024	6:07 PM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	☑	☐				0.48
2944069	1/15/2024	6:07 PM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	☑	☐				0.48
2944076	1/15/2024	6:17 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	☑	☐				0.48
2944075	1/15/2024	6:17 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	☑	☐				0.48
2944064	1/15/2024	6:27 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	☑	☐				0.48
2944063	1/15/2024	6:27 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	☑	☐				0.48
2944062	1/15/2024	6:27 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	☑	☐				0.48
2944058	1/15/2024	6:37 PM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	☑	☐		1.76	1.66	
2944057	1/15/2024	6:37 PM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	☑	☐		2.50	2.14	
2944055	1/15/2024	6:47 PM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	☑	☑		0.73		
2944045	1/15/2024	6:57 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	☑	☐				0.48
2944044	1/15/2024	6:57 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	☑	☐				0.48
2944041	1/15/2024	6:57 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	☑	☐				0.48
2944040	1/15/2024	6:57 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	☑	☐				0.48
2944398	1/15/2024	11:47 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐				0.48
2944399	1/15/2024	11:48 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐				0.48
2944406	1/15/2024	11:58 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐				0.48
2944408	1/15/2024	11:59 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐				0.48
2944228	1/16/2024	12:45 AM	Floor 05	540 Faucet (507-26)	2	☑	☐		1.2	1.2	
2944290	1/16/2024	8:05 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	☑	☐		1.2	1.2	
2945145	1/16/2024	8:15 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	☑	☐				0.81
2944278	1/16/2024	8:27 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	☑	☐		1.2	1.3	
2945143	1/16/2024	8:37 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	☑	☐				0.76
2944261	1/16/2024	8:48 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	☑	☐		1.3	1.2	
2944296	1/16/2024	9:00 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	☑	☐		1.1	1.0	
2944319	1/16/2024	9:12 AM	Floor 07	Suite 710 Faucet (710-03)	2	☑	☐		1.2	1.2	
2944386	1/16/2024	9:19 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	☑	☐		1.3	0.96	
2944320	1/16/2024	9:25 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	☑	☐		1.2	1.0	
2944349	1/16/2024	9:38 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	☑	☑		1.1		
2944385	1/16/2024	9:39 AM	Floor 10	Suite 1010 Lavatory Faucet	1	☑	☐				0.48
2944321	1/16/2024	9:49 AM	Floor 08	Suite 810 Kitchen Faucet	1	☑	☑		1.2		
2944356	1/16/2024	10:02 AM	Floor 09	Suite 910A Faucet (910-05)	2	☑	☐		1.1	1.1	
2944379	1/16/2024	10:09 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	☑	☐		1.1	1.0	
2944355	1/16/2024	10:16 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	☑	☐		1.2	1.1	
2944411	1/16/2024	10:45 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	☑	☐		1.2	1.2	
2944409	1/16/2024	10:58 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	☑	☐		1.2	1.2	
2944259	1/16/2024	11:15 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	☑	☐		1.2	1.0	
2944418	1/16/2024	11:28 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	☑	☐		1.1	1.0	
2944227	1/16/2024	11:42 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	☑	☐		1.1	1.1	
2945142	1/16/2024	12:32 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	☑	☐		1.3		
2944226	1/16/2024	1:00 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	☑	☐		1.2	1.1	
2945147	1/16/2024	1:15 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	☑	☐		1.1	1.0	
2944247	1/16/2024	1:28 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	☑	☐		1.2		
2944126	1/17/2024	1:44 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	☑	☐				0.48
2944224	1/17/2024	7:50 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	☑	☐		1.2	1.2	
2944222	1/17/2024	8:02 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	☑	☐		1.4		
2944225	1/17/2024	8:08 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	☑	☐		1.07	1.07	
2945144	1/17/2024	8:08 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	☑	☐				0.6
2944221	1/17/2024	8:15 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	☑	☐		1.2	1.1	
2944163	1/17/2024	8:29 AM	Floor 02	234 Kitchen Faucet (209-04)	2	☑	☐		1.2	1.3	
2944223	1/17/2024	8:41 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	☑	☐		1.07	0.85	
2944164	1/17/2024	8:42 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	☑	☐		1.3	1.2	
2944165	1/17/2024	8:55 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	☑	☐		1.0	1.2	
2944166	1/17/2024	9:09 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	☑	☐		1.2	1.2	
2944059	1/17/2024	9:23 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	☑	☐		1.2	1.3	

2944096	1/17/2024	9:35 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	0
2944097	1/17/2024	9:46 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
2944099	1/17/2024	9:57 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	1.1	
2944107	1/17/2024	10:06 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.11
2944098	1/17/2024	10:08 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
2944110	1/17/2024	10:17 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
2944422	1/17/2024	10:20 AM	Floor 01	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.7	1.5	
2944108	1/17/2024	10:29 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
2944089	1/17/2024	10:34 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.6	
2944127	1/17/2024	10:44 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
2944086	1/17/2024	10:48 AM	Floor 01	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.5	
2944128	1/17/2024	10:58 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
2944087	1/17/2024	11:02 AM	Floor 01	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.20
2944132	1/17/2024	11:12 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.72
2944088	1/17/2024	11:14 AM	Floor 01	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
2944134	1/17/2024	11:25 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.30
2944135	1/17/2024	11:25 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			3.00
2944090	1/17/2024	11:28 AM	Floor 01	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
2944133	1/17/2024	11:35 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.50
2944114	1/17/2024	11:37 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
2944115	1/17/2024	11:37 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
2944116	1/17/2024	11:37 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
2944091	1/17/2024	11:40 AM	Floor 01	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
2944120	1/17/2024	11:50 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.72
2944121	1/17/2024	11:50 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.50
2944122	1/17/2024	11:50 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.72
2944123	1/17/2024	11:50 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.72
2944124	1/17/2024	11:50 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.50
2944092	1/17/2024	1:30 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
2944093	1/17/2024	1:45 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
2944095	1/17/2024	1:58 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
2944094	1/17/2024	2:13 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
2944106	1/17/2024	2:30 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.8	1.9	
2944421	1/17/2024	2:45 PM	Floor LL	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.42		
2944054	1/17/2024	3:08 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.96	0.93	
2944050	1/17/2024	3:20 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
2944052	1/17/2024	3:20 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
2944125	1/17/2024	4:51 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			3.00
						<input type="checkbox"/>	<input type="checkbox"/>			
						<input type="checkbox"/>	<input type="checkbox"/>			
						<input type="checkbox"/>	<input type="checkbox"/>			
						<input type="checkbox"/>	<input type="checkbox"/>			
						<input type="checkbox"/>	<input type="checkbox"/>			
						<input type="checkbox"/>	<input type="checkbox"/>			
						<input type="checkbox"/>	<input type="checkbox"/>			
						<input type="checkbox"/>	<input type="checkbox"/>			
						<input type="checkbox"/>	<input type="checkbox"/>			

**985 Federal Building**  
**Weekly .2 Micron Filter Inspection Exception Report**  
**From 01/14/2024 to 01/19/2024**

**There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.**

**Outlets w/Filters that are not included in the log**

<b>Planned Date</b>	<b>Asset Number</b>	<b>Publication Description</b>
1/15/2024	2944407	10W-1 Women's Restroom East - Lavatory Faucet-Center
1/15/2024	2944317	7W-1 Women's Restroom East - Lavatory Faucet-Center
1/15/2024	2944287	6W-1 Women's Restroom East - Lavatory Faucet-Left
1/15/2024	2944274	6M-2 Men's Restroom West - Lavatory Faucet-Left
1/15/2024	2944256	5W-1 Women's Restroom East - Lavatory Faucet-Left
1/15/2024	2944200	4W-1 Women's Restroom East - Lavatory Faucet-Right
1/15/2024	2944199	4W-1 Women's Restroom East - Lavatory Faucet-Center
1/15/2024	2944198	4W-1 Women's Restroom East - Lavatory Faucet-Left
1/15/2024	2944074	1W-1 Women's Restroom North - Lavatory Faucet-Left
1/16/2024	2944419	Suite. 540 Kitchenette - Faucet
1/16/2024	2944416	Suite 608 Kitchen - Faucet
1/16/2024	2944260	Suite 520 Kitchenette Faucet (508-13)