

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
1/22/2024	1:46 AM	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	1:47 AM	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	1:50 AM	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	2:09 AM	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	2:10 AM	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	2:15 AM	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
1/22/2024	2:17 AM	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/22/2024	2:18 AM	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	2:40 AM	1U-1 Loading Dock - Lavatory Faucet	2	☑	☐	0.5			0.48
1/22/2024	2:44 AM	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	☑	☐		2.6		
1/22/2024	2:46 AM	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
1/22/2024	2:49 AM	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	2:49 AM	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.42
1/22/2024	2:55 AM	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
1/22/2024	2:56 AM	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
1/22/2024	3:00 AM	C607-Janitor's Closet - Mop/Slop Sink	1	☑	☐		2.0		
1/22/2024	3:06 AM	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	3:09 AM	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
1/22/2024	3:11 AM	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	3:12 AM	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/22/2024	3:12 AM	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	5:23 AM	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/22/2024	5:24 AM	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	5:30 AM	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	5:31 AM	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/22/2024	5:33 AM	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	5:37 AM	108-4 Cafe Prep. - Kitchen Faucet-Small	1	☑	☐	1.5	1.6	1.6	
1/22/2024	5:39 AM	108-4 Cafe Prep. - Kitchen Faucet-Large	1	☑	☐	1.5	1.4	1.4	
1/22/2024	5:54 AM	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	5:55 AM	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	6:00 AM	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	6:01 AM	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	6:07 AM	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	☑	☐		1.4		
1/22/2024	6:13 AM	LLM-1 Men-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	6:15 AM	LLM-1 Men-Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	6:28 AM	LLW-1 Women-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	6:35 AM	LLW-1 Women-Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	1:27 PM	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	☑	☐	1.5	1.2	0.78	
1/22/2024	7:20 PM	C1007-Janitor's Closet-Mop/Slop Sink	1	☑	☐		2.72		
1/22/2024	7:25 PM	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	7:25 PM	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	7:55 PM	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/22/2024	7:55 PM	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	7:58 PM	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	7:59 PM	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.42
1/22/2024	7:59 PM	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
1/22/2024	7:59 PM	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	8:00 PM	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
1/22/2024	8:02 PM	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	8:15 PM	C907-Janitor's Closet-Mop/Slop Sink	1	☑	☐		2.6		
1/22/2024	8:16 PM	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	8:17 PM	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/22/2024	8:18 PM	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	8:25 PM	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
1/22/2024	8:28 PM	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
1/22/2024	8:29 PM	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	8:30 PM	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	8:31 PM	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	8:31 PM	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/22/2024	8:31 PM	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	8:38 PM	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	8:38 PM	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/22/2024	8:39 PM	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	8:42 PM	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/22/2024	8:42 PM	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/22/2024	8:49 PM	C507 Janitor's Closet - Mop/Slop Sink	1	☑	☑		3.0		

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
1/22/2024	8:52 PM	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	8:53 PM	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	8:55 PM	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	8:56 PM	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	8:57 PM	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:00 PM	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
1/22/2024	9:00 PM	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
1/22/2024	9:01 PM	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:01 PM	C407 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		3.3		
1/22/2024	9:05 PM	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:05 PM	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:08 PM	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:10 PM	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:10 PM	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:10 PM	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:13 PM	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:15 PM	C807-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.4		
1/22/2024	9:17 PM	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:19 PM	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.5			
1/22/2024	9:22 PM	4W-2 Women West-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:23 PM	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:23 PM	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:23 PM	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:24 PM	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:25 PM	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
1/22/2024	9:30 PM	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:30 PM	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:39 PM	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:40 PM	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
1/22/2024	9:40 PM	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:41 PM	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
1/22/2024	9:41 PM	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
1/22/2024	9:43 PM	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
1/22/2024	9:45 PM	C707-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.16		
1/22/2024	9:50 PM	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:50 PM	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
1/22/2024	9:50 PM	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
1/22/2024	10:00 PM	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	10:02 PM	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	10:04 PM	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	10:17 PM	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	10:18 PM	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	10:26 PM	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	10:30 PM	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	10:31 PM	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	10:32 PM	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	11:03 PM	E201 Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/22/2024	9:42 P	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
1/23/2024	8:04 AM	Suite 620 Break Room-Kitchen Faucet (608-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.10	
1/23/2024	8:14 AM	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		0.81	
1/23/2024	8:25 AM	Suite 608 Kitchen - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.42	0.85	
1/23/2024	8:26 AM	Suite 614 Room-Kitchen Faucet (610-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.20	
1/23/2024	8:39 AM	Suite 710 Faucet (710-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.10	
1/23/2024	8:52 AM	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.20	
1/23/2024	8:52 AM	Suite 707-01 Break Room - Faucet (707-2)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.11	0.57	
1/23/2024	9:07 AM	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.10	1.00	
1/23/2024	9:20 AM	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	0.78	
1/23/2024	9:28 AM	Suite 810 Kitchen Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.15	1.07	
1/23/2024	9:51 AM	Suite 808A Break Room Faucet (809-02)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.15	0.83	
1/23/2024	9:55 AM	Suite 910A Faucet (910-05)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.00	1.10	
1/23/2024	10:08 AM	Suite 707-10 Faucet (707-07)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.30	0.78	
1/23/2024	10:15 AM	Suite 908 Break Room Faucet (908-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.20	
1/23/2024	10:32 AM	Suite 907A Break Room Faucet (907-22)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.10	
1/23/2024	10:36 AM	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.39	1.20	
1/23/2024	10:53 AM	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.20	
1/23/2024	11:30 AM	Suite 415 Kitchenette - Faucet (N)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.5		

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
1/23/2024	1:00 PM	Suite 535 Break Room-Kitchen Faucet (507-36)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.20	
1/23/2024	1:13 PM	Suite 1010 Kitchenette Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.15	
1/23/2024	1:15 PM	Suite 532 Lactation Room - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.00	
1/23/2024	1:34 PM	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5			0.48
1/23/2024	2:09 PM	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.20	1.00	
1/23/2024	2:11 PM	Suite 520 Kitchenette Faucet (508-13)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	0.90	0.75	
1/23/2024	2:28 PM	Suite 530 Kitchenette - Faucet (509-10)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/24/2024	8:02 AM	Suite 416 Kitchenette - Faucet (NE) - North	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	0.79	
1/24/2024	8:15 AM	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.0	
1/24/2024	8:15 AM	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
1/24/2024	8:20 AM	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.4	0.5	
1/24/2024	8:25 AM	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		0.5	
1/24/2024	8:45 AM	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/24/2024	9:00 AM	Suite 410 Kitchenette Faucet (NW)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	0.78	
1/24/2024	9:16 AM	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/24/2024	9:27 AM	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/24/2024	9:38 AM	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/24/2024	9:49 AM	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/24/2024	10:00 AM	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.5			1.11
1/24/2024	10:00 AM	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
1/24/2024	10:05 AM	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/24/2024	10:15 AM	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.6	1.2	
1/24/2024	10:15 AM	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/24/2024	10:27 AM	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6	1.6	1.3	
1/24/2024	10:40 AM	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/24/2024	10:42 AM	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.6	1.5	
1/24/2024	10:45 AM	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/24/2024	10:47 AM	126-05 Men-Lavatory Faucet-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
1/24/2024	10:58 AM	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>				1.2
1/24/2024	10:59 AM	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/24/2024	11:00 AM	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/24/2024	11:05 AM	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/24/2024	11:08 AM	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/24/2024	11:10 AM	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.32	1.24	
1/24/2024	11:10 AM	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.0
1/24/2024	11:12 AM	126-06 Shower Room - Shower-South-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/24/2024	11:15 AM	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/24/2024	11:24 AM	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			1.4
1/24/2024	11:30 AM	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			1.3
1/24/2024	11:31 AM	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			1.3
1/24/2024	11:33 AM	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			1.4
1/24/2024	11:36 AM	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/24/2024	11:36 AM	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/24/2024	11:38 AM	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/24/2024	11:40 AM	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.92	1.92	
1/24/2024	11:50 AM	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/24/2024	12:45 PM	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/24/2024	1:03 PM	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/24/2024	1:15 PM	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.04	0.3	
1/24/2024	1:20 PM	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/24/2024	1:25 PM	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.5			0.28
1/24/2024	1:28 PM	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/24/2024	1:45 PM	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.2		
1/24/2024	11:24 PM	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			

**985 Federal Building**  
**Weekly .2 Micron Filter Inspection Exception Report**  
**From 01/21/2024 to 01/27/2024**

**There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.**

**Outlets w/Filters that are not included in the log**

<b>Planned Date</b>	<b>Asset Number</b>	<b>Publication Description</b>
1/22/2024	2944155	2W-1 Women's Restroom East - Lavatory Faucet-Center
1/22/2024	2944154	2W-1 Women's Restroom East - Lavatory Faucet-Left
1/22/2024	2944136	C207 Janitor's Closet-Mop/Slop Sink
1/22/2024	2944100	C105-1 Janitor's Closet - Mop/Slop Sink
1/22/2024	2944074	1W-1 Women's Restroom North - Lavatory Faucet-Left
1/23/2024	2944419	Suite. 540 Kitchenette - Faucet
1/23/2024	2944278	Suite 615 Break Room-Kitchen Faucet (607-06)
1/23/2024	2945143	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)
1/23/2024	2944228	540 Faucet (507-26)
1/24/2024	2944224	Suite 420 Kitchenette - Faucet (NE) - South
1/24/2024	2944088	119-17 Toilet/Sink Combo