

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
1/29/2024	12:56 AM	C407 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.0		
1/29/2024	12:59 AM	4W-2 Women West-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:00 AM	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:00 AM	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
1/29/2024	1:06 AM	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:06 AM	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:10 AM	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
1/29/2024	1:10 AM	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:20 AM	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:20 AM	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:20 AM	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:27 AM	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:28 AM	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:28 AM	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:34 AM	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:34 AM	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:43 AM	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:50 AM	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.8
1/29/2024	1:50 AM	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	1:50 AM	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:00 AM	E201 Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:16 AM	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:17 AM	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:20 AM	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:20 AM	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:24 AM	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:24 AM	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:24 AM	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:30 AM	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:30 AM	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:33 AM	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:34 AM	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:34 AM	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:34 AM	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:34 AM	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:37 AM	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:39 AM	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:41 AM	1U-1 Loading Dock - Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:46 AM	C507 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.7		
1/29/2024	2:46 AM	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.16		
1/29/2024	2:52 AM	C105-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.0		
1/29/2024	2:55 AM	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:55 AM	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	2:56 AM	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:02 AM	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:02 AM	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:08 AM	108-4 Cafe Prep. - Kitchen Faucet-Large	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	0.68	1.22	
1/29/2024	3:10 AM	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:16 AM	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:16 AM	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:20 AM	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:23 AM	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:34 AM	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.00		
1/29/2024	3:36 AM	LLM-1 Men-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:51 AM	LLM-1 Men-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:51 AM	LLW-1 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	3:51 AM	LLW-1 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	10:05 PM	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	10:06 PM	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	10:12 PM	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
1/29/2024	10:13 PM	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	10:14 PM	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	10:28 PM	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	10:29 PM	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	10:35 PM	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/29/2024	10:36 PM	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
1/29/2024	10:37 PM	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/29/2024	10:46 PM	C1007-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.6		
1/29/2024	10:50 PM	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	☑	☐	1.5	0.92	1.0	
1/29/2024	10:56 PM	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/29/2024	10:57 PM	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/29/2024	10:58 PM	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/29/2024	11:10 PM	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/29/2024	11:11 PM	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/29/2024	11:21 PM	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/29/2024	11:22 PM	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/29/2024	11:45 PM	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/29/2024	11:46 PM	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/29/2024	11:47 PM	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/29/2024	11:54 PM	C907-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.7		
1/29/2024	238 AM	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/29/2024	3:08 ANM	108-4 Cafe Prep. - Kitchen Faucet-Small	1	☑	☐	1.5	0.68	1.21	
1/30/2024	12:02 AM	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	12:03 AM	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	12:08 AM	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/30/2024	12:09 AM	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	12:10 AM	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	12:18 AM	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	12:19 AM	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	12:25 AM	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/30/2024	12:26 AM	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	12:27 AM	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	12:36 AM	C807-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.8		
1/30/2024	12:42 AM	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	12:52 AM	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	12:54 AM	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	1:00 AM	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	1:01 AM	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	1:04 AM	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	1:05 AM	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/30/2024	1:06 AM	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	1:18 AM	C707-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.8		
1/30/2024	1:22 AM	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	1:23 AM	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/30/2024	1:24 AM	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	1:31 AM	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	1:32 AM	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	1:43 AM	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	1:47 AM	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	1:48 AM	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/30/2024	1:49 AM	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	1:59 AM	C607-Janitor's Closet - Mop/Slop Sink	1	☑	☐		1.8		
1/30/2024	2:04 AM	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
1/30/2024	2:05 AM	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
1/30/2024	2:06 AM	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
1/30/2024	8:00 AM	Suite 620 Break Room-Kitchen Faucet (608-12)	2	☑	☐	1.5	1.2	1.1	
1/30/2024	8:08 AM	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	☑	☐	1.5		0.85	
1/30/2024	8:19 AM	Suite 615 Break Room-Kitchen Faucet (607-06)	2	☑	☐	1.5	1.2	1.0	
1/30/2024	8:26 AM	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	☑	☐	1.5		0.78	
1/30/2024	8:37 AM	Suite 614 Room-Kitchen Faucet (610-03)	2	☑	☐	1.5	1.2	1.2	
1/30/2024	8:49 AM	Suite 608 Kitchen - Faucet	2	☑	☐	1.5	1.2	1.0	
1/30/2024	9:01 AM	Suite 707-01 Break Room - Faucet (707-2)	2	☑	☐	1.5	1.2	1.2	
1/30/2024	9:13 AM	Suite 710 Faucet (710-03)	2	☑	☐	1.5	1.2	1.2	
1/30/2024	9:26 AM	Suite 707-10 Faucet (707-07)	2	☑	☐	1.5	1.2	1.2	
1/30/2024	9:39 AM	Suite 810 Kitchen Faucet	1	☑	☐	1.5	1.3	1.2	
1/30/2024	9:50 AM	Suite 808A Break Room Faucet (809-02)	1	☑	☐	1.5	1.2	1.0	
1/30/2024	9:51 AM	Suite 907A Break Room Faucet (907-22)	2	☑	☐	1.5	1.0		
1/30/2024	10:13 AM	Suite 910A Faucet (910-05)	2	☑	☐	1.5	1.2	1.2	
1/30/2024	10:26 AM	Suite 908 Break Room Faucet (908-15)	2	☑	☐	1.5	1.2	1.1	
1/30/2024	10:26 AM	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	☑	☐	1.5	1.2	1.2	
1/30/2024	10:38 AM	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	☑	☐	1.5	1.2	1.2	
1/30/2024	10:52 AM	Suite 1010 Kitchenette Faucet	2	☑	☐	1.5	1.2	1.1	

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
1/30/2024	11:14 AM	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5			0.48
1/30/2024	11:28 AM	Suite 530 Kitchenette - Faucet (509-10)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
1/30/2024	12:48 PM	Suite 535 Break Room-Kitchen Faucet (507-36)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.0	
1/30/2024	1:00 PM	Suite 532 Lactation Room - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.0	0.78	
1/30/2024	1:13 PM	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/30/2024	1:26 PM	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
1/30/2024	1:39 PM	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.2		
1/30/2024	1:54 PM	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	0.84	
1/31/2024	1:39 AM	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.5
1/31/2024	8:01 AM	Suite 420 Kitchenette - Faucet (NE) - South	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/31/2024	8:10 AM	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.03	1.0	
1/31/2024	8:12 AM	Suite 410 Kitchenette Faucet (NW)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	0.98	
1/31/2024	8:23 AM	Suite 416 Kitchenette - Faucet (NE) - North	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.2		
1/31/2024	8:30 AM	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		0.06	
1/31/2024	8:35 AM	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
1/31/2024	8:46 AM	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
1/31/2024	8:49 AM	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.25	1.2	
1/31/2024	8:57 AM	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
1/31/2024	9:09 AM	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/31/2024	9:19 AM	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			1.15
1/31/2024	9:20 AM	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/31/2024	9:22 AM	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/31/2024	9:30 AM	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/31/2024	9:41 AM	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
1/31/2024	9:45 AM	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/31/2024	9:51 AM	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/31/2024	10:03 AM	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.6	1.2	
1/31/2024	10:14 AM	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6	1.7	0.78	
1/31/2024	10:15 AM	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/31/2024	10:26 AM	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.7	1.5	
1/31/2024	10:28 AM	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/31/2024	10:38 AM	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>				1.2
1/31/2024	10:40 AM	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/31/2024	10:49 AM	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.72
1/31/2024	10:50 AM	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/31/2024	11:00 AM	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.5
1/31/2024	11:07 AM	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/31/2024	11:10 AM	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/31/2024	11:20 AM	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/31/2024	11:20 AM	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.72
1/31/2024	11:30 AM	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/31/2024	11:40 AM	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/31/2024	11:50 AM	126-05 Men-Lavatory Faucet-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
1/31/2024	12:45 PM	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/31/2024	12:57 PM	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/31/2024	1:12 PM	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/31/2024	1:26 PM	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
1/31/2024	1:28 PM	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/31/2024	1:28 PM	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/31/2024	1:28 PM	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
1/31/2024	1:39 PM	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
1/31/2024	1:51 PM	126-06 Shower Room - Shower-South-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.72
1/31/2024	2:20 PM	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
1/31/2024	2:50 PM	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		1.76	0.72	
1/31/2024	3:09 PM	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.03	0.74	
1/31/2024	3:22 PM	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
1/31/2024	3:46 PM	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42

985 Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 01/28/2024 to 02/03/2024

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
1/29/2024	2944317	7W-1 Women's Restroom East - Lavatory Faucet-Center
1/29/2024	2944316	7W-1 Women's Restroom East - Lavatory Faucet-Left
1/29/2024	2944274	6M-2 Men's Restroom West - Lavatory Faucet-Left
1/29/2024	2944136	C207 Janitor's Closet-Mop/Slop Sink
1/30/2024	2944419	Suite. 540 Kitchenette - Faucet
1/30/2024	2944260	Suite 520 Kitchenette Faucet (508-13)
1/30/2024	2944228	540 Faucet (507-26)
1/31/2024	2944222	Suite 415 Kitchenette - Faucet (N)