

| Date | Time | Floor | Location / Plumbing Outlet (For Publication) | Number of Filters | Filter(s) Inspected | Filter(s) Replaced | Cold Flow Rate (GPM) | Hot Flow Rate (GPM) | Mixed Flow Rate (GPM) |
|------------|----------|----------|--|----------------------|-------------------------------------|--------------------------|----------------------------|---------------------------|-----------------------------|
| 11/13/2023 | 12:52 AM | Floor 10 | 10M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 1:22 AM | Floor 10 | 10W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 1:22 AM | Floor 10 | 10W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.666 |
| 11/13/2023 | 1:24 AM | Floor 10 | 10W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 1:49 AM | Floor 10 | 10M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 2:02 AM | Floor 10 | 10M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 2:19 AM | Floor 10 | 10W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.5 |
| 11/13/2023 | 2:19 AM | Floor 10 | 10W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 2:21 AM | Floor 10 | 10W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.54 |
| 11/13/2023 | 2:42 AM | Floor 10 | C1007-Janitor's Closet-Mop/Slop Sink | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 1.8 |
| 11/13/2023 | 2:58 AM | Floor 09 | 9M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.36 |
| 11/13/2023 | 3:07 AM | Floor 09 | 9M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 3:15 AM | Floor 10 | 9W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.54 |
| 11/13/2023 | 3:15 AM | Floor 09 | 9W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 3:16 AM | Floor 09 | 9W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 3:31 AM | Floor 09 | 9M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 3:39 AM | Floor 09 | 9M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.54 |
| 11/13/2023 | 3:41 AM | Floor 09 | 9W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.36 |
| 11/13/2023 | 3:41 AM | Floor 09 | 9W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 3:45 AM | Floor 09 | 9W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 3:57 AM | Floor 09 | C907-Janitor's Closet-Mop/Slop Sink | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | 0.24 | |
| 11/13/2023 | 4:04 AM | Floor 08 | 8M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.8 |
| 11/13/2023 | 4:14 AM | Floor 08 | 8M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 4:18 AM | Floor 08 | 8W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 4:18 AM | Floor 08 | 8W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 4:21 AM | Floor 08 | 8W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 4:38 AM | Floor 08 | 8M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.54 |
| 11/13/2023 | 4:44 AM | Floor 08 | 8W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 4:45 AM | Floor 08 | 8W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.54 |
| 11/13/2023 | 4:45 AM | Floor 08 | 8W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 4:55 AM | Floor 08 | C807-Janitor's Closet-Mop/Slop Sink | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.37 |
| 11/13/2023 | 11:00 AM | Floor 08 | 7W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 11:00 AM | Floor 07 | 7W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 11:00 AM | Floor 07 | 7W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 11:34 AM | Floor 07 | 7M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 11:34 AM | Floor 07 | 7M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 12:15 PM | Floor 10 | 10M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.54 |
| 11/13/2023 | 1:37 PM | Floor 07 | 7M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 1:37 PM | Floor 07 | 7M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 1:58 PM | Floor 07 | 7W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 1:58 PM | Floor 07 | 7W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 1:58 PM | Floor 07 | 7W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 2:11 PM | Floor 07 | C707-Janitor's Closet-Mop/Slop Sink | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.44 |
| 11/13/2023 | 4:30 PM | Floor 08 | 8M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 4:30 PM | Floor 07 | 6W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 4:30 PM | Floor 06 | 6W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 4:30 PM | Floor 06 | 6W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.42 |
| 11/13/2023 | 4:30 PM | Floor 06 | 6M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.54 |
| 11/13/2023 | 4:30 PM | Floor 06 | 6M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 5:15 PM | Floor 06 | 6M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 5:15 PM | Floor 06 | 6M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.36 |
| 11/13/2023 | 5:37 PM | Floor 06 | 6W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 5:37 PM | Floor 06 | 6W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 5:37 PM | Floor 06 | 6W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 5:53 PM | Floor 06 | C607-Janitor's Closet - Mop/Slop Sink | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.36 |
| 11/13/2023 | 6:04 PM | Floor 06 | 5W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 6:04 PM | Floor 05 | 5W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 6:04 PM | Floor 05 | 5W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 6:46 PM | Floor 05 | 5M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 6:46 PM | Floor 05 | 5M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 9:16 PM | Floor 05 | C507 Janitor's Closet - Mop/Slop Sink | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 9:20 PM | Floor 05 | 5M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 9:20 PM | Floor 05 | 5M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/13/2023 | 9:26 PM | Floor 05 | 5W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 9:26 PM | Floor 05 | 5W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 9:26 PM | Floor 05 | 5W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/13/2023 | 9:35 PM | Floor 04 | C407 Janitor's Closet-Mop/Slop Sink | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |

| Date | Time | Floor | Location / Plumbing Outlet (For Publication) | Number of Filters | Filter(s) Inspected | Filter(s) Replaced | Cold Flow Rate (GPM) | Hot Flow Rate (GPM) | Mixed Flow Rate (GPM) |
|------------|----------|------------|---|-------------------|---------------------|--------------------|----------------------|---------------------|-----------------------|
| 11/13/2023 | 9:42 PM | Floor 04 | 4M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 9:46 PM | Floor 04 | 4M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.448 |
| 11/13/2023 | 9:50 PM | Floor 04 | 4W-2 Women West-Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 9:50 PM | Floor 04 | 4W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 9:50 PM | Floor 04 | 4W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 10:11 PM | Floor 04 | 4M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 10:11 PM | Floor 04 | 4M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 10:16 PM | Floor 04 | 4W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 10:16 PM | Floor 04 | 4W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 10:16 PM | Floor 04 | 4W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 11/13/2023 | 10:38 PM | Floor 03 | 3W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 10:38 PM | Floor 03 | 3W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 10:40 PM | Floor 03 | 3W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 11/13/2023 | 10:49 PM | Floor 03 | 3M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 10:49 PM | Floor 03 | 3M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 11:01 PM | Floor 03 | 3M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 11/13/2023 | 11:07 PM | Floor 03 | 3W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 11:07 PM | Floor 03 | 3W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 11/13/2023 | 11:07 PM | Floor 03 | 3W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:11 AM | Floor 02 | 2M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:11 AM | Floor 02 | 2M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:11 AM | Floor 02 | 2W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:16 AM | Floor 02 | 2W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:16 AM | Floor 02 | 2W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 11/14/2023 | 12:44 AM | Floor 02 | 2M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:44 AM | Floor 02 | 2M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:53 AM | Floor 02 | 2W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:53 AM | Floor 02 | 2W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 12:55 AM | Floor 02 | 2W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 1:16 AM | Floor 02 | C207 Janitor's Closet-Mop/Slop Sink | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 1:24 AM | Floor 02 | 1U-1 Loading Dock - Lavatory Faucet | 2 | ☑ | ☐ | | | 0.48 |
| 11/14/2023 | 1:24 AM | Floor 01 | 114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink | 2 | ☑ | ☐ | | | |
| 11/14/2023 | 1:41 AM | Floor 01 | C105-1 Janitor's Closet - Mop/Slop Sink | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:00 AM | Floor 01 | 1W-2 Women's Restroom South - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:00 AM | Floor 01 | 1W-2 Women's Restroom South - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:06 AM | Floor 01 | 1W-1 Women's Restroom North - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:06 AM | Floor 01 | 1W-1 Women's Restroom North - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:06 AM | Floor 01 | 1W-1 Women's Restroom North - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 11/14/2023 | 2:14 AM | Floor 01 | 1M-1 Men's Restroom North - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:14 AM | Floor 01 | 1M-1 Men's Restroom North - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:14 AM | Floor 01 | 1M-1 Men's Restroom North - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 11/14/2023 | 2:24 AM | Floor 01 | 1M-2 Men's Restroom South - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:24 AM | Floor 01 | 1M-2 Men's Restroom South - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:40 AM | Floor 01 | 108-4 Cafe Prep. - Kitchen Faucet-Small | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 2:42 AM | Floor 01 | 108-4 Cafe Prep. - Kitchen Faucet-Large | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 3:03 AM | Floor LL | LLM-1 Men-Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 3:07 AM | Exterior | CLL09-1 Janitor's Closet - Mop/Slop Sink | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 3:31 AM | Floor LL | LLM-1 Men-Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 11/14/2023 | 3:55 AM | Floor LL | LLW-1 Women-Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 11/14/2023 | 3:55 AM | Floor LL | LLW-1 Women-Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 4:28 AM | Floor 02EC | E201 Restroom - Lavatory Faucet | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 8:18 AM | Floor 06 | Suite 615 Break Room-Kitchen Faucet (607-06) | 2 | ☑ | ☐ | 1.07 | 1.24 | |
| 11/14/2023 | 8:20 AM | Floor 06 | Suite 620 Break Room-Kitchen Faucet (608-12) | 2 | ☑ | ☐ | 1.2 | 1 | |
| 11/14/2023 | 8:38 AM | Floor 05 | Suite 614 Room-Kitchen Faucet (610-03) | 2 | ☑ | ☐ | 1.3 | 1.2 | |
| 11/14/2023 | 8:48 AM | Floor 03 | Suite 608 Kitchen - Faucet | 2 | ☐ | ☐ | 1.36 | 1.5 | |
| 11/14/2023 | 8:53 AM | Floor 06 | Suite 707-01 Break Room - Faucet (707-2) | 2 | ☑ | ☐ | | | 1.1 |
| 11/14/2023 | 9:06 AM | Floor LL | Suite 710 Faucet (710-03) | 2 | ☑ | ☑ | 1.06 | 0.68 | |
| 11/14/2023 | 9:16 AM | Floor 07 | Suite 707-10 Faucet (707-07) | 2 | ☑ | ☐ | 1.2 | 1.2 | |
| 11/14/2023 | 9:34 AM | Floor 08 | Suite 808A Break Room Faucet (809-02) | 1 | ☑ | ☐ | 1 | 1.04 | |
| 11/14/2023 | 9:42 AM | Floor 07 | Suite 810 Kitchen Faucet | 1 | ☑ | ☐ | 1.15 | 1.07 | |
| 11/14/2023 | 9:50 AM | Floor 09 | Suite 910A Faucet (910-05) | 2 | ☑ | ☐ | 1.1 | 0.84 | |
| 11/14/2023 | 10:05 AM | Floor 10 | Suite 1008 Break Room-Kitchen Faucet (1009-07) | 2 | ☑ | ☐ | 0.98 | 0.98 | |
| 11/14/2023 | 10:14 AM | Floor 08 | Suite 907A Break Room Faucet (907-22) | 2 | ☑ | ☐ | 1.1 | | |
| 11/14/2023 | 10:25 AM | Floor 10 | Suite 1009C Break Room-Kitchen Faucet (1009-19) | 2 | ☑ | ☐ | 0.93 | 0.9 | |
| 11/14/2023 | 10:35 AM | Floor LL | Suite 1015 GSA Kitchenette Faucet (1000-03) | 2 | ☑ | ☐ | 0.96 | | |
| 11/14/2023 | 10:53 AM | Floor 07 | Suite 1010 Lavatory Faucet | 1 | ☑ | ☐ | | | |
| 11/14/2023 | 10:59 AM | Floor 09 | Suite 908 Break Room Faucet (908-15) | 2 | ☑ | ☐ | 1.1 | | |

| Date | Time | Floor | Location / Plumbing Outlet (For Publication) | Number of Filters | Filter(s) Inspected | Filter(s) Replaced | Cold Flow Rate (GPM) | Hot Flow Rate (GPM) | Mixed Flow Rate (GPM) |
|------------|----------|----------|--|----------------------|-------------------------------------|-------------------------------------|----------------------------|---------------------------|-----------------------------|
| 11/14/2023 | 11:08 AM | Floor 09 | Suite 1010 Kitchenette Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 0.96 | 0.88 | |
| 11/14/2023 | 11:27 AM | Floor 04 | Suite 535 Break Room-Kitchen Faucet (507-36) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.2 | 0.88 | |
| 11/14/2023 | 11:30 AM | Floor 05 | Suite 532 Lactation Room - Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.25 | 0.85 | |
| 11/14/2023 | 1:07 PM | Floor 05 | 540 Faucet (507-26) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.08 | 1 | |
| 11/14/2023 | 1:12 PM | Floor 05 | Suite 540 Kitchenette - Faucet (507-25) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.36 | 0.78 | |
| 11/14/2023 | 1:40 PM | Floor 05 | Suite 540 Training Lobby - Faucet (507-12) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.2 | 1 | |
| 11/14/2023 | 2:01 PM | Floor 05 | Suite 520 Kitchenette Faucet (508-13) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.1 | 0.88 | |
| 11/14/2023 | 2:18 PM | Floor 05 | Suite 530 Kitchenette - Faucet (509-10) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.2 | 1 | |
| 11/14/2023 | 2:00 PM | Floor 05 | 540 Faucet (507-26) A (Second fixture) | 2 | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | 1.36 | 0.73 | |
| 11/15/2023 | 12:56 AM | Floor LL | 119-17 Toilet/Sink Combo | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 8:01 AM | Floor 04 | Suite 435 Kitchenette Faucet (SE) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 0.92 | 1 | |
| 11/15/2023 | 8:05 AM | Floor LL | Suite 435 Kitchenette Faucet (SE) A (Second fixture) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | 0.38 | |
| 11/15/2023 | 8:13 AM | Floor 04 | Suite 420 Kitchenette - Faucet (NE) - South | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.12 | 1.03 | |
| 11/15/2023 | 8:25 AM | Floor 04 | Suite 416 Kitchenette - Faucet (NE) - North | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.1 | 0.84 | |
| 11/15/2023 | 8:38 AM | Floor 02 | Suite 410 Kitchenette Faucet (NW) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1 | 1.3 | 1.2 |
| 11/15/2023 | 8:38 AM | Floor 04 | Suite 415 Kitchenette - Faucet (N) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.85 | | |
| 11/15/2023 | 9:00 AM | Floor 10 | Break Room North West - Kitchen Faucet (207-14) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.3 | | |
| 11/15/2023 | 9:00 AM | Floor 01 | 234 Kitchen Faucet (209-04) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.36 | 1.11 | |
| 11/15/2023 | 9:16 AM | Floor 02 | Break Room North East Kitchen - Faucet (207-39) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.3 | 1 | |
| 11/15/2023 | 9:25 AM | Floor 02 | Break Room South East Kitchen - Faucet (207-49) | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.11 | 1.07 | |
| 11/15/2023 | 9:30 AM | Floor LL | GSA Suite Kitchenette-Sink/Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.2 | 1.3 | |
| 11/15/2023 | 9:47 AM | Floor 01 | 128-01 Lactation Room A-Sink/Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.2 | 1.2 | |
| 11/15/2023 | 9:48 AM | Floor 01 | 123-05 Health Unit - Sink/Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 1.2 |
| 11/15/2023 | 10:00 AM | Floor 01 | 128-02 Lactation Room B-Sink/Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.2 | 1.2 | |
| 11/15/2023 | 10:07 AM | Floor 01 | 123-08 Health Unit-Lavatory Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/15/2023 | 10:19 AM | Floor 01 | 123-07 Health Unit-Lavatory Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/15/2023 | 10:30 AM | Floor 01 | 128-03 Lactation Room C-Sink/Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.1 | 1.2 | |
| 11/15/2023 | 10:30 AM | Floor 01 | 128-04 Lactation Room D-Sink/Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.1 | 1.1 | |
| 11/15/2023 | 10:45 AM | Floor 01 | 119-02 Mailroom - Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.8 | 1.7 | |
| 11/15/2023 | 10:45 AM | Floor 01 | 126-05 Men-Lavatory Faucet-Left | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/15/2023 | 10:45 AM | Floor 01 | 126-05 Men-Lavatory Faucet-Center | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/15/2023 | 10:45 AM | Floor 01 | 126-05 Men-Lavatory Faucet-Right | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 10:57 AM | Floor 01 | 119-19 Food Storage Room-Sink/Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.8 | | |
| 11/15/2023 | 11:02 AM | Floor 01 | 126-06 Shower Room-Shower-North-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.15 | 1.03 | |
| 11/15/2023 | 11:02 AM | Floor 01 | 126-06 Shower Room - Shower-North-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.07 | 1.03 | |
| 11/15/2023 | 11:02 AM | Floor 01 | 126-06 Shower Room - Shower-South-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 0.93 | 1.25 | |
| 11/15/2023 | 11:02 AM | Floor 01 | 126-06 Shower Room-Shower-South-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.07 | 0.9 | |
| 11/15/2023 | 11:02 AM | Floor 01 | 126-06 Shower Room - Shower-South-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.76 | 1.66 | |
| 11/15/2023 | 11:15 AM | Floor 01 | 119-16A Shower | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.4 | 1.48 | |
| 11/15/2023 | 11:35 AM | Floor 01 | 119-21 Faucet/Eyewash | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 1:10 PM | Floor 01 | 126-03 Women-Shower-1st from L to R | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2.14 | 2.3 | |
| 11/15/2023 | 1:10 PM | Floor 01 | 126-03 Women-Shower-2nd from L to R | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2.14 | 2.3 | |
| 11/15/2023 | 1:10 PM | Floor 01 | 126-03 Women-Shower-3rd from L to R | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.76 | 2.14 | |
| 11/15/2023 | 1:10 PM | Floor 01 | 126-03 Women-Shower-4th from L to R | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.87 | 2.14 | |
| 11/15/2023 | 1:33 PM | Floor 01 | 119-11 Toilet/Sink Combo | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 1:47 PM | Floor 01 | 119-10 Toilet/Sink Combo | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 2:00 PM | Floor 01 | 119-07 Toilet/Sink Combo-Left | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 2:15 PM | Floor 02 | 126-02 Women-Lavatory Faucet-Center | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.54 |
| 11/15/2023 | 2:15 PM | Floor 01 | 126-02 Women-Lavatory Faucet-Right | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 2:15 PM | Floor 01 | 126-02 Women-Lavatory Faucet-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/15/2023 | 2:17 PM | Floor 01 | 119-07 Toilet/Sink Combo-Right | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 2:32 PM | Floor 04 | Print, Postal Sorting Area Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1.5 | | |
| 11/15/2023 | 2:57 PM | Floor 01 | LL15 Break Room-Kitchen Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 0.93 | 0.88 | |
| 11/15/2023 | 3:12 PM | Floor 04 | LL15 Men's Restroom - Lavatory Faucet | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/15/2023 | 3:12 PM | Floor LL | LL15 Women's Restroom - Lavatory Faucet | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | 0.48 |
| 11/15/2023 | 4:17 PM | Floor 01 | 119-08 Toilet/Sink Combo-Left | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 4:17 PM | Floor 01 | 119-08 Toilet/Sink Combo-Right | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| 11/15/2023 | 5:16 PM | Floor 01 | 113-6 JLL Kitchenette-Kitchen Faucet | 2 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2.14 | 1.15 | |
| 11/15/2023 | 11:02 PM | Floor 01 | 126-06 Shower Room - Shower-North-Left | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 0.66 | 0.65 | |