

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
11/26/2023	7:30 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	7:30 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.6
11/26/2023	7:35 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	7:55 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	7:59 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	7:59 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	8:00 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/26/2023	8:00 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	8:05 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.6
11/26/2023	8:06 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.6
11/26/2023	8:10 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	8:13 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/26/2023	8:15 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/26/2023	8:20 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.92		
11/26/2023	8:23 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/26/2023	8:23 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/26/2023	8:23 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/26/2023	8:24 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	8:24 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.6
11/26/2023	8:24 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	8:24 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	8:30 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.44		
11/26/2023	8:44 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/26/2023	8:44 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/26/2023	8:50 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/26/2023	8:54 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	8:54 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/26/2023	9:28 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/26/2023	9:28 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/26/2023	9:28 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.58
11/26/2023	9:28 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/26/2023	9:28 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.36
11/26/2023	9:41 PM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.56		
11/27/2023	1:54 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:56 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/27/2023	1:56 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.56
11/27/2023	2:14 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	2:14 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	2:18 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	2:25 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	2:25 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	2:25 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/27/2023	2:32 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/27/2023	2:32 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.36
11/27/2023	2:32 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.36
11/27/2023	2:41 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.16		
11/27/2023	2:53 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	2:53 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	2:53 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	2:56 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	3:05 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	3:20 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	3:24 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.33
11/27/2023	3:29 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	3:40 AM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2		
11/27/2023	3:58 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	3:58 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	4:08 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	4:08 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	4:22 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.33
11/27/2023	4:30 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	4:30 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	4:31 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	4:48 AM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.92		
11/27/2023	5:00 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	5:15 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:00 AM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.13		

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
11/27/2023	9:00 AM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:00 AM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:00 AM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:00 AM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:00 AM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:45 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:45 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:45 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.3
11/27/2023	9:45 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	9:45 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:18 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:18 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:18 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:18 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:18 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:45 AM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:45 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:45 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	10:45 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:21 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:21 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:21 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:21 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:21 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:40 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:40 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:40 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:40 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:40 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	11:40 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/27/2023	12:08 PM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	12:08 PM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3.44		
11/27/2023	12:30 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	1:43 PM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/27/2023	1:43 PM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	1:43 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	2:30 PM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.57	2	
11/27/2023	2:30 PM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.5	3	
11/27/2023	2:30 PM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.72		
11/27/2023	2:30 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/27/2023	2:30 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	2:30 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/27/2023	2:30 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			0.24
11/28/2023	8:03 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	0.81	
11/28/2023	8:07 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.03	
11/28/2023	8:07 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.229		
11/28/2023	8:07 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.76
11/28/2023	8:30 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	1.4	
11/28/2023	8:45 AM	Floor 06	Suite 608 Kitchen - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	1.2	
11/28/2023	8:48 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.11	0.71	
11/28/2023	9:05 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	0.9	
11/28/2023	9:15 AM	Floor 07	Suite 710 Faucet (710-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.15	0.93	
11/28/2023	9:15 AM	Floor 09	Suite 910A Faucet (910-05)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.93		
11/28/2023	9:24 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	0.93	
11/28/2023	9:42 AM	Floor 08	Suite 810 Kitchen Faucet	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.2	0.66	
11/28/2023	10:00 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1		
11/28/2023	10:17 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2		
11/28/2023	10:30 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.88	0.96	
11/28/2023	10:43 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.81		

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
11/28/2023	10:48 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.88	0.88	
11/28/2023	11:06 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.07	0.93	
11/28/2023	11:08 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	9.2	
11/28/2023	12:40 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.33	1.25	
11/28/2023	1:10 PM	Floor 05	540 Faucet (507-26)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	1.3	
11/28/2023	1:21 PM	Floor 05	Suite. 540 Kitchenette - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.25	1.15	
11/28/2023	1:25 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.08	1.1	
11/28/2023	1:43 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	0.92	
11/28/2023	1:48 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.15	1.11	
11/28/2023	2:22 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.2	0.76	
11/28/2023	2:48 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.25	1.25	
11/28/2023	3:13 PM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.11	0.93	
11/28/2023	11:30 AM	Floor 10	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/29/2023	8:08 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1	
11/29/2023	8:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.04	1	
11/29/2023	8:22 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	0.88	
11/29/2023	8:25 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.24
11/29/2023	8:35 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.84		
11/29/2023	8:37 AM	Floor 02	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.3	
11/29/2023	8:52 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	0.84	
11/29/2023	8:55 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4		
11/29/2023	9:12 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.3	
11/29/2023	9:27 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	1.1	
11/29/2023	9:46 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	1.3	
11/29/2023	9:59 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	1.2	
11/29/2023	10:10 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/29/2023	10:10 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/29/2023	10:10 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/29/2023	10:10 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.3
11/29/2023	10:10 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.66
11/29/2023	10:12 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
11/29/2023	10:25 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.25
11/29/2023	10:25 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.66
11/29/2023	10:25 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2
11/29/2023	10:25 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.3
11/29/2023	10:25 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	1	
11/29/2023	10:42 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
11/29/2023	11:04 AM	Floor 01	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.8		
11/29/2023	11:16 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.7		
11/29/2023	11:28 AM	Floor 01	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.8		
11/29/2023	12:35 PM	Floor 01	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.2
11/29/2023	12:48 PM	Floor 01	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/29/2023	1:25 PM	Floor LL	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.58		
11/29/2023	1:45 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/29/2023	1:48 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/29/2023	1:57 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.12	0.92	
11/29/2023	2:30 PM	Floor 01	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/29/2023	2:30 PM	Floor 01	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/29/2023	2:40 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.16	1.24	
11/29/2023	2:45 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.32	1.72	
11/29/2023	2:55 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/29/2023	2:55 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/29/2023	3:00 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/29/2023	3:03 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/29/2023	3:20 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/29/2023	3:25 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/29/2023	4:00 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/29/2023	4:00 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/29/2023	4:00 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/29/2023	4:20 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.3
11/29/2023	4:20 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.15
11/29/2023	4:20 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.87
11/29/2023	4:20 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2