

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
12/10/2023	1:52 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/10/2023	10:14 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			64
12/10/2023	10:14 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			56
12/10/2023	10:30 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			56
12/10/2023	10:36 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			56
12/10/2023	10:36 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/10/2023	10:38 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/10/2023	10:38 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/10/2023	10:51 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/10/2023	10:53 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			49
12/10/2023	11:02 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3		
12/10/2023	11:17 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			43
12/10/2023	11:17 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/10/2023	11:18 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/10/2023	11:50 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/10/2023	11:55 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	12:00 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			36
12/11/2023	12:00 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	12:00 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	12:04 AM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.92		
12/11/2023	12:07 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	12:08 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	12:15 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	12:15 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	12:20 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	12:20 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	12:23 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	12:30 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			36
12/11/2023	12:31 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	12:34 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	12:34 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	12:34 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	12:40 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3.32		
12/11/2023	2:33 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	2:36 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	2:36 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	3:32 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	3:32 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	3:35 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	3:35 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	3:35 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.96		
12/11/2023	3:40 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			58
12/11/2023	3:40 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	3:40 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	3:50 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	3:50 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	3:52 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	3:53 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	3:53 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	4:00 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	4:00 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.08		
12/11/2023	4:03 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	4:05 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	4:05 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	4:05 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	4:15 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	4:15 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	4:24 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	4:24 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	4:28 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	4:38 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3		
12/11/2023	4:48 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	4:50 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	4:54 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	4:54 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	4:54 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	4:59 AM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	32		

12/11/2023	5:01 AM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	5:05 AM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	5:05 AM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	5:05 AM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			58
12/11/2023	5:10 AM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	5:20 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	5:20 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	5:30 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	5:30 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			42
12/11/2023	5:33 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			36
12/11/2023	5:47 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			60
12/11/2023	9:30 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	9:30 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	9:30 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	9:46 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	9:46 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	9:52 AM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	9:52 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	9:52 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	9:52 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	10:33 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	10:33 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	10:33 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	10:33 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	10:33 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	11:00 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	11:00 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	11:00 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			36
12/11/2023	11:00 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	11:00 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	11:00 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/11/2023	11:36 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	11:36 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	5.0		
12/11/2023	11:36 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3		
12/11/2023	12:10 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	1:45 PM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	1:45 PM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	1:45 PM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	1:45 PM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	2:00 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	2:00 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	2:00 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
12/11/2023	2:37 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	2:37 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			48
12/11/2023	2:37 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	3:00 PM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.87	1.66	
12/11/2023	3:00 PM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3.33	2.72	
12/11/2023	3:53 PM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.87		
12/11/2023	3:53 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	3:53 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	3:53 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/11/2023	3:53 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			54
12/12/2023	8:02 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.4		
12/12/2023	8:10 AM	Floor 06	Suite 608 Kitchen - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.42	1.2	
12/12/2023	8:12 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		0.62	
12/12/2023	8:39 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/12/2023	8:39 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.11	1.07	
12/12/2023	8:40 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	1.4	
12/12/2023	8:58 AM	Floor 07	Suite 710 Faucet (710-03)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.1	0.53	
12/12/2023	9:13 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.15	1.07	
12/12/2023	9:36 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.66	0.71	
12/12/2023	10:00 AM	Floor 09	Suite 910A Faucet (910-05)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
12/12/2023	10:24 AM	Floor 08	Suite 810 Kitchen Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.03	0.88	
12/12/2023	10:42 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.69	0.67	
12/12/2023	10:45 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.1	0.4	
12/12/2023	11:15 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.99	1.0	
12/12/2023	11:18 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.11	0.7	
12/12/2023	11:45 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.76	0.51	
12/12/2023	12:40 PM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	9.3	

12/12/2023	1:00 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	1.1	
12/12/2023	1:08 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.9	0.93	
12/12/2023	1:15 PM	Floor 05	540 Faucet (507-26)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.0	1.1	
12/12/2023	1:30 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	1.0	
12/12/2023	1:44 PM	Floor 10	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/12/2023	1:45 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.1	0.66	
12/12/2023	2:00 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	0.78	
12/12/2023	2:13 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.11	
12/12/2023	2:29 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
12/12/2023	3:01 PM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.11	1.07	
12/13/2023	8:04 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.8	0.83	
12/13/2023	8:20 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.15	0.76	
12/13/2023	8:20 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	1.2	
12/13/2023	8:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		0.69	
12/13/2023	8:40 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.76		
12/13/2023	8:48 AM	Floor 02	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	1.3	
12/13/2023	9:00 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.25	
12/13/2023	9:07 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3		
12/13/2023	9:22 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.15
12/13/2023	9:22 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	9:23 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
12/13/2023	9:39 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1	
12/13/2023	9:45 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	9:57 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.3	
12/13/2023	10:06 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	10:06 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	10:06 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	10:10 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
12/13/2023	10:22 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	1.2	
12/13/2023	10:30 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.5
12/13/2023	10:30 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.3
12/13/2023	10:30 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.3
12/13/2023	10:30 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.3
12/13/2023	10:33 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		0.95	
12/13/2023	10:56 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	10:56 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	10:56 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/13/2023	11:00 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
12/13/2023	11:15 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.66
12/13/2023	11:15 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.87
12/13/2023	11:15 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.25
12/13/2023	11:15 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.5
12/13/2023	11:15 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.5
12/13/2023	11:15 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.72
12/13/2023	11:20 AM	Floor 01	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.9	1.8	
12/13/2023	11:32 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.7	0.90	
12/13/2023	11:49 AM	Floor 01	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.8	1.3	
12/13/2023	12:35 PM	Floor 01	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.4
12/13/2023	12:52 PM	Floor 01	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/13/2023	1:05 PM	Floor 01	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/13/2023	1:22 PM	Floor 01	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/13/2023	1:39 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/13/2023	1:51 PM	Floor LL	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		
12/13/2023	1:56 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/13/2023	2:10 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.85	0.25	
12/13/2023	2:12 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/13/2023	2:25 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	2:25 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/13/2023	2:30 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/13/2023	2:45 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.0	1.2	

985 Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 12/10/2023 to 12/15/2023

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description	Notes
12/12/2023	2944419	Suite. 540 Kitchenette - Faucet	