

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
12/17/2023	8:00 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	8:10 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	8:20 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	8:22 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	8:37 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/17/2023	8:37 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	8:37 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	9:40 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.28		
12/17/2023	9:50 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	9:50 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	9:51 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	10:40 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	10:42 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	10:42 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	10:55 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	10:55 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	10:55 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	10:57 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	11:50 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	11:50 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/17/2023	11:50 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	12:13 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.5		
12/18/2023	12:47 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	12:47 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:25 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:25 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:25 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:25 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:25 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:25 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:00 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:00 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.24		
12/18/2023	2:00 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:00 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:00 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:00 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:00 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:00 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:00 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:47 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:47 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:47 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:47 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:47 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:47 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:47 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:00 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4		
12/18/2023	3:20 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:20 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:20 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:20 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.2	2.2	
12/18/2023	3:20 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3.2	3.2	
12/18/2023	5:15 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3		
12/18/2023	5:15 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:15 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:15 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:15 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	11:30 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	11:30 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	11:30 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	11:36 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	11:36 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	12:13 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	12:13 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.32
12/18/2023	12:13 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	12:13 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	12:13 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48

12/18/2023	12:55 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:18 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:18 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:18 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:18 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:18 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:40 PM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.3		
12/18/2023	1:40 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:40 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:40 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:40 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	1:40 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	2:20 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:30 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.3		
12/18/2023	3:30 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:30 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:30 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:30 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:30 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:55 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:55 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:55 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
12/18/2023	3:55 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	3:55 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:15 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:15 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:15 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:15 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:15 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:35 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:35 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:35 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	4:35 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:00 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:00 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:00 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:00 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:00 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:23 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:23 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:23 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:23 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:23 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	5:23 PM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/18/2023	6:26 PM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	6:26 PM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3.75		
12/18/2023	6:41 PM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.3		
12/18/2023	6:41 PM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/18/2023	11:58 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.32		
12/19/2023	8:00 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	1.4	
12/19/2023	8:10 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.83
12/19/2023	8:15 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	1.36	
12/19/2023	8:26 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.3	
12/19/2023	8:30 AM	Floor 06	Suite 608 Kitchen - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.52	1.4	
12/19/2023	8:43 AM	Floor 07	Suite 710 Faucet (710-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.20	1.20	
12/19/2023	8:50 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.36	1.15	
12/19/2023	9:00 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.4	
12/19/2023	9:00 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.28	1.20	
12/19/2023	9:15 AM	Floor 09	Suite 910A Faucet (910-05)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.36	1.30	
12/19/2023	9:20 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.30	1.40	
12/19/2023	9:35 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.16	0.90	
12/19/2023	9:45 AM	Floor 08	Suite 810 Kitchen Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.15	
12/19/2023	10:05 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.25		
12/19/2023	11:15 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.00	1.00	
12/19/2023	11:20 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.04	0.93	
12/19/2023	11:25 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.20	0.72	
12/19/2023	12:40 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.30	1.20	
12/19/2023	1:00 PM	Floor 10	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
12/19/2023	1:00 PM	Floor 05	540 Faucet (507-26)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.00	1.00	

12/19/2023	1:20 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.00	0.84	
12/19/2023	1:25 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2		
12/19/2023	1:35 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.12	0.75	
12/19/2023	2:00 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.12		
12/20/2023	8:00 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	0.78	
12/20/2023	8:20 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.1	0.73	
12/20/2023	8:26 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.07	1.07	
12/20/2023	8:26 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		0.6	
12/20/2023	8:37 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.3	3
12/20/2023	8:56 AM	Floor 02	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.3	
12/20/2023	9:10 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.15
12/20/2023	9:14 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3		
12/20/2023	9:37 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	9:45 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.1	1.1	
12/20/2023	9:49 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	10:00 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.3	
12/20/2023	10:08 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	10:08 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	10:08 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	10:13 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
12/20/2023	10:25 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.2	
12/20/2023	10:33 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.30
12/20/2023	10:37 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	0.9	
12/20/2023	10:45 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.50
12/20/2023	10:45 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.30
12/20/2023	10:45 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.30
12/20/2023	10:50 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.2	
12/20/2023	11:04 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	11:09 AM	Floor 01	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.9	1.0	
12/20/2023	11:17 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	11:17 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/20/2023	11:21 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.6		
12/20/2023	11:38 AM	Floor 01	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.7	1.2	
12/20/2023	11:40 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.36
12/20/2023	11:40 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.57
12/20/2023	11:40 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			1.1
12/20/2023	11:50 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.5
12/20/2023	11:50 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.3
12/20/2023	11:50 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			2.3
12/20/2023	11:55 AM	Floor 01	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			1.2
12/20/2023	12:25 PM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		
12/20/2023	12:40 PM	Floor 01	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/20/2023	12:51 PM	Floor 01	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/20/2023	1:07 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/20/2023	1:21 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/20/2023	1:36 PM	Floor 01	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/20/2023	1:54 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/20/2023	1:59 PM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.0		
12/20/2023	2:07 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
12/20/2023	2:23 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.9	1.0	
12/20/2023	4:27 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	4:40 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
12/20/2023	4:52 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.73	0.93	
12/20/2023	5:15 PM	Floor LL	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		

985 Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 12/17/2023 to 12/22/2023

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description	Notes
12/18/2023	2944317	7W-1 Women's Restroom East - Lavatory Faucet-Center	
12/18/2023	2944075	1W-1 Women's Restroom North - Lavatory Faucet-Center	
12/19/2023	2944419	Suite. 540 Kitchenette - Faucet	
12/19/2023	2944278	Suite 615 Break Room-Kitchen Faucet (607-06)	
12/19/2023	2945143	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	
12/19/2023	2944409	Suite 1009C Break Room-Kitchen Faucet (1009-19)	
12/19/2023	2944260	Suite 520 Kitchenette Faucet (508-13)	