

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/12/2024	12:00 AM	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	12:04 AM	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	12:05 AM	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	12:06 AM	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	12:17 AM	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	☑	☐	1.5	1.4	1.4	
2/12/2024	12:22 AM	C1007-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.8		
2/12/2024	12:28 AM	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	12:29 AM	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	12:30 AM	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	12:38 AM	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	12:39 AM	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	12:46 AM	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	12:47 AM	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	12:49 AM	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	12:50 AM	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	12:51 AM	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	12:59 AM	C907-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.7		
2/12/2024	1:09 AM	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	1:10 AM	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	1:14 AM	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	1:15 AM	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	1:16 AM	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	1:27 AM	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	1:28 AM	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	1:33 AM	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	1:34 AM	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	1:35 AM	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	1:42 AM	C807-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.8		
2/12/2024	1:50 AM	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	1:52 AM	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	2:00 AM	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	2:01 AM	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	2:10 AM	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	2:11 AM	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	2:13 AM	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	2:14 AM	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	2:15 AM	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	2:22 AM	C707-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.7		
2/12/2024	3:03 AM	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	3:06 AM	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	3:17 AM	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	3:18 AM	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	3:25 AM	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	3:28 AM	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	3:30 AM	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	3:31 AM	E201 Restroom - Lavatory Faucet	1	☑	☐	0.5			0.48
2/12/2024	3:40 AM	C105-1 Janitor's Closet - Mop/Slop Sink	1	☑	☐		2.4		
2/12/2024	3:41 AM	C607-Janitor's Closet - Mop/Slop Sink	1	☑	☐		1.6		
2/12/2024	3:41 AM	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	☑	☐		2.4		
2/12/2024	3:42 AM	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	3:48 AM	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	3:49 AM	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	3:50 AM	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	3:50 AM	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	3:50 AM	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	3:55 AM	LLM-1 Men-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	4:01 AM	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	4:02 AM	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	4:03 AM	LLM-1 Men-Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	4:03 AM	LLW-1 Women-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	4:03 AM	LLW-1 Women-Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	4:10 AM	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	☑	☐		1.8		
2/12/2024	4:16 AM	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	4:18 AM	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	4:20 AM	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	4:21 AM	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/12/2024	4:22 AM	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	4:30 AM	C507 Janitor's Closet - Mop/Slop Sink	1	☑	☐		1.6		
2/12/2024	5:09 AM	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	3:44 PM	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	7:40 PM	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	7:40 PM	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	7:40 PM	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	7:48 PM	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	7:48 PM	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	7:50 PM	C407 Janitor's Closet-Mop/Slop Sink	1	☑	☐		2		
2/12/2024	7:51 PM	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	7:56 PM	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	8:00 PM	4W-2 Women West-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:00 PM	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	8:00 PM	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	8:04 PM	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:06 PM	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	8:07 PM	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	8:12 PM	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:12 PM	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	8:21 PM	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:26 PM	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:26 PM	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	8:26 PM	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	8:34 PM	1U-1 Loading Dock - Lavatory Faucet	2	☑	☐	0.5			0.42
2/12/2024	8:35 PM	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	8:35 PM	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/12/2024	8:37 PM	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:37 PM	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	8:37 PM	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:40 PM	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	8:43 PM	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:43 PM	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	8:43 PM	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	8:47 PM	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	8:51 PM	C207 Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.8		
2/12/2024	9:00 PM	108-4 Cafe Prep. - Kitchen Faucet-Small	1	☑	☐	1.5	0.65	1.23	
2/12/2024	9:00 PM	108-4 Cafe Prep. - Kitchen Faucet-Large	1	☑	☐	1.5	0.68	1.21	
2/12/2024	9:05 PM	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/12/2024	9:07 PM	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	9:20 PM	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	9:20 PM	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	9:20 PM	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	11:43 PM	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	11:44 PM	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	11:49 PM	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/12/2024	11:50 PM	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/12/2024	11:59 PM	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/13/2024	8:00 AM	Suite 710 Faucet (710-03)	2	☑	☐	1.5	1.2	1.2	
2/13/2024	8:12 AM	Suite 707-01 Break Room - Faucet (707-2)	2	☑	☐	1.5	1.2	1.2	
2/13/2024	8:15 AM	Suite 620 Break Room-Kitchen Faucet (608-12)	2	☑	☐	1.5	1.2	1.12	
2/13/2024	8:20 AM	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	☑	☐	1.5			0.5
2/13/2024	8:24 AM	Suite 707-10 Faucet (707-07)	2	☑	☐	1.5	1.2	1.0	
2/13/2024	8:37 AM	Suite 808A Break Room Faucet (809-02)	1	☑	☐	1.5	1.2	1.0	
2/13/2024	8:40 AM	Suite 614 Room-Kitchen Faucet (610-03)	2	☑	☐	1.5	1.40	1.30	
2/13/2024	8:48 AM	Suite 810 Kitchen Faucet	1	☑	☐	1.5	1.2	1.1	
2/13/2024	9:00 AM	Suite 908 Break Room Faucet (908-15)	2	☑	☐	1.5	1.2	1.0	
2/13/2024	9:01 AM	Suite 907A Break Room Faucet (907-22)	2	☑	☐	1.5	1.2	1.0	
2/13/2024	9:10 AM	Suite 608 Kitchen - Faucet	2	☑	☑	1.5	1.4	0.68	
2/13/2024	9:25 AM	Suite 910A Faucet (910-05)	2	☑	☐	1.5	1.2	1.1	
2/13/2024	9:30 AM	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	☑	☐	1.5	1.36	1.2	
2/13/2024	9:39 AM	Suite 530 Kitchenette - Faucet (509-10)	2	☑	☐	1.5	1.2	1.1	
2/13/2024	10:15 AM	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	☑	☐	1.5	1.28	1.25	
2/13/2024	10:45 AM	Suite 532 Lactation Room - Faucet	2	☑	☐	1.5	1.08	0.88	
2/13/2024	11:10 AM	Suite 535 Break Room-Kitchen Faucet (507-36)	2	☑	☑	1.5	1.2	0.76	
2/13/2024	12:30 PM	Suite 1010 Kitchenette Faucet	2	☑	☐	1.5	1.32	1.04	

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/13/2024	12:45 PM	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5			0.48
2/13/2024	1:05 PM	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.25	1.25	
2/13/2024	1:10 PM	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
2/13/2024	1:25 PM	540 Faucet (507-26)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.0	0.98	
2/13/2024	1:25 PM	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.2		
2/14/2024	8:00 AM	Suite 420 Kitchenette - Faucet (NE) - South	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/14/2024	8:12 AM	Suite 410 Kitchenette Faucet (NW)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.0	
2/14/2024	8:16 AM	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.07	0.93	
2/14/2024	8:24 AM	Suite 416 Kitchenette - Faucet (NE) - North	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.2	
2/14/2024	8:27 AM	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		0.62	
2/14/2024	8:36 AM	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.0	
2/14/2024	8:48 AM	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/14/2024	9:01 AM	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/14/2024	9:22 AM	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/14/2024	9:22 AM	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/14/2024	9:27 AM	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.2	
2/14/2024	9:30 AM	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.36	1.07	
2/14/2024	9:38 AM	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/14/2024	9:49 AM	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/14/2024	9:58 AM	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/14/2024	10:00 AM	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/14/2024	10:11 AM	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/14/2024	10:17 AM	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.72
2/14/2024	10:24 AM	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.8	0.93	
2/14/2024	10:27 AM	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.72
2/14/2024	10:27 AM	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.5
2/14/2024	10:33 AM	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.72
2/14/2024	10:36 AM	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.6	1.8		
2/14/2024	10:46 AM	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/14/2024	10:50 AM	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.8	1.6	
2/14/2024	10:57 AM	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/14/2024	10:57 AM	126-05 Men-Lavatory Faucet-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/14/2024	11:03 AM	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>				1.2
2/14/2024	11:04 AM	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/14/2024	11:22 AM	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/14/2024	11:22 AM	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.5
2/14/2024	11:22 AM	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.5
2/14/2024	11:27 AM	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/14/2024	11:35 AM	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/14/2024	11:35 AM	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/14/2024	11:45 AM	126-06 Shower Room - Shower-South-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.72
2/14/2024	12:45 PM	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/14/2024	12:58 PM	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/14/2024	1:12 PM	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/14/2024	1:27 PM	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/14/2024	1:40 PM	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/14/2024	1:56 PM	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.3	1.3	
2/14/2024	2:15 PM	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.76	1.66	

985 Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 02/11/2024 to 02/17/2024

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
2/12/2024	2944407	10W-1 Women's Restroom East - Lavatory Faucet-Center
2/12/2024	2944317	7W-1 Women's Restroom East - Lavatory Faucet-Center
2/12/2024	2944287	6W-1 Women's Restroom East - Lavatory Faucet-Left
2/12/2024	2944274	6M-2 Men's Restroom West - Lavatory Faucet-Left
2/12/2024	2944256	5W-1 Women's Restroom East - Lavatory Faucet-Left
2/13/2024	2944419	Suite. 540 Kitchenette - Faucet
2/13/2024	2945147	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)
2/13/2024	2944278	Suite 615 Break Room-Kitchen Faucet (607-06)
2/13/2024	2945143	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)
2/13/2024	2944260	Suite 520 Kitchenette Faucet (508-13)
2/14/2024	2944107	123-05 Health Unit - Sink/Faucet
2/14/2024	2944110	123-07 Health Unit-Lavatory Faucet
2/14/2024	2944108	123-08 Health Unit-Lavatory Faucet