

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/19/2024	1:15 AM	E201 Restroom - Lavatory Faucet	1	☑	☐	0.5			0.48
2/19/2024	2:05 AM	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	2:05 AM	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	2:06 AM	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	2:20 AM	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	2:20 AM	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	2:32 AM	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
2/19/2024	2:32 AM	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	2:32 AM	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	2:40 AM	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	2:54 AM	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	2:56 AM	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	2:56 AM	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	2:58 AM	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	2:58 AM	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:03 AM	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:06 AM	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:06 AM	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	3:06 AM	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:09 AM	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:11 AM	C207 Janitor's Closet-Mop/Slop Sink	1	☑	☐				
2/19/2024	3:14 AM	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	☑	☐	1.5	1.23	0.94	
2/19/2024	3:19 AM	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:22 AM	1U-1 Loading Dock - Lavatory Faucet	2	☑	☐	0.5			0.48
2/19/2024	3:23 AM	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	☑	☐		2.0		
2/19/2024	3:24 AM	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:24 AM	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	3:28 AM	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:28 AM	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:30 AM	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:31 AM	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:35 AM	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:35 AM	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	3:37 AM	108-4 Cafe Prep. - Kitchen Faucet-Small	1	☑	☐	1.5	69	1.23	
2/19/2024	3:37 AM	108-4 Cafe Prep. - Kitchen Faucet-Large	1	☑	☐	1.5	68	1.23	
2/19/2024	3:40 AM	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/19/2024	3:42 AM	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:42 AM	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:43 AM	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:45 AM	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:45 AM	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	3:45 AM	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:46 AM	C607-Janitor's Closet - Mop/Slop Sink	1	☑	☐		2.0		
2/19/2024	3:49 AM	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:49 AM	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	3:49 AM	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:50 AM	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	3:53 AM	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:53 AM	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	3:56 AM	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	3:56 AM	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	4:03 AM	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/19/2024	4:06 AM	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	4:10 AM	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	4:10 AM	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	4:10 AM	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	4:12 AM	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	☑	☐		2.0		
2/19/2024	4:14 AM	C507 Janitor's Closet - Mop/Slop Sink	1	☑	☐		1.5		
2/19/2024	4:21 AM	LLM-1 Men-Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	4:25 AM	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	4:25 AM	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	4:28 AM	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	4:28 AM	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	4:30 AM	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	4:39 AM	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	4:41 AM	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/19/2024	4:44 AM	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	4:44 AM	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/19/2024	4:46 AM	4W-2 Women West-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	4:49 AM	C407 Janitor's Closet-Mop/Slop Sink	1	☑	☐		2.3		
2/19/2024	4:59 AM	LLM-1 Men-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	5:03 AM	LLW-1 Women-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	5:10 AM	LLW-1 Women-Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	7:16 PM	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	7:23 PM	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/19/2024	7:23 PM	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
2/19/2024	7:42 PM	C1007-Janitor's Closet-Mop/Slop Sink	1	☑	☐		2.2		
2/19/2024	7:45 PM	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/19/2024	7:46 PM	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	7:49 PM	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	7:49 PM	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	7:49 PM	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	7:51 PM	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	7:51 PM	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	7:51 PM	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	7:56 PM	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:00 PM	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:00 PM	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:08 PM	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:09 PM	C907-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.9		
2/19/2024	8:12 PM	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:14 PM	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:14 PM	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	8:14 PM	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:25 PM	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:25 PM	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:28 PM	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:29 PM	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	8:29 PM	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:32 PM	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:39 PM	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:39 PM	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	8:39 PM	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:40 PM	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:40 PM	C807-Janitor's Closet-Mop/Slop Sink	1	☑	☐		2.0		
2/19/2024	8:46 PM	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:47 PM	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:47 PM	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	8:50 PM	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:50 PM	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	8:53 PM	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	8:54 PM	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/19/2024	9:00 PM	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/19/2024	9:00 PM	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/19/2024	9:00 PM	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/19/2024	9:10 PM	C707-Janitor's Closet-Mop/Slop Sink	1	☑	☐		2.5		
2/19/2024	7:18 PM	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/20/2024	8:02 AM	Suite 620 Break Room-Kitchen Faucet (608-12)	2	☑	☐	1.5	1.2	1.1	
2/20/2024	8:12 AM	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	☑	☐	1.5		0.83	
2/20/2024	8:13 AM	Suite 615 Break Room-Kitchen Faucet (607-06)	2	☑	☐	1.5	1.15	1.15	
2/20/2024	8:14 AM	Suite 608 Kitchen - Faucet	2	☑	☐	1.5	1.2	1.2	
2/20/2024	8:26 AM	Suite 614 Room-Kitchen Faucet (610-03)	2	☑	☐	1.5	1.2	1.2	
2/20/2024	8:30 AM	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	☑	☐	1.5		0.65	
2/20/2024	8:38 AM	Suite 710 Faucet (710-03)	2	☑	☐	1.5	1.2	1.1	
2/20/2024	8:51 AM	Suite 707-01 Break Room - Faucet (707-2)	2	☑	☐	1.5	1.2	0.93	
2/20/2024	8:52 AM	Suite 808A Break Room Faucet (809-02)	1	☑	☐	1.5	1.1	0.86	
2/20/2024	9:05 AM	Suite 810 Kitchen Faucet	1	☑	☐	1.5	1.1	1.0	
2/20/2024	9:17 AM	Suite 707-10 Faucet (707-07)	2	☑	☐	1.5	1.36	0.93	
2/20/2024	9:25 AM	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	☑	☐	1.5	1.2	1.1	
2/20/2024	9:38 AM	Suite 908 Break Room Faucet (908-15)	2	☑	☐	1.5	1.25	1.03	
2/20/2024	9:45 AM	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	☑	☐	1.5	1.2	1.1	
2/20/2024	9:57 AM	Suite 907A Break Room Faucet (907-22)	2	☑	☐	1.5	1.36	1.2	

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/20/2024	10:10 AM	Suite 530 Kitchenette - Faucet (509-10)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.0	
2/20/2024	10:17 AM	Suite 910A Faucet (910-05)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.3	1.36	
2/20/2024	10:46 AM	Suite 1010 Kitchenette Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.25	0.96	
2/20/2024	11:06 AM	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5			0.48
2/20/2024	12:50 PM	Suite 532 Lactation Room - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/20/2024	1:08 PM	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.15	1.0	
2/20/2024	1:10 PM	Suite 535 Break Room-Kitchen Faucet (507-36)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/20/2024	1:22 PM	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.03	0.73	
2/20/2024	1:26 PM	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/20/2024	1:39 PM	540 Faucet (507-26)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/20/2024	1:53 PM	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/21/2024	8:02 AM	Suite 420 Kitchenette - Faucet (NE) - South	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
2/21/2024	8:13 AM	Suite 416 Kitchenette - Faucet (NE) - North	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/21/2024	8:25 AM	Suite 415 Kitchenette - Faucet (N)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.44	1.52	
2/21/2024	8:25 AM	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/21/2024	8:30 AM	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5			0.66
2/21/2024	8:50 AM	Suite 410 Kitchenette Faucet (NW)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.12	0.75	
2/21/2024	8:55 AM	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/21/2024	9:00 AM	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.36	1.12	
2/21/2024	9:06 AM	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/21/2024	9:20 AM	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
2/21/2024	9:20 AM	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
2/21/2024	9:25 AM	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/21/2024	9:31 AM	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/21/2024	9:35 AM	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/21/2024	9:42 AM	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/21/2024	9:53 AM	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/21/2024	9:55 AM	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/21/2024	9:58 AM	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/21/2024	10:04 AM	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/21/2024	10:17 AM	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.7	1.2	
2/21/2024	10:20 AM	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2
2/21/2024	10:25 AM	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/21/2024	10:29 AM	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6	1.6	1.6	
2/21/2024	10:30 AM	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/21/2024	10:30 AM	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/21/2024	10:35 AM	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2
2/21/2024	10:40 AM	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2
2/21/2024	10:45 AM	126-06 Shower Room - Shower-South-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/21/2024	10:50 AM	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/21/2024	10:55 AM	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>				1.2
2/21/2024	10:55 AM	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/21/2024	11:08 AM	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/21/2024	11:10 AM	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/21/2024	11:15 AM	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/21/2024	11:20 AM	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/21/2024	11:25 AM	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.7
2/21/2024	11:26 AM	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/21/2024	12:45 PM	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/21/2024	1:00 PM	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/21/2024	1:00 PM	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.5			0.48
2/21/2024	1:10 PM	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/21/2024	1:17 PM	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/21/2024	1:20 PM	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.04	0.5	
2/21/2024	1:31 PM	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/21/2024	1:35 PM	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.87	1.66	
2/21/2024	1:53 PM	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/21/2024	11:39 PM	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/21/2024	8:43 A<	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.0	

985 Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 02/18/2024 to 02/24/2024

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
2/19/2024	2944100	C105-1 Janitor's Closet - Mop/Slop Sink
2/19/2024	2944074	1W-1 Women's Restroom North - Lavatory Faucet-Left
2/20/2024	2944419	Suite. 540 Kitchenette - Faucet
2/20/2024	2944260	Suite 520 Kitchenette Faucet (508-13)
2/21/2024	2944086	119-21 Faucet/Eyewash
2/21/2024	2944116	126-05 Men-Lavatory Faucet-Right