

Color key:

Below established thresholds for legionella, metals, and total coliform/E. coli

Above established thresholds for legionella, metals, and total coliform/E. coli

Positive for legionella, but below the established threshold

Notes:

[1] U.S. EPA Primary Drinking Water Standards establish action levels for lead and copper as 15 ppb and 1,300 ppb, respectively.

[2] CDC guidance defines < 1 CFU/mL for potable sources as the threshold for systems where legionella growth appears to be well controlled.

[3] ppb means parts per billion.

[4] CFU/mL means Colony Forming Units per milliliter.

[5] ND means Legionella was not detected in the sample analyzed.

[6] Column headers indicate when samples were pulled pre or post-filter.

985 Michigan Federal Building Water Testing Summary				Monthly Round 1 (3/26 -3/27)	
Plumbing Outlet Unique Identifier (for publication)	Floor	Analysis	Units	PRE FILTER	POST FILTER
LL15-1 Meter Room-Water Main Service Line	LL	E.Coli	--		Absent
LL15-1 Meter Room-Water Main Service Line	LL	Total Coliform	--		Absent
LL15-1 Meter Room-Water Main Service Line	LL	Lead	ppb		2.6
LL15-1 Meter Room-Water Main Service Line	LL	Copper	ppb		40
LL15-1 Meter Room-Water Main Service Line	LL	Legionella Culture	CFU/mL		ND
LL16 Fire Pump Room-Water Main Service Line	LL	E.Coli	--		Absent
LL16 Fire Pump Room-Water Main Service Line	LL	Total Coliform	--		Absent
LL16 Fire Pump Room-Water Main Service Line	LL	Lead	ppb		0
LL16 Fire Pump Room-Water Main Service Line	LL	Copper	ppb		27
LL16 Fire Pump Room-Water Main Service Line	LL	Legionella Culture	CFU/mL		ND
Print, Postal Sorting Area Faucet	LL	Copper	ppb	300	270
Print, Postal Sorting Area Faucet	LL	E.Coli	--		
Print, Postal Sorting Area Faucet	LL	Lead	ppb	0	0
Print, Postal Sorting Area Faucet	LL	Total Coliform	--		

Print, Postal Sorting Area Faucet	LL	Legionella Culture	CFU/mL	ND	ND
LLW-1 Women-Lavatory Faucet-Left	LL	E.Coli	--		
LLW-1 Women-Lavatory Faucet-Left	LL	Total Coliform	--		
LLW-1 Women-Lavatory Faucet-Left	LL	Lead	ppb		
LLW-1 Women-Lavatory Faucet-Left	LL	Copper	ppb		
LLW-1 Women-Lavatory Faucet-Left	LL	Legionella Culture	CFU/mL		
LLW-1 Women-Lavatory Faucet-Right	LL	Legionella Culture	CFU/mL	ND	ND
LLW-1 Women-Lavatory Faucet-Right	LL	Copper	ppb	760	410
LLW-1 Women-Lavatory Faucet-Right	LL	E.Coli	--	Absent	Absent
LLW-1 Women-Lavatory Faucet-Right	LL	Lead	ppb	5.6	0
LLW-1 Women-Lavatory Faucet-Right	LL	Total Coliform	--	Absent	Absent
LLM-1 Men-Lavatory Faucet-Left	LL	Legionella Culture	CFU/mL		
LLM-1 Men-Lavatory Faucet-Left	LL	Copper	ppb		
LLM-1 Men-Lavatory Faucet-Left	LL	E.Coli	--		
LLM-1 Men-Lavatory Faucet-Left	LL	Lead	ppb		
LLM-1 Men-Lavatory Faucet-Left	LL	Total Coliform	--		
LLM-1 Men-Lavatory Faucet-Right	LL	Legionella Culture	CFU/mL	ND	ND
LLM-1 Men-Lavatory Faucet-Right	LL	Copper	ppb	160	140
LLM-1 Men-Lavatory Faucet-Right	LL	E.Coli	--	Absent	Absent
LLM-1 Men-Lavatory Faucet-Right	LL	Lead	ppb	0	0
LLM-1 Men-Lavatory Faucet-Right	LL	Total Coliform	--	Absent	Absent
LL Corridor North - Drinking Fountain-Left	LL	Legionella Culture	CFU/mL		
LL Corridor North - Drinking Fountain-Left	LL	Copper	ppb		
LL Corridor North - Drinking Fountain-Left	LL	E.Coli	--		
LL Corridor North - Drinking Fountain-Left	LL	Lead	ppb		
LL Corridor North - Drinking Fountain-Left	LL	Total Coliform	--		
LL15 Men's Restroom - Lavatory Faucet	LL	Legionella Culture	CFU/mL	ND	ND
LL15 Men's Restroom - Lavatory Faucet	LL	Copper	ppb	870	1400
LL15 Men's Restroom - Lavatory Faucet	LL	E.Coli	--	Absent	Absent
LL15 Men's Restroom - Lavatory Faucet	LL	Lead	ppb	1.7	0
LL15 Men's Restroom - Lavatory Faucet	LL	Total Coliform	--	Absent	Absent

LL15 Women's Restroom - Lavatory Faucet	LL	Legionella Culture	CFU/mL	ND	ND
LL15 Women's Restroom - Lavatory Faucet	LL	Copper	ppb	1100	1200
LL15 Women's Restroom - Lavatory Faucet	LL	E.Coli	--	Absent	Absent
LL15 Women's Restroom - Lavatory Faucet	LL	Lead	ppb	0	0
LL15 Women's Restroom - Lavatory Faucet	LL	Total Coliform	--	Absent	Absent
LL15 Break Room-Kitchen Faucet	LL	E.Coli	--	Absent	Absent
LL15 Break Room-Kitchen Faucet	LL	Total Coliform	--	Absent	Absent
LL15 Break Room-Kitchen Faucet	LL	Lead	ppb	3.3	0
LL15 Break Room-Kitchen Faucet	LL	Copper	ppb	200	180
LL15 Break Room-Kitchen Faucet	LL	Legionella Culture	CFU/mL	ND	ND
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Legionella Culture	CFU/mL	0.4	ND
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Copper	ppb	300	170
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	E.Coli	--	Absent	Absent
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Lead	ppb	3.1	0
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Total Coliform	--	Absent	Absent
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Legionella Culture	CFU/mL	ND	ND
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Copper	ppb	450	270
108-4 Cafe Prep. - Kitchen Faucet-Large	1	E.Coli	--	Absent	Absent
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Lead	ppb	0	0
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Total Coliform	--	Absent	Absent
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Legionella Culture	CFU/mL	ND	ND
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Copper	ppb	340	440
108-4 Cafe Prep. - Kitchen Faucet-Small	1	E.Coli	--	Absent	Absent
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Lead	ppb	0	0
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Total Coliform	--	Absent	Absent
GSA Suite Kitchenette-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND
GSA Suite Kitchenette-Sink/Faucet	1	Copper	ppb	1200	290
GSA Suite Kitchenette-Sink/Faucet	1	E.Coli	--	Absent	Absent
GSA Suite Kitchenette-Sink/Faucet	1	Lead	ppb	0	0
GSA Suite Kitchenette-Sink/Faucet	1	Total Coliform	--	Absent	Absent
1 Corridor South - Drinking Fountain-Left	1	Legionella Culture	CFU/mL		

1 Corridor South - Drinking Fountain-Left	1	Copper	ppb		
1 Corridor South - Drinking Fountain-Left	1	E.Coli	--		
1 Corridor South - Drinking Fountain-Left	1	Lead	ppb		
1 Corridor South - Drinking Fountain-Left	1	Total Coliform	--		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Copper	ppb		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	E.Coli	--		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Lead	ppb		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Total Coliform	--		
1M-1 Men's Restroom North - Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	ND	ND
1M-1 Men's Restroom North - Lavatory Faucet-Center	1	Copper	ppb	2800	250
1M-1 Men's Restroom North - Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent
1M-1 Men's Restroom North - Lavatory Faucet-Center	1	Lead	ppb	28	0
1M-1 Men's Restroom North - Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent
1M-1 Men's Restroom North - Lavatory Faucet-Right	1	Legionella Culture	CFU/mL		
1M-1 Men's Restroom North - Lavatory Faucet-Right	1	Copper	ppb		
1M-1 Men's Restroom North - Lavatory Faucet-Right	1	E.Coli	--		
1M-1 Men's Restroom North - Lavatory Faucet-Right	1	Lead	ppb		
1M-1 Men's Restroom North - Lavatory Faucet-Right	1	Total Coliform	--		
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL		
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Copper	ppb		
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	E.Coli	--		
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Lead	ppb		
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Total Coliform	--		
1M-2 Men's Restroom South - Lavatory Faucet-Right	1	Legionella Culture	CFU/mL	ND	ND
1M-2 Men's Restroom South - Lavatory Faucet-Right	1	Copper	ppb	4100	1100
1M-2 Men's Restroom South - Lavatory Faucet-Right	1	E.Coli	--	Absent	Absent
1M-2 Men's Restroom South - Lavatory Faucet-Right	1	Lead	ppb	0	0
1M-2 Men's Restroom South - Lavatory Faucet-Right	1	Total Coliform	--	Absent	Absent
1W-1 Women's Restroom North - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL		
1W-1 Women's Restroom North - Lavatory Faucet-Left	1	Copper	ppb		

1W-1 Women's Restroom North - Lavatory Faucet-Left	1	E.Coli	--		
1W-1 Women's Restroom North - Lavatory Faucet-Left	1	Lead	ppb		
1W-1 Women's Restroom North - Lavatory Faucet-Left	1	Total Coliform	--		
1W-1 Women's Restroom North - Lavatory Faucet-Center	1	Legionella Culture	CFU/mL		
1W-1 Women's Restroom North - Lavatory Faucet-Center	1	Copper	ppb		
1W-1 Women's Restroom North - Lavatory Faucet-Center	1	E.Coli	--		
1W-1 Women's Restroom North - Lavatory Faucet-Center	1	Lead	ppb		
1W-1 Women's Restroom North - Lavatory Faucet-Center	1	Total Coliform	--		
1W-1 Women's Restroom North - Lavatory Faucet-Right	1	Legionella Culture	CFU/mL	ND	ND
1W-1 Women's Restroom North - Lavatory Faucet-Right	1	Copper	ppb	3000	390
1W-1 Women's Restroom North - Lavatory Faucet-Right	1	E.Coli	--	Absent	Absent
1W-1 Women's Restroom North - Lavatory Faucet-Right	1	Lead	ppb	12	0
1W-1 Women's Restroom North - Lavatory Faucet-Right	1	Total Coliform	--	Absent	Absent
1W-2 Women's Restroom South - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL		
1W-2 Women's Restroom South - Lavatory Faucet-Left	1	Copper	ppb		
1W-2 Women's Restroom South - Lavatory Faucet-Left	1	E.Coli	--		
1W-2 Women's Restroom South - Lavatory Faucet-Left	1	Lead	ppb		
1W-2 Women's Restroom South - Lavatory Faucet-Left	1	Total Coliform	--		
1W-2 Women's Restroom South - Lavatory Faucet-Right	1	Legionella Culture	CFU/mL	8	ND
1W-2 Women's Restroom South - Lavatory Faucet-Right	1	Copper	ppb	540	800
1W-2 Women's Restroom South - Lavatory Faucet-Right	1	E.Coli	--	Absent	Absent
1W-2 Women's Restroom South - Lavatory Faucet-Right	1	Lead	ppb	0	0
1W-2 Women's Restroom South - Lavatory Faucet-Right	1	Total Coliform	--	Absent	Absent
119-21 Faucet/Eyewash	1	Legionella Culture	CFU/mL	ND	ND
119-21 Faucet/Eyewash	1	Copper	ppb	1200	210
119-21 Faucet/Eyewash	1	E.Coli	--	Absent	Absent
119-21 Faucet/Eyewash	1	Lead	ppb	0	3.5
119-21 Faucet/Eyewash	1	Total Coliform	--	Absent	Absent
119-16A Shower	1	Legionella Culture	CFU/mL		ND
119-16A Shower	1	Copper	ppb		330
119-16A Shower	1	E.Coli	--		Absent

119-16A Shower	1	Lead	ppb		0
119-16A Shower	1	Total Coliform	--		Absent
119-17 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND
119-17 Toilet/Sink Combo	1	Copper	ppb	1200	960
119-17 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent
119-17 Toilet/Sink Combo	1	Lead	ppb	0	0
119-17 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent
119-19 Food Storage Room-Sink/Faucet	1	Legionella Culture	CFU/mL		
119-19 Food Storage Room-Sink/Faucet	1	Copper	ppb		
119-19 Food Storage Room-Sink/Faucet	1	E.Coli	--		
119-19 Food Storage Room-Sink/Faucet	1	Lead	ppb		
119-19 Food Storage Room-Sink/Faucet	1	Total Coliform	--		
119-11 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND
119-11 Toilet/Sink Combo	1	Copper	ppb	2300	110
119-11 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent
119-11 Toilet/Sink Combo	1	Lead	ppb	0	1.5
119-11 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent
119-10 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND
119-10 Toilet/Sink Combo	1	Copper	ppb	2500	130
119-10 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent
119-10 Toilet/Sink Combo	1	Lead	ppb	0	2
119-10 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent
119-07 Toilet/Sink Combo-Left	1	Legionella Culture	CFU/mL	ND	ND
119-07 Toilet/Sink Combo-Left	1	Copper	ppb	1100	120
119-07 Toilet/Sink Combo-Left	1	E.Coli	--	Absent	Absent
119-07 Toilet/Sink Combo-Left	1	Lead	ppb	0	0
119-07 Toilet/Sink Combo-Left	1	Total Coliform	--	Absent	Absent
119-07 Toilet/Sink Combo-Right	1	Legionella Culture	CFU/mL	ND	ND
119-07 Toilet/Sink Combo-Right	1	Copper	ppb	910	120
119-07 Toilet/Sink Combo-Right	1	E.Coli	--	Absent	Absent
119-07 Toilet/Sink Combo-Right	1	Lead	ppb	0	0

119-07 Toilet/Sink Combo-Right	1	Total Coliform	--	Absent	Absent
119-08 Toilet/Sink Combo-Left	1	Legionella Culture	CFU/mL	ND	ND
119-08 Toilet/Sink Combo-Left	1	Copper	ppb	920	130
119-08 Toilet/Sink Combo-Left	1	E.Coli	--	Absent	Absent
119-08 Toilet/Sink Combo-Left	1	Lead	ppb	0	0
119-08 Toilet/Sink Combo-Left	1	Total Coliform	--	Absent	Absent
119-08 Toilet/Sink Combo-Right	1	Legionella Culture	CFU/mL	ND	ND
119-08 Toilet/Sink Combo-Right	1	Copper	ppb	1100	490
119-08 Toilet/Sink Combo-Right	1	E.Coli	--	Absent	Absent
119-08 Toilet/Sink Combo-Right	1	Lead	ppb	0	1.2
119-08 Toilet/Sink Combo-Right	1	Total Coliform	--	Absent	Absent
128-01 Lactation Room A-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND
128-01 Lactation Room A-Sink/Faucet	1	Copper	ppb	1500	370
128-01 Lactation Room A-Sink/Faucet	1	E.Coli	--	Absent	Absent
128-01 Lactation Room A-Sink/Faucet	1	Lead	ppb	0	0
128-01 Lactation Room A-Sink/Faucet	1	Total Coliform	--	Absent	Absent
128-02 Lactation Room B-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND
128-02 Lactation Room B-Sink/Faucet	1	Copper	ppb	1200	350
128-02 Lactation Room B-Sink/Faucet	1	E.Coli	--	Absent	Absent
128-02 Lactation Room B-Sink/Faucet	1	Lead	ppb	0	0
128-02 Lactation Room B-Sink/Faucet	1	Total Coliform	--	Absent	Absent
128-03 Lactation Room C-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND
128-03 Lactation Room C-Sink/Faucet	1	Copper	ppb	1200	340
128-03 Lactation Room C-Sink/Faucet	1	E.Coli	--	Absent	Absent
128-03 Lactation Room C-Sink/Faucet	1	Lead	ppb	0	0
128-03 Lactation Room C-Sink/Faucet	1	Total Coliform	--	Absent	Absent
128-04 Lactation Room D-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND
128-04 Lactation Room D-Sink/Faucet	1	Copper	ppb	1200	290
128-04 Lactation Room D-Sink/Faucet	1	E.Coli	--	Absent	Absent
128-04 Lactation Room D-Sink/Faucet	1	Lead	ppb	0	0
128-04 Lactation Room D-Sink/Faucet	1	Total Coliform	--	Absent	Absent

119-02 Mailroom - Faucet	1	Legionella Culture	CFU/mL		
119-02 Mailroom - Faucet	1	Copper	ppb		
119-02 Mailroom - Faucet	1	E.Coli	--		
119-02 Mailroom - Faucet	1	Lead	ppb		
119-02 Mailroom - Faucet	1	Total Coliform	--		
C105-1 Janitor's Closet - Mop/Slop Sink	1	Legionella Culture	CFU/mL	ND	ND
C105-1 Janitor's Closet - Mop/Slop Sink	1	Copper	ppb	190	140
C105-1 Janitor's Closet - Mop/Slop Sink	1	E.Coli	--	Absent	Absent
C105-1 Janitor's Closet - Mop/Slop Sink	1	Lead	ppb	0	0
C105-1 Janitor's Closet - Mop/Slop Sink	1	Total Coliform	--	Absent	Absent
1 Corridor North - Drinking Fountain-Left	1	Legionella Culture	CFU/mL		
1 Corridor North - Drinking Fountain-Left	1	Copper	ppb		
1 Corridor North - Drinking Fountain-Left	1	E.Coli	--		
1 Corridor North - Drinking Fountain-Left	1	Lead	ppb		
1 Corridor North - Drinking Fountain-Left	1	Total Coliform	--		
114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	1	Legionella Culture	CFU/mL	ND	ND
114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	1	Copper	ppb	83	62
114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	1	E.Coli	--	Absent	Absent
114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	1	Lead	ppb	1.3	1.5
114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	1	Total Coliform	--	Absent	Absent
1U-1 Loading Dock - Lavatory Faucet	1	Legionella Culture	CFU/mL		
1U-1 Loading Dock - Lavatory Faucet	1	Copper	ppb		
1U-1 Loading Dock - Lavatory Faucet	1	E.Coli	--		
1U-1 Loading Dock - Lavatory Faucet	1	Lead	ppb		
1U-1 Loading Dock - Lavatory Faucet	1	Total Coliform	--		
113-6 JLL Kitchenette-Kitchen Faucet	1	Legionella Culture	CFU/mL	ND	ND
113-6 JLL Kitchenette-Kitchen Faucet	1	Copper	ppb	790	1700
113-6 JLL Kitchenette-Kitchen Faucet	1	E.Coli	--	Absent	Absent
113-6 JLL Kitchenette-Kitchen Faucet	1	Lead	ppb	7.1	0
113-6 JLL Kitchenette-Kitchen Faucet	1	Total Coliform	--	Absent	Absent
123-05 Health Unit - Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND

123-05 Health Unit - Sink/Faucet	1	Copper	ppb	480	410
123-05 Health Unit - Sink/Faucet	1	E.Coli	--	Absent	Absent
123-05 Health Unit - Sink/Faucet	1	Lead	ppb	0	0
123-05 Health Unit - Sink/Faucet	1	Total Coliform	--	Absent	Absent
123-08 Health Unit-Lavatory Faucet	1	Legionella Culture	CFU/mL	ND	ND
123-08 Health Unit-Lavatory Faucet	1	Copper	ppb	4100	1900
123-08 Health Unit-Lavatory Faucet	1	E.Coli	--	Absent	Absent
123-08 Health Unit-Lavatory Faucet	1	Lead	ppb	0	0
123-08 Health Unit-Lavatory Faucet	1	Total Coliform	--	Absent	Absent
123-07 Health Unit-Lavatory Faucet	1	Legionella Culture	CFU/mL	ND	ND
123-07 Health Unit-Lavatory Faucet	1	Copper	ppb	1800	2200
123-07 Health Unit-Lavatory Faucet	1	E.Coli	--	Absent	Absent
123-07 Health Unit-Lavatory Faucet	1	Lead	ppb	0	0
123-07 Health Unit-Lavatory Faucet	1	Total Coliform	--	Absent	Absent
126-05 Men-Lavatory Faucet-Left	1	Legionella Culture	CFU/mL		
126-05 Men-Lavatory Faucet-Left	1	Copper	ppb		
126-05 Men-Lavatory Faucet-Left	1	E.Coli	--		
126-05 Men-Lavatory Faucet-Left	1	Lead	ppb		
126-05 Men-Lavatory Faucet-Left	1	Total Coliform	--		
126-05 Men-Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	ND	ND
126-05 Men-Lavatory Faucet-Center	1	Copper	ppb	1100	720
126-05 Men-Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent
126-05 Men-Lavatory Faucet-Center	1	Lead	ppb	0	3.1
126-05 Men-Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent
126-05 Men-Lavatory Faucet-Right	1	Legionella Culture	CFU/mL		
126-05 Men-Lavatory Faucet-Right	1	Copper	ppb		
126-05 Men-Lavatory Faucet-Right	1	E.Coli	--		
126-05 Men-Lavatory Faucet-Right	1	Lead	ppb		
126-05 Men-Lavatory Faucet-Right	1	Total Coliform	--		
126-06 Shower Room - Shower-North-Left	1	Legionella Culture	CFU/mL	ND	ND
126-06 Shower Room - Shower-North-Left	1	Copper	ppb	1300	960

126-06 Shower Room - Shower-North-Left	1	E.Coli	--	Absent	Absent
126-06 Shower Room - Shower-North-Left	1	Lead	ppb	0	0
126-06 Shower Room - Shower-North-Left	1	Total Coliform	--	Absent	Absent
126-06 Shower Room-Shower-North-Center	1	Legionella Culture	CFU/mL	ND	ND
126-06 Shower Room-Shower-North-Center	1	Copper	ppb	1100	820
126-06 Shower Room-Shower-North-Center	1	E.Coli	--	Absent	Absent
126-06 Shower Room-Shower-North-Center	1	Lead	ppb	0	0
126-06 Shower Room-Shower-North-Center	1	Total Coliform	--	Absent	Absent
126-06 Shower Room - Shower-North-Right	1	Legionella Culture	CFU/mL	ND	ND
126-06 Shower Room - Shower-North-Right	1	Copper	ppb	910	810
126-06 Shower Room - Shower-North-Right	1	E.Coli	--	Absent	Absent
126-06 Shower Room - Shower-North-Right	1	Lead	ppb	0	0
126-06 Shower Room - Shower-North-Right	1	Total Coliform	--	Absent	Absent
126-06 Shower Room - Shower-South-Left	1	Legionella Culture	CFU/mL	ND	ND
126-06 Shower Room - Shower-South-Left	1	Copper	ppb	1100	860
126-06 Shower Room - Shower-South-Left	1	E.Coli	--	Absent	Absent
126-06 Shower Room - Shower-South-Left	1	Lead	ppb	0	0
126-06 Shower Room - Shower-South-Left	1	Total Coliform	--	Absent	Absent
126-06 Shower Room-Shower-South-Center	1	Legionella Culture	CFU/mL	ND	ND
126-06 Shower Room-Shower-South-Center	1	Copper	ppb	1100	830
126-06 Shower Room-Shower-South-Center	1	E.Coli	--	Absent	Absent
126-06 Shower Room-Shower-South-Center	1	Lead	ppb	0	0
126-06 Shower Room-Shower-South-Center	1	Total Coliform	--	Absent	Absent
126-06 Shower Room - Shower-South-Right	1	Legionella Culture	CFU/mL	ND	ND
126-06 Shower Room - Shower-South-Right	1	Copper	ppb	1200	660
126-06 Shower Room - Shower-South-Right	1	E.Coli	--	Absent	Absent
126-06 Shower Room - Shower-South-Right	1	Lead	ppb	0	0
126-06 Shower Room - Shower-South-Right	1	Total Coliform	--	Absent	Absent
126-02 Women-Lavatory Faucet-Left	1	Legionella Culture	CFU/mL		
126-02 Women-Lavatory Faucet-Left	1	Copper	ppb		
126-02 Women-Lavatory Faucet-Left	1	E.Coli	--		

126-02 Women-Lavatory Faucet-Left	1	Lead	ppb		
126-02 Women-Lavatory Faucet-Left	1	Total Coliform	--		
126-02 Women-Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	ND	ND
126-02 Women-Lavatory Faucet-Center	1	Copper	ppb	1800	590
126-02 Women-Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent
126-02 Women-Lavatory Faucet-Center	1	Lead	ppb	13	1.5
126-02 Women-Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent
126-02 Women-Lavatory Faucet-Right	1	Legionella Culture	CFU/mL		
126-02 Women-Lavatory Faucet-Right	1	Copper	ppb		
126-02 Women-Lavatory Faucet-Right	1	E.Coli	--		
126-02 Women-Lavatory Faucet-Right	1	Lead	ppb		
126-02 Women-Lavatory Faucet-Right	1	Total Coliform	--		
126-03 Women-Shower-1st from L to R	1	Legionella Culture	CFU/mL	ND	ND
126-03 Women-Shower-1st from L to R	1	Copper	ppb	930	920
126-03 Women-Shower-1st from L to R	1	E.Coli	--	Absent	Absent
126-03 Women-Shower-1st from L to R	1	Lead	ppb	0	0
126-03 Women-Shower-1st from L to R	1	Total Coliform	--	Absent	Absent
126-03 Women-Shower-2nd from L to R	1	Legionella Culture	CFU/mL	ND	ND
126-03 Women-Shower-2nd from L to R	1	Copper	ppb	1100	670
126-03 Women-Shower-2nd from L to R	1	E.Coli	--	Absent	Absent
126-03 Women-Shower-2nd from L to R	1	Lead	ppb	0	0
126-03 Women-Shower-2nd from L to R	1	Total Coliform	--	Absent	Absent
126-03 Women-Shower-3rd from L to R	1	Legionella Culture	CFU/mL	ND	ND
126-03 Women-Shower-3rd from L to R	1	Copper	ppb	1100	610
126-03 Women-Shower-3rd from L to R	1	E.Coli	--	Absent	Absent
126-03 Women-Shower-3rd from L to R	1	Lead	ppb	0	0
126-03 Women-Shower-3rd from L to R	1	Total Coliform	--	Absent	Absent
126-03 Women-Shower-4th from L to R	1	Legionella Culture	CFU/mL	ND	ND
126-03 Women-Shower-4th from L to R	1	Copper	ppb	740	580
126-03 Women-Shower-4th from L to R	1	E.Coli	--	Absent	Absent
126-03 Women-Shower-4th from L to R	1	Lead	ppb	0	0

126-03 Women-Shower-4th from L to R	1	Total Coliform	--	Absent	Absent
2 Corridor West - Drinking Fountain-Left	2	Legionella Culture	CFU/mL		
2 Corridor West - Drinking Fountain-Left	2	Copper	ppb		
2 Corridor West - Drinking Fountain-Left	2	E.Coli	--		
2 Corridor West - Drinking Fountain-Left	2	Lead	ppb		
2 Corridor West - Drinking Fountain-Left	2	Total Coliform	--		
2W-2 Women's Restroom West - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL		
2W-2 Women's Restroom West - Lavatory Faucet-Left	2	Copper	ppb		
2W-2 Women's Restroom West - Lavatory Faucet-Left	2	E.Coli	--		
2W-2 Women's Restroom West - Lavatory Faucet-Left	2	Lead	ppb		
2W-2 Women's Restroom West - Lavatory Faucet-Left	2	Total Coliform	--		
2W-2 Women's Restroom West - Lavatory Faucet-Center	2	Legionella Culture	CFU/mL	ND	ND
2W-2 Women's Restroom West - Lavatory Faucet-Center	2	Copper	ppb	1200	260
2W-2 Women's Restroom West - Lavatory Faucet-Center	2	E.Coli	--	Absent	Absent
2W-2 Women's Restroom West - Lavatory Faucet-Center	2	Lead	ppb	0	0
2W-2 Women's Restroom West - Lavatory Faucet-Center	2	Total Coliform	--	Absent	Absent
2W-2 Women's Restroom West - Lavatory Faucet-Right	2	Legionella Culture	CFU/mL		
2W-2 Women's Restroom West - Lavatory Faucet-Right	2	Copper	ppb		
2W-2 Women's Restroom West - Lavatory Faucet-Right	2	E.Coli	--		
2W-2 Women's Restroom West - Lavatory Faucet-Right	2	Lead	ppb		
2W-2 Women's Restroom West - Lavatory Faucet-Right	2	Total Coliform	--		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Copper	ppb		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	E.Coli	--		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Lead	ppb		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Total Coliform	--		
2M-2 Men's Restroom West - Lavatory Faucet-Right	2	Legionella Culture	CFU/mL	ND	ND
2M-2 Men's Restroom West - Lavatory Faucet-Right	2	Copper	ppb	660	300
2M-2 Men's Restroom West - Lavatory Faucet-Right	2	E.Coli	--	Absent	Absent
2M-2 Men's Restroom West - Lavatory Faucet-Right	2	Lead	ppb	13	0
2M-2 Men's Restroom West - Lavatory Faucet-Right	2	Total Coliform	--	Absent	Absent

2W-1 Women's Restroom East - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL		
2W-1 Women's Restroom East - Lavatory Faucet-Left	2	Copper	ppb		
2W-1 Women's Restroom East - Lavatory Faucet-Left	2	E.Coli	--		
2W-1 Women's Restroom East - Lavatory Faucet-Left	2	Lead	ppb		
2W-1 Women's Restroom East - Lavatory Faucet-Left	2	Total Coliform	--		
2W-1 Women's Restroom East - Lavatory Faucet-Center	2	Legionella Culture	CFU/mL		
2W-1 Women's Restroom East - Lavatory Faucet-Center	2	Copper	ppb		
2W-1 Women's Restroom East - Lavatory Faucet-Center	2	E.Coli	--		
2W-1 Women's Restroom East - Lavatory Faucet-Center	2	Lead	ppb		
2W-1 Women's Restroom East - Lavatory Faucet-Center	2	Total Coliform	--		
2W-1 Women's Restroom East - Lavatory Faucet-Right	2	Legionella Culture	CFU/mL	ND	ND
2W-1 Women's Restroom East - Lavatory Faucet-Right	2	Copper	ppb	2600	210
2W-1 Women's Restroom East - Lavatory Faucet-Right	2	E.Coli	--	Absent	Absent
2W-1 Women's Restroom East - Lavatory Faucet-Right	2	Lead	ppb	12	0
2W-1 Women's Restroom East - Lavatory Faucet-Right	2	Total Coliform	--	Absent	Absent
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Copper	ppb		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	E.Coli	--		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Lead	ppb		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Total Coliform	--		
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Legionella Culture	CFU/mL	13.6	ND
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Copper	ppb	2200	210
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	E.Coli	--	Absent	Absent
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Lead	ppb	0	0
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Total Coliform	--	Absent	Absent
234 Kitchen Faucet (209-04)	2	Legionella Culture	CFU/mL	ND	ND
234 Kitchen Faucet (209-04)	2	Copper	ppb	810	770
234 Kitchen Faucet (209-04)	2	E.Coli	--	Absent	Absent
234 Kitchen Faucet (209-04)	2	Lead	ppb	0	0
234 Kitchen Faucet (209-04)	2	Total Coliform	--	Absent	Absent
Break Room North West - Kitchen Faucet (207-14)	2	Legionella Culture	CFU/mL	ND	ND

Break Room North West - Kitchen Faucet (207-14)	2	Copper	ppb	1100	650
Break Room North West - Kitchen Faucet (207-14)	2	E.Coli	--	Absent	Absent
Break Room North West - Kitchen Faucet (207-14)	2	Lead	ppb	0	0
Break Room North West - Kitchen Faucet (207-14)	2	Total Coliform	--	Absent	Absent
Break Room North East Kitchen - Faucet (207-39)	2	Legionella Culture	CFU/mL	ND	ND
Break Room North East Kitchen - Faucet (207-39)	2	Copper	ppb	1200	660
Break Room North East Kitchen - Faucet (207-39)	2	E.Coli	--	Absent	Absent
Break Room North East Kitchen - Faucet (207-39)	2	Lead	ppb	0	0
Break Room North East Kitchen - Faucet (207-39)	2	Total Coliform	--	Absent	Absent
Break Room South East Kitchen - Faucet (207-49)	2	Legionella Culture	CFU/mL	ND	ND
Break Room South East Kitchen - Faucet (207-49)	2	Copper	ppb	77	100
Break Room South East Kitchen - Faucet (207-49)	2	E.Coli	--	Absent	Absent
Break Room South East Kitchen - Faucet (207-49)	2	Lead	ppb	0	0
Break Room South East Kitchen - Faucet (207-49)	2	Total Coliform	--	Absent	Absent
E201 Restroom - Lavatory Faucet	2	Legionella Culture	CFU/mL		
E201 Restroom - Lavatory Faucet	2	Copper	ppb		
E201 Restroom - Lavatory Faucet	2	E.Coli	--		
E201 Restroom - Lavatory Faucet	2	Lead	ppb		
E201 Restroom - Lavatory Faucet	2	Total Coliform	--		
C207 Janitor's Closet-Mop/Slop Sink	2	Legionella Culture	CFU/mL		
C207 Janitor's Closet-Mop/Slop Sink	2	Copper	ppb		
C207 Janitor's Closet-Mop/Slop Sink	2	E.Coli	--		
C207 Janitor's Closet-Mop/Slop Sink	2	Lead	ppb		
C207 Janitor's Closet-Mop/Slop Sink	2	Total Coliform	--		
3W-2 Women's Restroom West - Lavatory Faucet-Left	3	Legionella Culture	CFU/mL		
3W-2 Women's Restroom West - Lavatory Faucet-Left	3	Copper	ppb		
3W-2 Women's Restroom West - Lavatory Faucet-Left	3	E.Coli	--		
3W-2 Women's Restroom West - Lavatory Faucet-Left	3	Lead	ppb		
3W-2 Women's Restroom West - Lavatory Faucet-Left	3	Total Coliform	--		
3W-2 Women's Restroom West - Lavatory Faucet-Center	3	Legionella Culture	CFU/mL	ND	1.6
3W-2 Women's Restroom West - Lavatory Faucet-Center	3	Copper	ppb	480	98

3W-2 Women's Restroom West - Lavatory Faucet-Center	3	E.Coli	--	Absent	Absent
3W-2 Women's Restroom West - Lavatory Faucet-Center	3	Lead	ppb	0	0
3W-2 Women's Restroom West - Lavatory Faucet-Center	3	Total Coliform	--	Absent	Absent
3W-2 Women's Restroom West - Lavatory Faucet-Right	3	Legionella Culture	CFU/mL		
3W-2 Women's Restroom West - Lavatory Faucet-Right	3	Copper	ppb		
3W-2 Women's Restroom West - Lavatory Faucet-Right	3	E.Coli	--		
3W-2 Women's Restroom West - Lavatory Faucet-Right	3	Lead	ppb		
3W-2 Women's Restroom West - Lavatory Faucet-Right	3	Total Coliform	--		
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	Legionella Culture	CFU/mL	ND	ND
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	Copper	ppb	440	270
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	E.Coli	--	Absent	Absent
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	Lead	ppb	0	0
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	Total Coliform	--	Absent	Absent
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Legionella Culture	CFU/mL		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Copper	ppb		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	E.Coli	--		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Lead	ppb		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Total Coliform	--		
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	Legionella Culture	CFU/mL	ND	1.6
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	Copper	ppb	3300	170
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	E.Coli	--	Absent	Absent
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	Lead	ppb	43	0
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	Total Coliform	--	Absent	Absent
3W-1 Women's Restroom East - Lavatory Faucet-Left	3	Legionella Culture	CFU/mL		
3W-1 Women's Restroom East - Lavatory Faucet-Left	3	Copper	ppb		
3W-1 Women's Restroom East - Lavatory Faucet-Left	3	E.Coli	--		
3W-1 Women's Restroom East - Lavatory Faucet-Left	3	Lead	ppb		
3W-1 Women's Restroom East - Lavatory Faucet-Left	3	Total Coliform	--		
3W-1 Women's Restroom East - Lavatory Faucet-Center	3	Legionella Culture	CFU/mL	ND	0.4
3W-1 Women's Restroom East - Lavatory Faucet-Center	3	Copper	ppb	1200	270
3W-1 Women's Restroom East - Lavatory Faucet-Center	3	E.Coli	--	Absent	Absent

3W-1 Women's Restroom East - Lavatory Faucet-Center	3	Lead	ppb	16	0
3W-1 Women's Restroom East - Lavatory Faucet-Center	3	Total Coliform	--	Absent	Absent
3W-1 Women's Restroom East - Lavatory Faucet-Right	3	Legionella Culture	CFU/mL		
3W-1 Women's Restroom East - Lavatory Faucet-Right	3	Copper	ppb		
3W-1 Women's Restroom East - Lavatory Faucet-Right	3	E.Coli	--		
3W-1 Women's Restroom East - Lavatory Faucet-Right	3	Lead	ppb		
3W-1 Women's Restroom East - Lavatory Faucet-Right	3	Total Coliform	--		
3 Corridor East - Drinking Fountain-Left	3	Legionella Culture	CFU/mL		
3 Corridor East - Drinking Fountain-Left	3	Copper	ppb		
3 Corridor East - Drinking Fountain-Left	3	E.Coli	--		
3 Corridor East - Drinking Fountain-Left	3	Lead	ppb		
3 Corridor East - Drinking Fountain-Left	3	Total Coliform	--		
C307 Janitor's Closet-Mop/Slop Sink	3	Legionella Culture	CFU/mL		
C307 Janitor's Closet-Mop/Slop Sink	3	Copper	ppb		
C307 Janitor's Closet-Mop/Slop Sink	3	E.Coli	--		
C307 Janitor's Closet-Mop/Slop Sink	3	Lead	ppb		
C307 Janitor's Closet-Mop/Slop Sink	3	Total Coliform	--		
4W-1 Women's Restroom East - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL		
4W-1 Women's Restroom East - Lavatory Faucet-Left	4	Copper	ppb		
4W-1 Women's Restroom East - Lavatory Faucet-Left	4	E.Coli	--		
4W-1 Women's Restroom East - Lavatory Faucet-Left	4	Lead	ppb		
4W-1 Women's Restroom East - Lavatory Faucet-Left	4	Total Coliform	--		
4W-1 Women's Restroom East - Lavatory Faucet-Center	4	Legionella Culture	CFU/mL	7.2	4
4W-1 Women's Restroom East - Lavatory Faucet-Center	4	Copper	ppb	1100	130
4W-1 Women's Restroom East - Lavatory Faucet-Center	4	E.Coli	--	Absent	Absent
4W-1 Women's Restroom East - Lavatory Faucet-Center	4	Lead	ppb	52	0
4W-1 Women's Restroom East - Lavatory Faucet-Center	4	Total Coliform	--	Absent	Absent
4W-1 Women's Restroom East - Lavatory Faucet-Right	4	Legionella Culture	CFU/mL		
4W-1 Women's Restroom East - Lavatory Faucet-Right	4	Copper	ppb		
4W-1 Women's Restroom East - Lavatory Faucet-Right	4	E.Coli	--		
4W-1 Women's Restroom East - Lavatory Faucet-Right	4	Lead	ppb		

4W-1 Women's Restroom East - Lavatory Faucet-Right	4	Total Coliform	--		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Copper	ppb		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	E.Coli	--		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Lead	ppb		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Total Coliform	--		
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	Legionella Culture	CFU/mL	2.4	ND
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	Copper	ppb	500	300
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	E.Coli	--	Absent	Absent
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	Lead	ppb	0	0
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	Total Coliform	--	Absent	Absent
4W-2 Women's Restroom West - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL		
4W-2 Women's Restroom West - Lavatory Faucet-Left	4	Copper	ppb		
4W-2 Women's Restroom West - Lavatory Faucet-Left	4	E.Coli	--		
4W-2 Women's Restroom West - Lavatory Faucet-Left	4	Lead	ppb		
4W-2 Women's Restroom West - Lavatory Faucet-Left	4	Total Coliform	--		
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	Legionella Culture	CFU/mL	ND	ND
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	Copper	ppb	4700	170
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	E.Coli	--	Absent	Absent
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	Lead	ppb	59	0
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	Total Coliform	--	Absent	Absent
4W-2 Women West-Lavatory Faucet-Right	4	Legionella Culture	CFU/mL		
4W-2 Women West-Lavatory Faucet-Right	4	Copper	ppb		
4W-2 Women West-Lavatory Faucet-Right	4	E.Coli	--		
4W-2 Women West-Lavatory Faucet-Right	4	Lead	ppb		
4W-2 Women West-Lavatory Faucet-Right	4	Total Coliform	--		
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL		
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Copper	ppb		
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	E.Coli	--		
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Lead	ppb		
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Total Coliform	--		

4M-2 Men's Restroom West - Lavatory Faucet-Right	4	Legionella Culture	CFU/mL	ND	ND
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	Copper	ppb	1800	150
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	E.Coli	--	Absent	Absent
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	Lead	ppb	0	0
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	Total Coliform	--	Absent	Absent
4 Corridor West - Drinking Fountain-Left	4	Legionella Culture	CFU/mL		
4 Corridor West - Drinking Fountain-Left	4	Copper	ppb		
4 Corridor West - Drinking Fountain-Left	4	E.Coli	--		
4 Corridor West - Drinking Fountain-Left	4	Lead	ppb		
4 Corridor West - Drinking Fountain-Left	4	Total Coliform	--		
Suite 410 Kitchenette Faucet (NW)	4	Legionella Culture	CFU/mL	ND	ND
Suite 410 Kitchenette Faucet (NW)	4	Copper	ppb	1800	890
Suite 410 Kitchenette Faucet (NW)	4	E.Coli	--	Absent	Absent
Suite 410 Kitchenette Faucet (NW)	4	Lead	ppb	0	0
Suite 410 Kitchenette Faucet (NW)	4	Total Coliform	--	Absent	Absent
Suite 415 Kitchenette - Faucet (N)	4	Legionella Culture	CFU/mL	ND	ND
Suite 415 Kitchenette - Faucet (N)	4	Copper	ppb	82	250
Suite 415 Kitchenette - Faucet (N)	4	E.Coli	--	Absent	Absent
Suite 415 Kitchenette - Faucet (N)	4	Lead	ppb	0	0
Suite 415 Kitchenette - Faucet (N)	4	Total Coliform	--	Absent	Absent
Suite 416 Kitchenette - Faucet (NE) - North	4	Legionella Culture	CFU/mL	ND	ND
Suite 416 Kitchenette - Faucet (NE) - North	4	Copper	ppb	760	990
Suite 416 Kitchenette - Faucet (NE) - North	4	E.Coli	--	Absent	Absent
Suite 416 Kitchenette - Faucet (NE) - North	4	Lead	ppb	0	0
Suite 416 Kitchenette - Faucet (NE) - North	4	Total Coliform	--	Absent	Absent
Suite 420 Kitchenette - Faucet (NE) - South	4	Legionella Culture	CFU/mL	ND	ND
Suite 420 Kitchenette - Faucet (NE) - South	4	Copper	ppb	750	540
Suite 420 Kitchenette - Faucet (NE) - South	4	E.Coli	--	Absent	Absent
Suite 420 Kitchenette - Faucet (NE) - South	4	Lead	ppb	0	0
Suite 420 Kitchenette - Faucet (NE) - South	4	Total Coliform	--	Absent	Absent
Suite 435 Kitchenette Faucet (SE)	4	Legionella Culture	CFU/mL	ND	ND

Suite 435 Kitchenette Faucet (SE)	4	Copper	ppb	610	490
Suite 435 Kitchenette Faucet (SE)	4	E.Coli	--	Absent	Absent
Suite 435 Kitchenette Faucet (SE)	4	Lead	ppb	0	0
Suite 435 Kitchenette Faucet (SE)	4	Total Coliform	--	Absent	Absent
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	Copper	ppb	170	200
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	E.Coli	--	Absent	Absent
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	Lead	ppb	0	0
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	Total Coliform	--	Absent	Absent
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	Legionella Culture	CFU/mL	ND	ND
C407 Janitor's Closet-Mop/Slop Sink	4	Legionella Culture	CFU/mL		
C407 Janitor's Closet-Mop/Slop Sink	4	Copper	ppb		
C407 Janitor's Closet-Mop/Slop Sink	4	E.Coli	--		
C407 Janitor's Closet-Mop/Slop Sink	4	Lead	ppb		
C407 Janitor's Closet-Mop/Slop Sink	4	Total Coliform	--		
Suite 540 Kitchenette - Faucet (507-25)	5	Legionella Culture	CFU/mL	ND	ND
Suite 540 Kitchenette - Faucet (507-25)	5	Copper	ppb	300	600
Suite 540 Kitchenette - Faucet (507-25)	5	E.Coli	--	Absent	Absent
Suite 540 Kitchenette - Faucet (507-25)	5	Lead	ppb	0	0
Suite 540 Kitchenette - Faucet (507-25)	5	Total Coliform	--	Absent	Absent
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Legionella Culture	CFU/mL	ND	ND
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Copper	ppb	1600	830
Suite 535 Break Room-Kitchen Faucet (507-36)	5	E.Coli	--	Absent	Absent
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Lead	ppb	0	0
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Total Coliform	--	Absent	Absent
540 Faucet (507-26)	5	Legionella Culture	CFU/mL	ND	ND
540 Faucet (507-26)	5	Copper	ppb	770	550
540 Faucet (507-26)	5	E.Coli	--	Absent	Absent
540 Faucet (507-26)	5	Lead	ppb	0	0
540 Faucet (507-26)	5	Total Coliform	--	Absent	Absent
540 Faucet (507-26) A (Second fixture)	5	E.Coli	--		
540 Faucet (507-26) A (Second fixture)	5	Total Coliform	--		

540 Faucet (507-26) A (Second fixture)	5	Lead	ppb		
540 Faucet (507-26) A (Second fixture)	5	Copper	ppb		
540 Faucet (507-26) A (Second fixture)	5	Legionella Culture	CFU/mL		
5W-2 Women's Restroom West - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL		
5W-2 Women's Restroom West - Lavatory Faucet-Left	5	Copper	ppb		
5W-2 Women's Restroom West - Lavatory Faucet-Left	5	E.Coli	--		
5W-2 Women's Restroom West - Lavatory Faucet-Left	5	Lead	ppb		
5W-2 Women's Restroom West - Lavatory Faucet-Left	5	Total Coliform	--		
5W-2 Women's Restroom West - Lavatory Faucet-Center	5	Legionella Culture	CFU/mL	ND	ND
5W-2 Women's Restroom West - Lavatory Faucet-Center	5	Copper	ppb	920	230
5W-2 Women's Restroom West - Lavatory Faucet-Center	5	E.Coli	--	Absent	Absent
5W-2 Women's Restroom West - Lavatory Faucet-Center	5	Lead	ppb	25	0
5W-2 Women's Restroom West - Lavatory Faucet-Center	5	Total Coliform	--	Absent	Absent
5W-2 Women's Restroom West - Lavatory Faucet-Right	5	Legionella Culture	CFU/mL		
5W-2 Women's Restroom West - Lavatory Faucet-Right	5	Copper	ppb		
5W-2 Women's Restroom West - Lavatory Faucet-Right	5	E.Coli	--		
5W-2 Women's Restroom West - Lavatory Faucet-Right	5	Lead	ppb		
5W-2 Women's Restroom West - Lavatory Faucet-Right	5	Total Coliform	--		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Copper	ppb		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	E.Coli	--		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Lead	ppb		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Total Coliform	--		
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	Legionella Culture	CFU/mL	ND	4
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	Copper	ppb	1300	410
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	E.Coli	--	Absent	Absent
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	Lead	ppb	0	0
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	Total Coliform	--	Absent	Absent
5 Corridor West - Drinking Fountain-Right	5	Legionella Culture	CFU/mL		
5 Corridor West - Drinking Fountain-Right	5	Copper	ppb		
5 Corridor West - Drinking Fountain-Right	5	E.Coli	--		

5 Corridor West - Drinking Fountain-Right	5	Lead	ppb		
5 Corridor West - Drinking Fountain-Right	5	Total Coliform	--		
Suite 540 Kitchenette - Faucet (507-15)	5	Legionella Culture	CFU/mL	ND	ND
Suite 540 Kitchenette - Faucet (507-15)	5	Copper	ppb	970	940
Suite 540 Kitchenette - Faucet (507-15)	5	E.Coli	--	Absent	Absent
Suite 540 Kitchenette - Faucet (507-15)	5	Lead	ppb	0	0
Suite 540 Kitchenette - Faucet (507-15)	5	Total Coliform	--	Absent	Absent
Suite 540 Training Lobby - Faucet (507-12)	5	Legionella Culture	CFU/mL		
Suite 540 Training Lobby - Faucet (507-12)	5	Copper	ppb		
Suite 540 Training Lobby - Faucet (507-12)	5	E.Coli	--		
Suite 540 Training Lobby - Faucet (507-12)	5	Lead	ppb		
Suite 540 Training Lobby - Faucet (507-12)	5	Total Coliform	--		
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL		
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Copper	ppb		
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	E.Coli	--		
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Lead	ppb		
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Total Coliform	--		
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	Legionella Culture	CFU/mL	ND	ND
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	Copper	ppb	860	75
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	E.Coli	--	Absent	Absent
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	Lead	ppb	22	0
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	Total Coliform	--	Absent	Absent
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL		
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	Copper	ppb		
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	E.Coli	--		
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	Lead	ppb		
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	Total Coliform	--		
5W-1 Women's Restroom East - Lavatory Faucet-Center	5	Legionella Culture	CFU/mL	0.8	ND
5W-1 Women's Restroom East - Lavatory Faucet-Center	5	Copper	ppb	2000	1300
5W-1 Women's Restroom East - Lavatory Faucet-Center	5	E.Coli	--	Absent	Absent
5W-1 Women's Restroom East - Lavatory Faucet-Center	5	Lead	ppb	51	0

5W-1 Women's Restroom East - Lavatory Faucet-Center	5	Total Coliform	--	Absent	Absent
5W-1 Women's Restroom East - Lavatory Faucet-Right	5	Legionella Culture	CFU/mL		
5W-1 Women's Restroom East - Lavatory Faucet-Right	5	Copper	ppb		
5W-1 Women's Restroom East - Lavatory Faucet-Right	5	E.Coli	--		
5W-1 Women's Restroom East - Lavatory Faucet-Right	5	Lead	ppb		
5W-1 Women's Restroom East - Lavatory Faucet-Right	5	Total Coliform	--		
Suite 530 Kitchenette - Faucet (509-10)	5	Legionella Culture	CFU/mL	ND	ND
Suite 530 Kitchenette - Faucet (509-10)	5	Copper	ppb	92	160
Suite 530 Kitchenette - Faucet (509-10)	5	E.Coli	--	Absent	Absent
Suite 530 Kitchenette - Faucet (509-10)	5	Lead	ppb	0	0
Suite 530 Kitchenette - Faucet (509-10)	5	Total Coliform	--	Absent	Absent
Suite 520 Kitchenette Faucet (508-13)	5	Legionella Culture	CFU/mL	ND	ND
Suite 520 Kitchenette Faucet (508-13)	5	Copper	ppb	1700	1000
Suite 520 Kitchenette Faucet (508-13)	5	E.Coli	--	Absent	Absent
Suite 520 Kitchenette Faucet (508-13)	5	Lead	ppb	0	0
Suite 520 Kitchenette Faucet (508-13)	5	Total Coliform	--	Absent	Absent
Suite 532 Lactation Room - Faucet	5	Legionella Culture	CFU/mL	ND	ND
Suite 532 Lactation Room - Faucet	5	Copper	ppb	810	780
Suite 532 Lactation Room - Faucet	5	E.Coli	--	Absent	Absent
Suite 532 Lactation Room - Faucet	5	Lead	ppb	0	0
Suite 532 Lactation Room - Faucet	5	Total Coliform	--	Absent	Absent
Suite. 540 Kitchenette - Faucet	5	Legionella Culture	CFU/mL		
Suite. 540 Kitchenette - Faucet	5	Copper	ppb		
Suite. 540 Kitchenette - Faucet	5	E.Coli	--		
Suite. 540 Kitchenette - Faucet	5	Lead	ppb		
Suite. 540 Kitchenette - Faucet	5	Total Coliform	--		
C507 Janitor's Closet - Mop/Slop Sink	5	Legionella Culture	CFU/mL		
C507 Janitor's Closet - Mop/Slop Sink	5	Copper	ppb		
C507 Janitor's Closet - Mop/Slop Sink	5	E.Coli	--		
C507 Janitor's Closet - Mop/Slop Sink	5	Lead	ppb		
C507 Janitor's Closet - Mop/Slop Sink	5	Total Coliform	--		

Suite 614 Room-Kitchen Faucet (610-03)	6	Legionella Culture	CFU/mL	ND	ND
Suite 614 Room-Kitchen Faucet (610-03)	6	Copper	ppb	310	340
Suite 614 Room-Kitchen Faucet (610-03)	6	E.Coli	--	Absent	Absent
Suite 614 Room-Kitchen Faucet (610-03)	6	Lead	ppb	0	0
Suite 614 Room-Kitchen Faucet (610-03)	6	Total Coliform	--	Absent	Absent
C607-Janitor's Closet - Mop/Slop Sink	6	Legionella Culture	CFU/mL		
C607-Janitor's Closet - Mop/Slop Sink	6	Copper	ppb		
C607-Janitor's Closet - Mop/Slop Sink	6	E.Coli	--		
C607-Janitor's Closet - Mop/Slop Sink	6	Lead	ppb		
C607-Janitor's Closet - Mop/Slop Sink	6	Total Coliform	--		
6 Corridor West - Drinking Fountain-Left	6	Legionella Culture	CFU/mL		
6 Corridor West - Drinking Fountain-Left	6	Copper	ppb		
6 Corridor West - Drinking Fountain-Left	6	E.Coli	--		
6 Corridor West - Drinking Fountain-Left	6	Lead	ppb		
6 Corridor West - Drinking Fountain-Left	6	Total Coliform	--		
6W-2 Women's Restroom West - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL		
6W-2 Women's Restroom West - Lavatory Faucet-Left	6	Copper	ppb		
6W-2 Women's Restroom West - Lavatory Faucet-Left	6	E.Coli	--		
6W-2 Women's Restroom West - Lavatory Faucet-Left	6	Lead	ppb		
6W-2 Women's Restroom West - Lavatory Faucet-Left	6	Total Coliform	--		
6W-2 Women's Restroom West - Lavatory Faucet-Center	6	Legionella Culture	CFU/mL	ND	ND
6W-2 Women's Restroom West - Lavatory Faucet-Center	6	Copper	ppb	560	300
6W-2 Women's Restroom West - Lavatory Faucet-Center	6	E.Coli	--	Absent	Absent
6W-2 Women's Restroom West - Lavatory Faucet-Center	6	Lead	ppb	0	0
6W-2 Women's Restroom West - Lavatory Faucet-Center	6	Total Coliform	--	Absent	Absent
6W-2 Women's Restroom West - Lavatory Faucet-Right	6	Legionella Culture	CFU/mL		
6W-2 Women's Restroom West - Lavatory Faucet-Right	6	Copper	ppb		
6W-2 Women's Restroom West - Lavatory Faucet-Right	6	E.Coli	--		
6W-2 Women's Restroom West - Lavatory Faucet-Right	6	Lead	ppb		
6W-2 Women's Restroom West - Lavatory Faucet-Right	6	Total Coliform	--		
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL		

6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Copper	ppb		
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	E.Coli	--		
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Lead	ppb		
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Total Coliform	--		
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	Legionella Culture	CFU/mL	ND	ND
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	Copper	ppb	1200	340
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	E.Coli	--	Absent	Absent
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	Lead	ppb	25	0
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	Total Coliform	--	Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Legionella Culture	CFU/mL	ND	ND
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Copper	ppb	970	490
Suite 615 Break Room-Kitchen Faucet (607-06)	6	E.Coli	--	Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Lead	ppb	0	0
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Total Coliform	--	Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	6	Copper	ppb	750	760
Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	6	E.Coli	--	Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	6	Lead	ppb	0	0
Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	6	Total Coliform	--	Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	6	Legionella Culture	CFU/mL	ND	ND
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL		
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Copper	ppb		
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	E.Coli	--		
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Lead	ppb		
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Total Coliform	--		
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	Legionella Culture	CFU/mL	ND	ND
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	Copper	ppb	1100	350
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	E.Coli	--	Absent	Absent
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	Lead	ppb	18	0
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	Total Coliform	--	Absent	Absent
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Copper	ppb		

6W-1 Women's Restroom East - Lavatory Faucet-Left	6	E.Coli	--		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Lead	ppb		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Total Coliform	--		
6W-1 Women's Restroom East - Lavatory Faucet-Center	6	Legionella Culture	CFU/mL	ND	ND
6W-1 Women's Restroom East - Lavatory Faucet-Center	6	Copper	ppb	1200	300
6W-1 Women's Restroom East - Lavatory Faucet-Center	6	E.Coli	--	Absent	Absent
6W-1 Women's Restroom East - Lavatory Faucet-Center	6	Lead	ppb	17	0
6W-1 Women's Restroom East - Lavatory Faucet-Center	6	Total Coliform	--	Absent	Absent
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	Legionella Culture	CFU/mL		
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	Copper	ppb		
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	E.Coli	--		
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	Lead	ppb		
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	Total Coliform	--		
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Legionella Culture	CFU/mL		
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Copper	ppb		
Suite 620 Break Room-Kitchen Faucet (608-12)	6	E.Coli	--		
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Lead	ppb		
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Total Coliform	--		
Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	6	Copper	ppb		
Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	6	E.Coli	--		
Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	6	Lead	ppb		
Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	6	Total Coliform	--		
Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	6	Legionella Culture	CFU/mL		
Suite 608 Kitchen - Faucet	6	Legionella Culture	CFU/mL	ND	ND
Suite 608 Kitchen - Faucet	6	Copper	ppb	400	240
Suite 608 Kitchen - Faucet	6	E.Coli	--	Absent	Absent
Suite 608 Kitchen - Faucet	6	Lead	ppb	0	0
Suite 608 Kitchen - Faucet	6	Total Coliform	--	Absent	Absent
C707-Janitor's Closet-Mop/Slop Sink	7	Legionella Culture	CFU/mL		
C707-Janitor's Closet-Mop/Slop Sink	7	Copper	ppb		
C707-Janitor's Closet-Mop/Slop Sink	7	E.Coli	--		

C707-Janitor's Closet-Mop/Slop Sink	7	Lead	ppb		
C707-Janitor's Closet-Mop/Slop Sink	7	Total Coliform	--		
7 Corridor East - Drinking Fountain-Left	7	Legionella Culture	CFU/mL		
7 Corridor East - Drinking Fountain-Left	7	Copper	ppb		
7 Corridor East - Drinking Fountain-Left	7	E.Coli	--		
7 Corridor East - Drinking Fountain-Left	7	Lead	ppb		
7 Corridor East - Drinking Fountain-Left	7	Total Coliform	--		
Suite 707-01 Break Room - Faucet (707-2)	7	Legionella Culture	CFU/mL	ND	ND
Suite 707-01 Break Room - Faucet (707-2)	7	Copper	ppb	74	56
Suite 707-01 Break Room - Faucet (707-2)	7	E.Coli	--	Absent	Absent
Suite 707-01 Break Room - Faucet (707-2)	7	Lead	ppb	0	0
Suite 707-01 Break Room - Faucet (707-2)	7	Total Coliform	--	Absent	Absent
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Copper	ppb		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	E.Coli	--		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Lead	ppb		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Total Coliform	--		
7W-2 Women's Restroom West - Lavatory Faucet-Center	7	Legionella Culture	CFU/mL	ND	ND
7W-2 Women's Restroom West - Lavatory Faucet-Center	7	Copper	ppb	660	270
7W-2 Women's Restroom West - Lavatory Faucet-Center	7	E.Coli	--	Absent	Absent
7W-2 Women's Restroom West - Lavatory Faucet-Center	7	Lead	ppb	0	0
7W-2 Women's Restroom West - Lavatory Faucet-Center	7	Total Coliform	--	Absent	Absent
7W-2 Women's Restroom West - Lavatory Faucet-Right	7	Legionella Culture	CFU/mL		
7W-2 Women's Restroom West - Lavatory Faucet-Right	7	Copper	ppb		
7W-2 Women's Restroom West - Lavatory Faucet-Right	7	E.Coli	--		
7W-2 Women's Restroom West - Lavatory Faucet-Right	7	Lead	ppb		
7W-2 Women's Restroom West - Lavatory Faucet-Right	7	Total Coliform	--		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Copper	ppb		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	E.Coli	--		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Lead	ppb		

7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Total Coliform	--		
7M-2 Men's Restroom West - Lavatory Faucet-Right	7	Legionella Culture	CFU/mL	ND	ND
7M-2 Men's Restroom West - Lavatory Faucet-Right	7	Copper	ppb	780	340
7M-2 Men's Restroom West - Lavatory Faucet-Right	7	E.Coli	--	Absent	Absent
7M-2 Men's Restroom West - Lavatory Faucet-Right	7	Lead	ppb	0	0
7M-2 Men's Restroom West - Lavatory Faucet-Right	7	Total Coliform	--	Absent	Absent
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL		
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Copper	ppb		
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	E.Coli	--		
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Lead	ppb		
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Total Coliform	--		
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	Legionella Culture	CFU/mL	ND	ND
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	Copper	ppb	490	280
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	E.Coli	--	Absent	Absent
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	Lead	ppb	0	0
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	Total Coliform	--	Absent	Absent
7W-1 Women's Restroom East - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL		
7W-1 Women's Restroom East - Lavatory Faucet-Left	7	Copper	ppb		
7W-1 Women's Restroom East - Lavatory Faucet-Left	7	E.Coli	--		
7W-1 Women's Restroom East - Lavatory Faucet-Left	7	Lead	ppb		
7W-1 Women's Restroom East - Lavatory Faucet-Left	7	Total Coliform	--		
7W-1 Women's Restroom East - Lavatory Faucet-Center	7	Legionella Culture	CFU/mL		
7W-1 Women's Restroom East - Lavatory Faucet-Center	7	Copper	ppb		
7W-1 Women's Restroom East - Lavatory Faucet-Center	7	E.Coli	--		
7W-1 Women's Restroom East - Lavatory Faucet-Center	7	Lead	ppb		
7W-1 Women's Restroom East - Lavatory Faucet-Center	7	Total Coliform	--		
7W-1 Women's Restroom East - Lavatory Faucet-Right	7	Legionella Culture	CFU/mL	ND	ND
7W-1 Women's Restroom East - Lavatory Faucet-Right	7	Copper	ppb	650	110
7W-1 Women's Restroom East - Lavatory Faucet-Right	7	E.Coli	--	Absent	Absent
7W-1 Women's Restroom East - Lavatory Faucet-Right	7	Lead	ppb	0	0
7W-1 Women's Restroom East - Lavatory Faucet-Right	7	Total Coliform	--	Absent	Absent

Suite 710 Faucet (710-03)	7	Legionella Culture	CFU/mL	ND	ND
Suite 710 Faucet (710-03)	7	Copper	ppb	110	100
Suite 710 Faucet (710-03)	7	E.Coli	--	Absent	Absent
Suite 710 Faucet (710-03)	7	Lead	ppb	0	0
Suite 710 Faucet (710-03)	7	Total Coliform	--	Absent	Absent
Suite 707-10 Faucet (707-07)	7	Legionella Culture	CFU/mL	ND	ND
Suite 707-10 Faucet (707-07)	7	Copper	ppb	230	170
Suite 707-10 Faucet (707-07)	7	E.Coli	--	Absent	Absent
Suite 707-10 Faucet (707-07)	7	Lead	ppb	0	0
Suite 707-10 Faucet (707-07)	7	Total Coliform	--	Absent	Absent
Suite 810 Kitchen Faucet	8	Legionella Culture	CFU/mL	ND	ND
Suite 810 Kitchen Faucet	8	Copper	ppb	270	430
Suite 810 Kitchen Faucet	8	E.Coli	--	Absent	Absent
Suite 810 Kitchen Faucet	8	Lead	ppb	0	0
Suite 810 Kitchen Faucet	8	Total Coliform	--	Absent	Absent
C807-Janitor's Closet-Mop/Slop Sink	8	Legionella Culture	CFU/mL		
C807-Janitor's Closet-Mop/Slop Sink	8	Copper	ppb		
C807-Janitor's Closet-Mop/Slop Sink	8	E.Coli	--		
C807-Janitor's Closet-Mop/Slop Sink	8	Lead	ppb		
C807-Janitor's Closet-Mop/Slop Sink	8	Total Coliform	--		
8 Corridor West - Drinking Fountain-Left	8	Legionella Culture	CFU/mL		
8 Corridor West - Drinking Fountain-Left	8	Copper	ppb		
8 Corridor West - Drinking Fountain-Left	8	E.Coli	--		
8 Corridor West - Drinking Fountain-Left	8	Lead	ppb		
8 Corridor West - Drinking Fountain-Left	8	Total Coliform	--		
8W-2 Women's Restroom West - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL		
8W-2 Women's Restroom West - Lavatory Faucet-Left	8	Copper	ppb		
8W-2 Women's Restroom West - Lavatory Faucet-Left	8	E.Coli	--		
8W-2 Women's Restroom West - Lavatory Faucet-Left	8	Lead	ppb		
8W-2 Women's Restroom West - Lavatory Faucet-Left	8	Total Coliform	--		
8W-2 Women's Restroom West - Lavatory Faucet-Center	8	Legionella Culture	CFU/mL	ND	ND

8W-2 Women's Restroom West - Lavatory Faucet-Center	8	Copper	ppb	410	290
8W-2 Women's Restroom West - Lavatory Faucet-Center	8	E.Coli	--	Absent	Absent
8W-2 Women's Restroom West - Lavatory Faucet-Center	8	Lead	ppb	0	0
8W-2 Women's Restroom West - Lavatory Faucet-Center	8	Total Coliform	--	Absent	Absent
8W-2 Women's Restroom West - Lavatory Faucet-Right	8	Legionella Culture	CFU/mL		
8W-2 Women's Restroom West - Lavatory Faucet-Right	8	Copper	ppb		
8W-2 Women's Restroom West - Lavatory Faucet-Right	8	E.Coli	--		
8W-2 Women's Restroom West - Lavatory Faucet-Right	8	Lead	ppb		
8W-2 Women's Restroom West - Lavatory Faucet-Right	8	Total Coliform	--		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Copper	ppb		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	E.Coli	--		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Lead	ppb		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Total Coliform	--		
8M-2 Men's Restroom West - Lavatory Faucet-Right	8	Legionella Culture	CFU/mL	ND	ND
8M-2 Men's Restroom West - Lavatory Faucet-Right	8	Copper	ppb	540	300
8M-2 Men's Restroom West - Lavatory Faucet-Right	8	E.Coli	--	Absent	Absent
8M-2 Men's Restroom West - Lavatory Faucet-Right	8	Lead	ppb	0	0
8M-2 Men's Restroom West - Lavatory Faucet-Right	8	Total Coliform	--	Absent	Absent
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL		
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Copper	ppb		
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	E.Coli	--		
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Lead	ppb		
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Total Coliform	--		
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	Legionella Culture	CFU/mL	ND	ND
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	Copper	ppb	700	350
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	E.Coli	--	Absent	Absent
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	Lead	ppb	0	0
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	Total Coliform	--	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL		
8W-1 Women's Restroom East - Lavatory Faucet-Left	8	Copper	ppb		

8W-1 Women's Restroom East - Lavatory Faucet-Left	8	E.Coli	--		
8W-1 Women's Restroom East - Lavatory Faucet-Left	8	Lead	ppb		
8W-1 Women's Restroom East - Lavatory Faucet-Left	8	Total Coliform	--		
8W-1 Women's Restroom East - Lavatory Faucet-Center	8	Legionella Culture	CFU/mL	0.4	ND
8W-1 Women's Restroom East - Lavatory Faucet-Center	8	Copper	ppb	740	380
8W-1 Women's Restroom East - Lavatory Faucet-Center	8	E.Coli	--	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-Center	8	Lead	ppb	0	0
8W-1 Women's Restroom East - Lavatory Faucet-Center	8	Total Coliform	--	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-Right	8	Legionella Culture	CFU/mL		
8W-1 Women's Restroom East - Lavatory Faucet-Right	8	Copper	ppb		
8W-1 Women's Restroom East - Lavatory Faucet-Right	8	E.Coli	--		
8W-1 Women's Restroom East - Lavatory Faucet-Right	8	Lead	ppb		
8W-1 Women's Restroom East - Lavatory Faucet-Right	8	Total Coliform	--		
Suite 808A Break Room Faucet (809-02)	8	Legionella Culture	CFU/mL	ND	ND
Suite 808A Break Room Faucet (809-02)	8	Copper	ppb	350	300
Suite 808A Break Room Faucet (809-02)	8	E.Coli	--	Absent	Absent
Suite 808A Break Room Faucet (809-02)	8	Lead	ppb	0	0
Suite 808A Break Room Faucet (809-02)	8	Total Coliform	--	Absent	Absent
C907-Janitor's Closet-Mop/Slop Sink	9	Legionella Culture	CFU/mL		
C907-Janitor's Closet-Mop/Slop Sink	9	Copper	ppb		
C907-Janitor's Closet-Mop/Slop Sink	9	E.Coli	--		
C907-Janitor's Closet-Mop/Slop Sink	9	Lead	ppb		
C907-Janitor's Closet-Mop/Slop Sink	9	Total Coliform	--		
9 Corridor East - Drinking Fountain-Left	9	Legionella Culture	CFU/mL		
9 Corridor East - Drinking Fountain-Left	9	Copper	ppb		
9 Corridor East - Drinking Fountain-Left	9	E.Coli	--		
9 Corridor East - Drinking Fountain-Left	9	Lead	ppb		
9 Corridor East - Drinking Fountain-Left	9	Total Coliform	--		
Suite 907A Break Room Faucet (907-22)	9	Legionella Culture	CFU/mL	ND	ND
Suite 907A Break Room Faucet (907-22)	9	Copper	ppb	510	810
Suite 907A Break Room Faucet (907-22)	9	E.Coli	--	Absent	Absent

Suite 907A Break Room Faucet (907-22)	9	Lead	ppb	0	0
Suite 907A Break Room Faucet (907-22)	9	Total Coliform	--	Absent	Absent
Suite 910A Faucet (910-05)	9	Legionella Culture	CFU/mL	ND	ND
Suite 910A Faucet (910-05)	9	Copper	ppb	650	700
Suite 910A Faucet (910-05)	9	E.Coli	--	Absent	Absent
Suite 910A Faucet (910-05)	9	Lead	ppb	0	0
Suite 910A Faucet (910-05)	9	Total Coliform	--	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL		
9W-2 Women's Restroom West - Lavatory Faucet-Left	9	Copper	ppb		
9W-2 Women's Restroom West - Lavatory Faucet-Left	9	E.Coli	--		
9W-2 Women's Restroom West - Lavatory Faucet-Left	9	Lead	ppb		
9W-2 Women's Restroom West - Lavatory Faucet-Left	9	Total Coliform	--		
9W-2 Women's Restroom West - Lavatory Faucet-Center	9	Legionella Culture	CFU/mL	ND	0.4
9W-2 Women's Restroom West - Lavatory Faucet-Center	9	Copper	ppb	510	270
9W-2 Women's Restroom West - Lavatory Faucet-Center	9	E.Coli	--	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-Center	9	Lead	ppb	0	0
9W-2 Women's Restroom West - Lavatory Faucet-Center	9	Total Coliform	--	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-Right	9	Legionella Culture	CFU/mL		
9W-2 Women's Restroom West - Lavatory Faucet-Right	9	Copper	ppb		
9W-2 Women's Restroom West - Lavatory Faucet-Right	9	E.Coli	--		
9W-2 Women's Restroom West - Lavatory Faucet-Right	9	Lead	ppb		
9W-2 Women's Restroom West - Lavatory Faucet-Right	9	Total Coliform	--		
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL		
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Copper	ppb		
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	E.Coli	--		
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Lead	ppb		
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Total Coliform	--		
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	Legionella Culture	CFU/mL	ND	ND
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	Copper	ppb	1500	330
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	E.Coli	--	Absent	Absent
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	Lead	ppb	0	0

9M-2 Men's Restroom West - Lavatory Faucet-Right	9	Total Coliform	--	Absent	Absent
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL		
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Copper	ppb		
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	E.Coli	--		
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Lead	ppb		
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Total Coliform	--		
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	Legionella Culture	CFU/mL	ND	ND
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	Copper	ppb	4000	310
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	E.Coli	--	Absent	Absent
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	Lead	ppb	0	0
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	Total Coliform	--	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL		
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	Copper	ppb		
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	E.Coli	--		
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	Lead	ppb		
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	Total Coliform	--		
9W-1 Women's Restroom East - Lavatory Faucet-Center	9	Legionella Culture	CFU/mL	4	ND
9W-1 Women's Restroom East - Lavatory Faucet-Center	9	Copper	ppb	430	220
9W-1 Women's Restroom East - Lavatory Faucet-Center	9	E.Coli	--	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-Center	9	Lead	ppb	0	0
9W-1 Women's Restroom East - Lavatory Faucet-Center	9	Total Coliform	--	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-Right	9	Legionella Culture	CFU/mL		
9W-1 Women's Restroom East - Lavatory Faucet-Right	9	Copper	ppb		
9W-1 Women's Restroom East - Lavatory Faucet-Right	9	E.Coli	--		
9W-1 Women's Restroom East - Lavatory Faucet-Right	9	Lead	ppb		
9W-1 Women's Restroom East - Lavatory Faucet-Right	9	Total Coliform	--		
Suite 908 Break Room Faucet (908-15)	9	Legionella Culture	CFU/mL	ND	ND
Suite 908 Break Room Faucet (908-15)	9	Copper	ppb	840	680
Suite 908 Break Room Faucet (908-15)	9	E.Coli	--	Absent	Absent
Suite 908 Break Room Faucet (908-15)	9	Lead	ppb	0	0
Suite 908 Break Room Faucet (908-15)	9	Total Coliform	--	Absent	Absent

C1007-Janitor's Closet-Mop/Slop Sink	10	Legionella Culture	CFU/mL		
C1007-Janitor's Closet-Mop/Slop Sink	10	Copper	ppb		
C1007-Janitor's Closet-Mop/Slop Sink	10	E.Coli	--		
C1007-Janitor's Closet-Mop/Slop Sink	10	Lead	ppb		
C1007-Janitor's Closet-Mop/Slop Sink	10	Total Coliform	--		
10 Corridor West - Drinking Fountain-Left	10	Legionella Culture	CFU/mL		
10 Corridor West - Drinking Fountain-Left	10	Copper	ppb		
10 Corridor West - Drinking Fountain-Left	10	E.Coli	--		
10 Corridor West - Drinking Fountain-Left	10	Lead	ppb		
10 Corridor West - Drinking Fountain-Left	10	Total Coliform	--		
Suite 1010 Lavatory Faucet	10	Legionella Culture	CFU/mL		
Suite 1010 Lavatory Faucet	10	Copper	ppb		
Suite 1010 Lavatory Faucet	10	E.Coli	--		
Suite 1010 Lavatory Faucet	10	Lead	ppb		
Suite 1010 Lavatory Faucet	10	Total Coliform	--		
Suite 1010 Kitchenette Faucet	10	Legionella Culture	CFU/mL	ND	ND
Suite 1010 Kitchenette Faucet	10	Copper	ppb	1000	1100
Suite 1010 Kitchenette Faucet	10	E.Coli	--	Absent	Absent
Suite 1010 Kitchenette Faucet	10	Lead	ppb	0	0
Suite 1010 Kitchenette Faucet	10	Total Coliform	--	Absent	Absent
10W-2 Women's Restroom West - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL		
10W-2 Women's Restroom West - Lavatory Faucet-Left	10	Copper	ppb		
10W-2 Women's Restroom West - Lavatory Faucet-Left	10	E.Coli	--		
10W-2 Women's Restroom West - Lavatory Faucet-Left	10	Lead	ppb		
10W-2 Women's Restroom West - Lavatory Faucet-Left	10	Total Coliform	--		
10W-2 Women's Restroom West - Lavatory Faucet-Center	10	Legionella Culture	CFU/mL	ND	ND
10W-2 Women's Restroom West - Lavatory Faucet-Center	10	Copper	ppb	360	230
10W-2 Women's Restroom West - Lavatory Faucet-Center	10	E.Coli	--	Absent	Absent
10W-2 Women's Restroom West - Lavatory Faucet-Center	10	Lead	ppb	0	0
10W-2 Women's Restroom West - Lavatory Faucet-Center	10	Total Coliform	--	Absent	Absent
10W-2 Women's Restroom West - Lavatory Faucet-Right	10	Legionella Culture	CFU/mL		

10W-2 Women's Restroom West - Lavatory Faucet-Right	10	Copper	ppb		
10W-2 Women's Restroom West - Lavatory Faucet-Right	10	E.Coli	--		
10W-2 Women's Restroom West - Lavatory Faucet-Right	10	Lead	ppb		
10W-2 Women's Restroom West - Lavatory Faucet-Right	10	Total Coliform	--		
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL		
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Copper	ppb		
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	E.Coli	--		
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Lead	ppb		
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Total Coliform	--		
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Legionella Culture	CFU/mL	ND	ND
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Copper	ppb	400	310
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	E.Coli	--	Absent	Absent
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Lead	ppb	0	0
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Total Coliform	--	Absent	Absent
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL		
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Copper	ppb		
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	E.Coli	--		
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Lead	ppb		
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Total Coliform	--		
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Legionella Culture	CFU/mL	ND	ND
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Copper	ppb	500	350
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	E.Coli	--	Absent	Absent
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Lead	ppb	0	0
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Total Coliform	--	Absent	Absent
10W-1 Women's Restroom East - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL		
10W-1 Women's Restroom East - Lavatory Faucet-Left	10	Copper	ppb		
10W-1 Women's Restroom East - Lavatory Faucet-Left	10	E.Coli	--		
10W-1 Women's Restroom East - Lavatory Faucet-Left	10	Lead	ppb		
10W-1 Women's Restroom East - Lavatory Faucet-Left	10	Total Coliform	--		
10W-1 Women's Restroom East - Lavatory Faucet-Center	10	Legionella Culture	CFU/mL		
10W-1 Women's Restroom East - Lavatory Faucet-Center	10	Copper	ppb		

10W-1 Women's Restroom East - Lavatory Faucet-Center	10	E.Coli	--		
10W-1 Women's Restroom East - Lavatory Faucet-Center	10	Lead	ppb		
10W-1 Women's Restroom East - Lavatory Faucet-Center	10	Total Coliform	--		
10W-1 Women's Restroom East - Lavatory Faucet-Right	10	Legionella Culture	CFU/mL	ND	ND
10W-1 Women's Restroom East - Lavatory Faucet-Right	10	Copper	ppb	420	280
10W-1 Women's Restroom East - Lavatory Faucet-Right	10	E.Coli	--	Absent	Absent
10W-1 Women's Restroom East - Lavatory Faucet-Right	10	Lead	ppb	0	0
10W-1 Women's Restroom East - Lavatory Faucet-Right	10	Total Coliform	--	Absent	Absent
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	Legionella Culture	CFU/mL	ND	ND
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	Copper	ppb	760	640
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	E.Coli	--	Absent	Absent
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	Lead	ppb	0	0
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	Total Coliform	--	Absent	Absent
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Legionella Culture	CFU/mL	ND	ND
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Copper	ppb	530	710
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	E.Coli	--	Absent	Absent
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Lead	ppb	0	0
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Total Coliform	--	Absent	Absent
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Legionella Culture	CFU/mL	ND	ND
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Copper	ppb	560	450
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	E.Coli	--	Absent	Absent
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Lead	ppb	1	0
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Total Coliform	--	Absent	Absent
EC Roof -Cooling Tower	EC Roof	Legionella Culture	CFU/mL		
EC Roof -Cooling Tower	EC Roof	E.Coli	--		
EC Roof -Cooling Tower	EC Roof	Total Coliform	--		
EC Roof -Cooling Tower	EC Roof	Copper	ppb		
EC Roof -Cooling Tower	EC Roof	Lead	ppb		
Water Cooler 108 Left	1	Legionella Culture	CFU/mL		ND
Water Cooler 108 Left	1	Copper	ppb		0
Water Cooler 108 Left	1	E.Coli	--		Absent

Water Cooler 108 Left	1	Lead	ppb		0
Water Cooler 108 Left	1	Total Coliform	--		Absent
Water Cooler 108 Right	1	Legionella Culture	CFU/mL		ND
Water Cooler 108 Right	1	Copper	ppb		0
Water Cooler 108 Right	1	E.Coli	--		Absent
Water Cooler 108 Right	1	Lead	ppb		0
Water Cooler 108 Right	1	Total Coliform	--		Absent
Water Cooler #3	1	Legionella Culture	CFU/mL		
Water Cooler #3	1	Copper	ppb		0
Water Cooler #3	1	E.Coli	--		Absent
Water Cooler #3	1	Lead	ppb		0
Water Cooler #3	1	Total Coliform	--		Absent
Water Cooler Loading Dock	1	Legionella Culture	CFU/mL		ND
Water Cooler Loading Dock	1	Copper	ppb		0
Water Cooler Loading Dock	1	E.Coli	--		Absent
Water Cooler Loading Dock	1	Lead	ppb		0
Water Cooler Loading Dock	1	Total Coliform	--		Absent
Water Cooler Housekeeping	1	Legionella Culture	CFU/mL		
Water Cooler Housekeeping	1	Copper	ppb		
Water Cooler Housekeeping	1	E.Coli	--		
Water Cooler Housekeeping	1	Lead	ppb		
Water Cooler Housekeeping	1	Total Coliform	--		