



July 18, 2022

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, MO 64108

Re: Goodfellow Federal Center – Bldg. 105 Air Sampling
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced building located at the Goodfellow Federal Complex, in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide sampling data regarding existing conditions to supplement previous investigation reports prepared for the facility. The following report summarizes air-sample collection activities and the laboratory analytical results of the samples submitted.

METHODOLOGY

On June 8 and 9, 2022, Ashley Anstaett & Jeff Smith of Burns & McDonnell and OCCU-TEC conducted area air-sampling for the presence of seven (7) of the RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver. Sampling was conducted in various locations throughout Building 105.

The sampling plan, number of samples, sample distribution, and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by sampling personnel while on-site.

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer (μm) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration. Air samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals according to NIOSH method 7300. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.

Diane Czarnecki
 Facilities Management Division
 July 18, 2022
 Page 2

RESULTS AND DISCUSSION

Results of the air sampling are summarized in the table below by identifying the range of results for Building 105 for each of the seven (7) metals that were sampled. Results indicate that all 27 air samples collected from Building 105 and analyzed for RCRA metals were below their respective OSHA Permissible Exposure Limit (PEL), as based on a time-weighted-average.

Table 1. Summary of Air Sampling Results

Analyte	Lowest Concentration ^(a) (µg/m ³) ^(b)	Highest Concentration ^(a) (µg/m ³) ^(b)	Permissible Exposure Limit (PEL) (µg/m ³) ^(b)
Arsenic	<0.26	<0.29	10
Barium	<0.26	<0.29	500
Cadmium	<0.051	<0.057	5
Chromium (Total)	<1.3	<1.5	500
Lead	<0.26	<0.29	1
Selenium	<1.3	<1.5	200
Silver	<0.26	<0.29	10

Notes:

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit, which varies based on sample air volume.
- (b) µg/m³ = micrograms per cubic meter of air.

GSA may choose to compare results with guidance limits from additional organizations for risk evaluation, including but not limited to the American Conference of Governmental Industrial Hygienists (ACGIH) and/or the World Health Organization (WHO).

A summary table of all sampling results by location is included in Appendix A. The complete laboratory report for the air sampling from EHS is attached in Appendix B.

LIMITATIONS

The scope of this assessment was limited as follows. Burns & McDonnell collected samples from a select number of locations in an effort to minimize cost while providing a general overview of the air quality at the site. Sample locations do not encompass every indoor space at the site. Additionally, based on previous sampling history, samples were only analyzed for a select number of potential contaminants likely to affect the air quality at the site. Burns &



Diane Czarnecki
Facilities Management Division
July 18, 2022
Page 3

McDonnell is not responsible for potential contaminants not identified in this report. This report was prepared for the sole use of GSA.

Burns & McDonnell appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A large black rectangular redaction box covers the signature area, with the text '(b) (6)' in red at the top left corner.

Matt Shanahan, CHMM
Project Manager

Attachments:

- Appendix A – Results Summary by Location
- Appendix B – Air Sample Laboratory Report

Information in Appendices A and B is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or r6environmental@gsa.gov.

APPENDIX A – RESULTS SUMMARY BY LOCATION

Appendix A
Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
105-A-01	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead ²	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--
105-A-02	2nd floor, north lobby hallway windowsill	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-03	2nd floor, railing by restroom	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.27	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
105-A-04	2nd floor, breakroom table, at column J10	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-05	2nd floor, desk at column H17	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10

Appendix A
Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
105-A-06	2nd floor, small table at column G27	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-07	2nd floor, desk at column F32	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.27	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
105-A-08	2nd floor, break room, table at column B29	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead ²	< 0.29	µg/m ³	1
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10
105-A-09	2nd floor, east hall, women's restroom, column B42	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-10	2nd floor, lab room 319, west wall table	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.053	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.27	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10

Appendix A
Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
105-A-11	2nd floor, railing across from elevator near room 350	Arsenic	< 0.26	µg/m ³	10
		Barium	< 0.26	µg/m ³	500
		Cadmium	< 0.051	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead ²	< 0.26	µg/m ³	1
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.26	µg/m ³	10
105-A-12	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead ²	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--
105-A-13	2nd floor, lab room 361, top of coat rack	Arsenic	< 0.28	µg	10
		Barium	< 0.28	µg	500
		Cadmium	< 0.055	µg	5
		Chromium	< 1.4	µg	500
		Lead ²	< 0.28	µg	1
		Selenium	< 1.4	µg	200
		Silver	< 0.28	µg	10
105-A-14	2nd floor, lab break room, top of microwave	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-15	2nd floor, lab room 324, table by door	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.27	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10

Appendix A
Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
105-A-16	2nd floor, conference room 331, tall table	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.053	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.27	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
105-A-17	2nd floor, admin room 342, top of filling cabinet	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-18	1st floor, south lobby, top of radiator	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-19	1st floor, north lobby, table on the north wall	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-20	1st floor, break room table at column F13	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.27	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10

Appendix A
Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
105-A-21	1st floor, supply station at column F16	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-22	1st floor, supply station, column D21	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead ²	< 0.29	µg/m ³	1
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10
105-A-23	1st floor, waiting area at column at J35	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-24	1st floor, lab processing at column B50	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-25	1st floor, warehouse at column E46	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead ²	< 0.29	µg/m ³	1
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10

Appendix A
Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
105-A-26	1st floor, storage room at column F49	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead ²	< 0.28	µg/m ³	1
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
105-A-27	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead ²	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--

Notes:

¹Limits equal to the Occupational Safety and Health Administration (OSHA) Permissible Exposure Limits (PELs)

²Limits equal to the World Health organization (WHO) Ambient Air Limit

APPENDIX B – AIR SAMPLE LABORATORY REPORT



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Air Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 22-06-03522
 Received Date: 06/17/2022
 Reported Date: 06/27/2022

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Client Number:
26-3514

Fax Number:
816-822-3494

Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
22-06-03522-001	105-A-01	06/25/2022	Arsenic (As)	0	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
22-06-03522-002	105-A-02	06/25/2022	Arsenic (As)	551	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-003	105-A-03	06/25/2022	Arsenic (As)	562	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03522

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
22-06-03522-004	105-A-04	06/25/2022	Arsenic (As)	543	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-005	105-A-05	06/25/2022	Arsenic (As)	543	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-006	105-A-06	06/25/2022	Arsenic (As)	541	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03522

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
22-06-03522-007	105-A-07	06/25/2022	Arsenic (As)	562	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
22-06-03522-008	105-A-08	06/25/2022	Arsenic (As)	528	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
22-06-03522-009	105-A-09	06/25/2022	Arsenic (As)	554	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-010	105-A-10	06/25/2022	Arsenic (As)	575	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03522

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
22-06-03522-011	105-A-11	06/25/2022	Arsenic (As)	596	<0.15	<0.26	
			Barium (Ba)		<0.15	<0.26	
			Cadmium (Cd)		<0.030	<0.051	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.26	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.26	
22-06-03522-012	105-A-12	06/25/2022	Arsenic (As)	0	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
22-06-03522-013	105-A-13	06/25/2022	Arsenic (As)	551	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-014	105-A-14	06/25/2022	Arsenic (As)	553	<0.15	<0.28	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03522

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-015	105-A-15	06/25/2022	Arsenic (As)	562	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
22-06-03522-016	105-A-16	06/25/2022	Arsenic (As)	570	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
22-06-03522-017	105-A-17	06/25/2022	Arsenic (As)	538	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03522

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-018	105-A-18	06/25/2022	Arsenic (As)	553	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-019	105-A-19	06/25/2022	Arsenic (As)	551	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-020	105-A-20	06/25/2022	Arsenic (As)	562	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
22-06-03522-021	105-A-21	06/25/2022	Arsenic (As)	554	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03522

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-022	105-A-22	06/25/2022	Arsenic (As)	533	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
22-06-03522-023	105-A-23	06/25/2022	Arsenic (As)	551	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-024	105-A-24	06/25/2022	Arsenic (As)	549	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03522

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Silver (Ag)		<0.15	<0.28	
22-06-03522-025	105-A-25	06/25/2022	Arsenic (As)	528	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
22-06-03522-026	105-A-26	06/25/2022	Arsenic (As)	549	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
22-06-03522-027	105-A-27	06/25/2022	Arsenic (As)	0	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03522

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	------------------------------------	--------------

Sample Narratives:

Method: NIOSH 7300M
Analyst: Carlos Gonzalez

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

LEGEND ug = microgram ug/m³ = micrograms per cubic meter
 mL = milliliter L = Liters

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Pg 1 of 2

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	eapulcher@burnsmcd.com
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd	
PO Number	168765	Collected By	A. Anstaeff + Ji Smith
Turn-Around Time	<input checked="" type="checkbox"/> 5 DAY <input type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS							Other Metals	PARTICULATES					AIR			WIPES <small>Circle The Unit of Measurement Used cm or in</small>
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP	CA 17 Total		Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM ₁₀	Total Time	Flow Rate	Vol.	
																Mins.	L/min.	Total Liters	
1	105-A-01	6/8/22 0945							Ag, As, Ba, Cd, Cr, Pb, Se						NA		NA	x	
2	105-A-02	1103 0221												212		551	x		
3	105-A-03	1104												212		562	x		
4	105-A-04	1106												213		513	x		
5	105-A-05	1107												213		513	x		
6	105-A-06	1108												212		541	x		
7	105-A-07	1110												212		562	x		
8	105-A-08	1111												211		528	x		
9	105-A-09	1113												209		554	x		
10	105-A-10	1504												217		575	x		
11	105-A-11	1505												217		596	x		
12	105-A-12	1121												NA		NA	x		
13	105-A-13	1506												216		551	x		
14	105-A-14	1509												217		553	x		
15	105-A-15	1510												216		562	x		

Released By:	A. Anstaeff	Date:	6/9/2022	Time:	
Signature:	(b) (6)				

LAB USE ONLY - BELOW THIS LINE

Received By: Thelma

Signature: (b) (6)

Date: 6/17/22 Time: 13p : AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010
 RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

22-06-03522

Due Date:
06/24/2022
(Friday)
EL MM-L

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Pg. 2 of 2

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	eapuicher@burnsmcd.com
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd	
PO Number	168765	Collected By	A. Anstett + J. Smith
Turn-Around Time	<input checked="" type="checkbox"/> 5 DAY <input type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES				AIR			WIPES AREA Circle The Unit of Measurement Used cm or in		
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA.17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time		Flow Rate	Vol.
																Mins.		L/min.	Total Liters
1	105-A-16	10/8/22 1511							Ag, As, Ba, Cd, Cr, Pb, Se						215		540	X	
2	105-A-17	10/8/22 1512												215		538	X		
3	105-A-18	1513												213		563	X		
4	105-A-19	10/9/22 1132												212		551	X		
5	105-A-20	1135												212		562	X		
6	105-A-21	1137												213		554	X		
7	105-A-22	1138												213		533	X		
8	105-A-23	1140												212		551	X		
9	105-A-24	1143												211		549	X		
10	105-A-25	1144												211		528	X		
11	105-A-26	1145												211		549	X		
12	105-A-27	0723												NA		NA	X		
13																	X		
14																	X		
15																	X		

Released By:	A. Anstett	Date:	10/9/22	Time:	1100
Signature:	(b) (6)				

LAB USE ONLY - BELOW THIS LINE

Received By: T. [Signature]

Signature: (b) (6)

Date: 6/17/22 Time: 13: AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

3522

Laboratories™

Attach Laboratory Label Here