



January 20, 2021

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, MO 64108

Re: Goodfellow Federal Center – Bldg. 105F Air Sampling
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced building located at the Goodfellow Federal Complex, in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide sampling data regarding existing conditions to supplement previous investigation reports prepared for the facility. The following report summarizes air-sample collection activities and the laboratory analytical results of the samples submitted.

METHODOLOGY

On December 10, 2020, Emily Ahlemeyer of Burns & McDonnell and Eric Wenger of Burns & McDonnell conducted area air-sampling for the presence of seven (7) of the RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver. Sampling was conducted in various locations throughout Building 105F.

The sampling scheme, number of samples, sample distribution, and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by sampling personnel while on-site.

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer (μm) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration. Air samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals according to NIOSH method 7300. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.

Diane Czarnecki
 Facilities Management Division
 January 20, 2021
 Page 2

RESULTS AND DISCUSSION

Results of the air sampling are summarized in the table below by identifying the range of results for Building 105F for each of the seven (7) metals that were sampled. Results indicate that all 9 air samples collected from Building 105F and analyzed for RCRA metals were below their respective OSHA Permissible Exposure Limit (PEL), as based on a time-weighted-average.

Table 1. Summary of Air Sampling Results

Analyte	Lowest Concentration ^(a) ($\mu\text{g}/\text{m}^3$) ^(b)	Highest Concentration ^(a) ($\mu\text{g}/\text{m}^3$) ^(b)	Permissible Exposure Limit (PEL) ($\mu\text{g}/\text{m}^3$) ^(b)
Arsenic	<0.25	<0.27	10
Barium	<0.25	<0.27	500
Cadmium	<0.050	<0.053	5
Chromium (Total)	<1.3	<1.4	500
Lead	<0.25	<0.27	50
Selenium	<1.3	<1.4	200
Silver	<0.25	<0.27	10

Notes:

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit, which varies based on sample air volume.
- (b) $\mu\text{g}/\text{m}^3$ = micrograms per cubic meter of air.

GSA may choose to compare results with guidance limits from additional organizations for risk evaluation, including but not limited to the American Conference of Governmental Industrial Hygienists (ACGIH) and/or the World Health Organization (WHO).

A summary table of all sampling results by location is included in Appendix A. The complete laboratory report for the air sampling from EHS is attached in Appendix B. The air sampling professional’s Missouri Lead license is included in Appendix C.

LIMITATIONS

The scope of this assessment was limited as follows. Burns & McDonnell collected samples from a select number of locations in an effort to minimize cost while providing a general overview of the air quality at the site. Sample locations do not encompass every indoor space at the site. Additionally, based on previous sampling history, samples were only analyzed for a select number of potential contaminants likely to affect the air quality at the site. Burns &



Diane Czarnecki
Facilities Management Division
January 20, 2021
Page 3

McDonnell is not responsible for potential contaminants not identified in this report. This report was prepared for the sole use of GSA.

Burns & McDonnell appreciates the opportunity to work with the General Services Administration on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A large black rectangular redaction box covers the signature area, with the text "(b) (6)" printed in white at the top left corner of the box.

Matt Shanahan, CHMM
Project Manager

Attachments:

- Appendix A – Results Summary by Location
- Appendix B – Air Sample Laboratory Report
- Appendix C – Licenses

Information in Appendices B and C is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or r6environmental@gsa.gov.

APPENDIX A – RESULTS SUMMARY BY LOCATION

Appendix A

Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
105F-A-01	1st floor, north stairwell/lobby	Arsenic	< 0.25	µg/m ³	10
		Barium	< 0.25	µg/m ³	500
		Cadmium	< 0.050	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead	< 0.25	µg/m ³	50
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.25	µg/m ³	10
105F-A-02	1st floor, office area near door	Arsenic	< 0.25	µg/m ³	10
		Barium	< 0.25	µg/m ³	500
		Cadmium	< 0.050	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead	< 0.25	µg/m ³	50
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.25	µg/m ³	10
105F-A-03	1st floor, outside snack shop	Arsenic	< 0.26	µg/m ³	10
		Barium	< 0.26	µg/m ³	500
		Cadmium	< 0.051	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead	< 0.26	µg/m ³	50
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.26	µg/m ³	10
105F-A-04	Basement	Arsenic	< 0.25	µg/m ³	10
		Barium	< 0.25	µg/m ³	500
		Cadmium	< 0.050	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead	< 0.25	µg/m ³	50
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.25	µg/m ³	10
105F-A-05	2nd floor, southeast end of office area	Arsenic	< 0.26	µg/m ³	10
		Barium	< 0.26	µg/m ³	500
		Cadmium	< 0.051	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead	< 0.26	µg/m ³	50
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.26	µg/m ³	10

Appendix A

Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
105F-A-06	2nd floor, northeast office	Arsenic	< 0.25	µg/m ³	10
		Barium	< 0.25	µg/m ³	500
		Cadmium	< 0.050	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead	< 0.25	µg/m ³	50
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.25	µg/m ³	10
105F-A-07	2nd floor, mechanical room, column L33	Arsenic	< 0.25	µg/m ³	10
		Barium	< 0.25	µg/m ³	500
		Cadmium	< 0.050	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead	< 0.25	µg/m ³	50
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.25	µg/m ³	10
105F-A-08	South penthouse	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.053	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.27	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
105F-A-09	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--

Notes:

¹Limits equal to the Occupational Safety and Health Administration (OSHA) Permissible Exposure Limits (PELs)

APPENDIX B – AIR SAMPLE LABORATORY REPORT



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Air Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 20-12-01802
 Received Date: 12/14/2020
 Reported Date: 12/17/2020

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 105F-A-01-09

Client Number:
26-3514

Fax Number:
816-822-3494

Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
20-12-01802-001	105F-A-01	12/16/2020	Arsenic (As)	602	<0.15	<0.25	
			Barium (Ba)		<0.15	<0.25	
			Cadmium (Cd)		<0.030	<0.050	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.25	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.25	
20-12-01802-002	105F-A-02	12/16/2020	Arsenic (As)	605	<0.15	<0.25	
			Barium (Ba)		<0.15	<0.25	
			Cadmium (Cd)		<0.030	<0.050	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.25	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.25	
20-12-01802-003	105F-A-03	12/16/2020	Arsenic (As)	597	<0.15	<0.26	
			Barium (Ba)		<0.15	<0.26	
			Cadmium (Cd)		<0.030	<0.051	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01802

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 105F-A-01-09

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.26	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.26	
20-12-01802-004	105F-A-04	12/16/2020	Arsenic (As)	601	<0.15	<0.25	
			Barium (Ba)		<0.15	<0.25	
			Cadmium (Cd)		<0.030	<0.050	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.25	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.25	
20-12-01802-005	105F-A-05	12/16/2020	Arsenic (As)	595	<0.15	<0.26	
			Barium (Ba)		<0.15	<0.26	
			Cadmium (Cd)		<0.030	<0.051	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.26	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.26	
20-12-01802-006	105F-A-06	12/16/2020	Arsenic (As)	604	<0.15	<0.25	
			Barium (Ba)		<0.15	<0.25	
			Cadmium (Cd)		<0.030	<0.050	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.25	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.25	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01802

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 105F-A-01-09

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
20-12-01802-007	105F-A-07	12/16/2020	Arsenic (As)	609	<0.15	<0.25	
			Barium (Ba)		<0.15	<0.25	
			Cadmium (Cd)		<0.030	<0.050	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.25	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.25	
20-12-01802-008	105F-A-08	12/16/2020	Arsenic (As)	567	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01802-009	105F-A-09	12/16/2020	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01802

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 105F-A-01-09

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	------------------------------------	--------------

Sample Narratives:

Method: NIOSH 7300M
Analyst: Brittany Meyer

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

LEGEND	ug = microgram	ug/m ³ = micrograms per cubic meter
	mL = milliliter	L= Liters

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4601	Email	eaahlemeyer@burnsmcd.com
Project Name / Testing Address	GFC/4300 Goodfellow Blvd		
PO Number	168765	Collected By	Emily Ahlemeyer & Eric Wenger
Turn-Around Time	<input checked="" type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS							Other Metals	PARTICULATES					AIR			WIPES AREA Circle The Unit of Measurement Used cm or in
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP	CA 17 Total		Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate	Vol.	
																Mins.	L/min.	Total Liters	
1	105F-A-01	12/10/2020 0826							Ag, As, Ba, Cd, Cr, Pb, Se						238	2.53	602	X	
2	105F-A-02	0827													238	2.54	605	X	
3	105F-A-03	0829													236	2.53	597	X	
4	105F-A-04	0832													237	2.54	601	X	
5	105F-A-05	0838													236	2.52	595	X	
6	105F-A-06	0839													236	2.56	604	X	
7	105F-A-07	0843													233	2.62	609	X	
8	105F-A-08	0847													230	2.47	567	X	
9	105F-A-09	1010													NA	NA	NA	X	
10																		X	
11																		X	
12																		X	
13																		X	
14																		X	
15																		X	

Released By: Emily Ahlemeyer	Date: 12/11/2020	Time: 1600
Signature: (b) (6)		

LAB USE ONLY - BELOW THIS LINE

Received By: TStone

Signature: (b) (6)

Date: 12/14/20 Time: 12:33 AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010
 RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

20-12-01802

Due Date:
12/17/2020
(Thursday)
EL

APPENDIX C – LICENSES



**Missouri Department of Health
and Senior Services**

(b) (6)

Lead Occupation License - ID Badge
License Number: 080311-300001861

Lead Risk Assessor

**Eric
Wenger**

Expiration Date: 03/11/2022

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Eric N. Wenger

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **3/11/2020**
Expiration Date: **3/11/2022**
License Number: **080311-300001861**

(b) (6)



Randall W. Williams, MD, FACOG
Director
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102