



July 12, 2023

Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center  
Metals in Settled Dust Sampling – Building 110  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 110 located at the Goodfellow Federal Center (GFC) in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

## **INTRODUCTION**

Per historical use and previous characterization, Burns & McDonnell was contracted to perform settled dust sampling for the analysis of seven (7) of the Resource Conservation and Recovery Act (RCRA) target metals (arsenic, barium, cadmium, chromium, lead, selenium, and silver) from various surfaces within buildings. The purpose of this testing was to further characterize the presence and concentration of target metals in common tenant-occupied areas of the building.

The proposed sampling scheme, the number of samples, the sample distribution and general methodology was developed by GSA and Burns & McDonnell. Specific sample locations were determined by sampling personnel while on-site.

Settled dust wipe sampling at Bldg. 110 was conducted on June 5, 2023 by Eric Wenger & Jeff Smith of Burns & McDonnell and OCCU-TEC.

## **METALS IN SETTLED DUST SAMPLING**

Metals in settled dust sampling was conducted primarily within tenant-occupied areas. Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination* and ASTM Standard D6966: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Determination of Metals*. ASTM Standards E1728 and D6966 are consistent with the methodology described in the Housing and

Diane Czarnecki  
Facilities Management Division  
July 12, 2023  
Page 2

Urban Development Guidelines-Appendix 13.1 and 40 CFR 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed by building occupants. A representative surface area of approximately one square foot (1 SF) was measured and delineated with plastic templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth "S" pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container. Dust wipe samples were submitted to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for Inductively Coupled Plasma (ICP) analysis of metals analysis using Environmental Protection Agency (EPA) method SW846 3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Laboratory Accreditation Program (LAP) identification number LAP-100420.

Whereas the Occupational Safety and Health Administration (OSHA) has not established regulatory limits for surface concentrations of metals, the OSHA Technical Manual Section II: Chapter 2 (III.A) describes a method for calculating "housekeeping" standards, as recommended acceptable surface limits. Brookhaven's IH75190 procedure uses the housekeeping standards to derive a lower, "clean area limit" for non-operational areas that can be accessed or contacted without special training or precautions. Burns & McDonnell calculated clean area limits for metals not included in the Brookhaven procedure, specifically barium, chromium (total), selenium and silver. Wipe results were compared to the Brookhaven procedure's clean area limits for each metal.

Results of the dust wipe samples collected from the building indicate that 7 of the 9 samples contained concentrations of target metals above laboratory reporting limits. The following table identifies the range of results for each of the seven metals that were analyzed. Samples with a "<" sign indicate that the results were below the lab's reportable limit.

Diane Czarnecki  
 Facilities Management Division  
 July 12, 2023  
 Page 3

**Table 1. Summary of Dust Wipe Results**

Analyte	Lowest Concentration <sup>(a)</sup> (µg/sq. ft) <sup>(b)</sup>	Highest Concentration <sup>(a)</sup> (µg/sq. ft) <sup>(b)</sup>	Clean Area Limit <sup>(c)</sup> µg/sq. ft <sup>(b)</sup>
Silver	<0.5	35.0	62
Arsenic	<2.5	<2.5	62
Barium	<0.5	130.0	3,094
Cadmium	<0.1	13.0	31
Chromium (Total)	<1.0	430.0	3,094
Lead	<0.5	73.0	10 <sup>(d)</sup>
Selenium	<2.5	<2.5	1,236

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit.
- (b) µg/sq. ft = micrograms per square foot of surface area.
- (c) Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [(PEL (µg/m<sup>3</sup>) x 10 m<sup>3</sup>/100cm<sup>2</sup>) x 929cm<sup>2</sup>/sq.ft.] / 15.
- (d) Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

Of the 7 samples that had detectable levels of one or more analytes, 2 of them exceeded the clean area limit.

1. A sample taken from the top of a wooden toolbox in the warehouse had 73 µg/ft<sup>2</sup> of lead.
2. A sample taken from the floor outside the break room in the warehouse had 37 µg/ft<sup>2</sup> of lead.

Burns & McDonnell appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

Matt Shanahan, CHMM  
 Project Manager

Attachments:  
 Appendix A – Sample Summary Table  
 Appendix B – Laboratory Analysis Report



Diane Czarnecki  
Facilities Management Division  
July 12, 2023  
Page 4

Information in Appendices A and B is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or [r6environmental@gsa.gov](mailto:r6environmental@gsa.gov).

**APPENDIX A – SAMPLE SUMMARY TABLE**

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-01	Maintenance office, conference room	Mid shelf in southeast corner	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	1.9	µg/ft <sup>2</sup>	3,094
			Cadmium	0.18	µg/ft <sup>2</sup>	31
			Chromium	3.3	µg/ft <sup>2</sup>	3,094
			Lead	1.3	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-02	Maintenance office, break room	Countertop by microwave	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	0.70	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-03	Maintenance office, lunch room	Floor near northeast door	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	5.0	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	1.2	µg/ft <sup>2</sup>	3,094
			Lead	7.6	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-04	Maintenance office	Floor near northwest door	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	3.3	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	4.1	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62

**Appendix A**  
**Sample Summary Table**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-05	Maintenance office	Desk top on east side	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	1.4	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	2.9	µg/ft <sup>2</sup>	3,094
			Lead	1.5	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-06	Maintenance office	Desk top on south side	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	< 0.50	µg/ft <sup>2</sup>	3,094
			Cadmium	< 0.10	µg/ft <sup>2</sup>	31
			Chromium	< 1.0	µg/ft <sup>2</sup>	3,094
			Lead	< 0.50	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	< 0.50	µg/ft <sup>2</sup>	62
110-W-07	Warehouse	Top of wooden toolbox	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	130	µg/ft <sup>2</sup>	3,094
			Cadmium	13	µg/ft <sup>2</sup>	31
			Chromium	430	µg/ft <sup>2</sup>	3,094
			Lead	73	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	2.2	µg/ft <sup>2</sup>	62
110-W-08	Warehouse	Floor outside break room	Arsenic	< 2.5	µg/ft <sup>2</sup>	62
			Barium	29	µg/ft <sup>2</sup>	3,094
			Cadmium	0.54	µg/ft <sup>2</sup>	31
			Chromium	13	µg/ft <sup>2</sup>	3,094
			Lead	37	µg/ft <sup>2</sup>	10
			Selenium	< 2.5	µg/ft <sup>2</sup>	1,236
			Silver	35	µg/ft <sup>2</sup>	62

## Appendix A

### Sample Summary Table

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
110-W-09	Field blank	--	Arsenic	< 2.50	µg	--
			Barium	< 0.500	µg	--
			Cadmium	< 0.100	µg	--
			Chromium	< 1.00	µg	--
			Lead	< 0.500	µg	--
			Selenium	< 2.50	µg	--
			Silver	< 0.500	µg	--

\* Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit  $[[PEL (\mu\text{g}/\text{m}^3) \times 10 \text{ m}^3/100\text{cm}^2] \times 929\text{cm}^2/\text{sq. ft.}] / 15$ . Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

\*\* Indicates results at or above the Clean Area Limit



**APPENDIX B – LABORATORY ANALYSIS REPORT**



Environmental Hazards Services, L.L.C.  
 7469 Whitepine Rd  
 Richmond, VA 23237  
 Telephone: 800.347.4010

## Wipe Metals Analysis Report

**Client:** Burns & McDonnell Engineering  
 9400 Ward Pkwy.  
 Kansas City, MO 64114

**Report Number:** 23-06-01515

**Received Date:** 06/09/2023

**Analyzed Date:** 06/11/2023

**Reported Date:** 06/13/2023

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.; Bldg 110

**Client Number:**  
 26-3514

# Laboratory Results

**Fax Number:**  
 816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
23-06-01515-001	110-W-01	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.88	1.9	L01
		Cadmium (Cd)	1.00	0.180	0.18	L01
		Chromium (Cr)	1.00	3.28	3.3	L01
		Lead (Pb)	1.00	1.32	1.3	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
23-06-01515-002	110-W-02	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.695	0.70	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 23-06-01515

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.; Bldg 110

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
23-06-01515-003	110-W-03	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	5.00	5.0	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	1.15	1.2	L01
		Lead (Pb)	1.00	7.56	7.6	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
23-06-01515-004	110-W-04	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	3.32	3.3	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	4.08	4.1	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
23-06-01515-005	110-W-05	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.44	1.4	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 23-06-01515

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.; Bldg 110

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	2.90	2.9	L01
		Lead (Pb)	1.00	1.48	1.5	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
23-06-01515-006	110-W-06	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	<0.500	<0.50	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
23-06-01515-007	110-W-07	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	129	130	L01
		Cadmium (Cd)	1.00	12.5	13	L01
		Chromium (Cr)	1.00	431	430	L01
		Lead (Pb)	1.00	73.5	73	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	2.16	2.2	L01

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 23-06-01515

**Project/Test Address:** 168765; GFC; 4300 Goodfellow Blvd.; Bldg 110

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
23-06-01515-008	110-W-08	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	29.3	29	L01
		Cadmium (Cd)	1.00	0.535	0.54	L01
		Chromium (Cr)	1.00	12.6	13	L01
		Lead (Pb)	1.00	37.2	37	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	34.6	35	L01
23-06-01515-009	110-W-09	Arsenic (As)		<2.50	<2.5	L01
		Barium (Ba)		<0.500	<0.50	L01
		Cadmium (Cd)		<0.100	<0.10	L01
		Chromium (Cr)		<1.00	<1.0	L01
		Lead (Pb)		<0.500	<0.50	L01
		Selenium (Se)		<2.50	<2.5	L01
		Silver (Ag)		<0.500	<0.50	L01

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 23-06-01515

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; Bldg 110


Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
-------------------	----------------------	----------	------------------------------	------------------	-------------------------------------	--------------

Sample Narratives:

L01: LCS and LCSD percent recovery for Se were outside of acceptance limits.

Analyst: Carlos Gonzalez

Method: EPA SW846 3050B/6010D



Reviewed By Authorized Signatory:

Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit based on a 50mL volume. The reporting limit for Lead is 0.5ug.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C.

Legend	ug = microgram	ug/ft <sup>2</sup> = micrograms per square foot
	mL = milliliter	ft <sup>2</sup> = square foot

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Pg 1 of 1

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	alanstaett@burnsmcd.com
Project Name / Testing Address	GFC / 4300 Goodfellow Blvd <i>Bldg. 110</i> <i>epalcher@burnsmcd.com</i>		
PO Number	168765	Collected By	<i>J. Smith + E. Wenger</i>
Turn-Around Time	<input checked="" type="checkbox"/> 5 DAY <input type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES			AIR			WIPES  AREA <small>Circle The Unit of Measurement Used</small> cm or <u>in</u>		
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM <sub>10</sub>		Total Time Mins.	Flow Rate L/min.
1	110-W-01	6/5/23 2:02							Ag, As, Ba, Cd, Cr, Pb, Se									12 x 12
2	110-W-02	2:02																12 x 12
3	110-W-03	2:13																12 x 12
4	110-W-04	2:22																12 x 12
5	110-W-05	2:24																12 x 12
6	110-W-06	2:32																12 x 12
7	110-W-07	2:33																12 x 12
8	110-W-08	2:38																12 x 12
9	110-W-09	2:40																0 x 0
10																		x
11																		x
12																		x
13																		x
14																		x
15																		x

Released By: <i>Eric Wenger</i>	Date: <i>6/8/23</i>	Time: <i>16:58</i>
Signature: <span style="background-color: black; color: red;">(b) (6)</span>		

LAB USE ONLY - BELOW THIS LINE

Received By: *T Stone*

Signature: (b) (6)

Date: *6/9/23* Time: *1:56*  AM  PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

23-06-01515

Due Date:  
**06/16/2023**  
(Friday)  
EL MM-L