

**SUPPLEMENTAL LEASE AGREEMENT
No. 3**

Page 2 of 2

**TO LEASE NO.
GS-04B-48869**

C. Paragraph 6.11 (A)(1) Electrical Distribution shall be amended as follows:

"1. Main power distribution switchboards and distribution and lighting panel boards shall be circuit breaker type with copper buses that are properly rated to provide the calculated fault circuits. All power distribution panel boards shall be supplied with separate equipment ground buses. All power distribution equipment shall be required to handle the actual specified and projected loads plus 8 percent spare load capacity. Distribution panels are required to accommodate circuit breakers for the actual calculated needs plus 8 percent spare circuits that will be equivalent to the majority of other circuit breakers in the panel system. All floors shall have 120/208 V, 3-phase, 4-wire with bond, 60 hertz electric service available."

D. Paragraph 9 of the lease is hereby deleted in its entirety and replaced with the following:

"9. In accordance with the SFO paragraph 3.8 entitled Operating Costs Base, the escalation base is established as \$7.0501/RSF (\$89,790.32 annum)."

Initials:  & 

Lessor

Govt