



February 24, 2022

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, MO 64108

Re: Goodfellow Federal Center –Building 104 Air and Wipe Sampling Evaluation Addendum
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the above referenced environmental sampling activities. The following is our report.

INTRODUCTION

As requested, Burns & McDonnell conducted area air sampling and wipe sampling for the presence of seven (7) RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver within the data center of the second floor of building 104 of the Goodfellow Federal Center located at 4300 Goodfellow Boulevard in St. Louis, Missouri. The purpose of the investigation was to provide ongoing sampling data to monitor conditions at the site. This report serves as an addendum to the *Goodfellow Federal Center – Building 104 Air and Wipe Sampling Evaluation*, dated February 16, 2021.

SAMPLING METHODOLOGY

Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination* and ASTM Standard D6966: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Determination of Metals*. ASTM Standards E1728 and D6966 are consistent with the methodology described in the Housing and Urban Development Guidelines-Appendix 13.1 and 40 CFR 745.63. The Brookhaven National Laboratory’s Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

A representative surface area of approximately one square foot (1 SF) was measured and delineated. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth “S” pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container.



Diane Czarnecki
Facilities Management Division
February 24, 2022
Page 2

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer (μm) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration.

All samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals. Air samples were analyzed by Inductively Coupled Plasma (ICP) according to NIOSH method 7300. Wipe samples were analyzed according to Environmental Protection Agency (EPA) method SW846-3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.

SAMPLE SUMMARY AND RESULTS

Air and wipe sample(s) were collected on January 26, 2022 and February 11, 2022, by Emily Pulcher of Burns & McDonnell.

Two (2) air samples were collected on January 26, 2022. One (1) sample was collected on the 2nd floor data center in storage room 5, on a shelf located at column C15. One (1) sample was collected in server room 4, on top of a box located at column D13. All analytes were below laboratory reporting limits. The complete air sampling laboratory reports from EHS are included as Appendix A.

Four (4) wipe samples were collected on January 26, 2022. The sample locations and results are listed below. The complete wipe sampling laboratory report from EHS is included in Appendix B.

- 2nd floor, data center, storage room 5, 2nd shelf at column C15
 - Arsenic, cadmium, chromium, selenium, and silver were all below laboratory reporting limits
 - Barium was detected at 7.7 micrograms per square foot ($\mu\text{g}/\text{sq. ft}$), below the clean area limit of 3,094 $\mu\text{g}/\text{sq. ft}$
 - Lead was detected at 1.4 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 10 $\mu\text{g}/\text{sq. ft}$

Diane Czarnecki
Facilities Management Division
February 24, 2022
Page 3

- 2nd floor, data center, storage room 5, top of left handrail
 - Arsenic, cadmium, chromium, selenium, and silver were all below laboratory reporting limits
 - Barium was detected at 0.72 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 3,094 $\mu\text{g}/\text{sq. ft}$
 - Lead was detected at 0.81 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 10 $\mu\text{g}/\text{sq. ft}$
- 2nd floor, data center, server room 4, top of desk at column B12
 - Arsenic, cadmium, chromium, selenium, and silver were all below laboratory reporting limits
 - Barium was detected at 3.2 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 3,094 $\mu\text{g}/\text{sq. ft}$
 - Lead was detected at 3.6 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 10 $\mu\text{g}/\text{sq. ft}$
- 2nd floor, data center, entrance lobby office, top of desk by window
 - Arsenic, cadmium, selenium, and silver were all below laboratory reporting limits
 - Barium was detected at 1.6 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 3,094 $\mu\text{g}/\text{sq. ft}$
 - Chromium was detected at 2.2 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 3,094 $\mu\text{g}/\text{sq. ft}$
 - Lead was detected at 0.64 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 10 $\mu\text{g}/\text{sq. ft}$

One (1) air sample was collected on February 11, 2022 from the 2nd floor data center, room 2 on a desk at column B10. All analytes were below laboratory reporting limits. The complete air sampling laboratory reports from EHS are included as Appendix A.

Two (2) wipe samples were collected on February 11, 2022. The sample locations and results are listed below. The complete wipe sampling laboratory report from EHS is included in Appendix B.



Diane Czarnecki
Facilities Management Division
February 24, 2022
Page 4

- 2nd floor, data center, room 2, top of desk at column B10
 - Arsenic, cadmium, chromium, selenium, and silver were all below laboratory reporting limits
 - Barium was detected at 1.6 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 3,094 $\mu\text{g}/\text{sq. ft}$
 - Lead was detected at 2.7 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 10 $\mu\text{g}/\text{sq. ft}$

- 2nd floor, data center, room 2, workstation at column D10
 - Arsenic, cadmium, selenium, and silver were all below laboratory reporting limits
 - Barium was detected at 3.1 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 3,094 $\mu\text{g}/\text{sq. ft}$
 - Chromium was detected at 1.6 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 3,094 $\mu\text{g}/\text{sq. ft}$
 - Lead was detected at 12 $\mu\text{g}/\text{sq. ft}$, exceeding the clean area limit of 10 $\mu\text{g}/\text{sq. ft}$

LIMITATIONS

The scope of this assessment was limited in nature. Burns & McDonnell collected samples from a representative number of surfaces in an effort to minimize cost while providing a general overview of site conditions. Sample locations do not encompass all surfaces at the site. Additionally, samples were only analyzed for a select number of potential contaminants. Burns & McDonnell is not responsible for potential contaminants not identified in this report.

Burns & McDonnell appreciates the opportunity to work GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.



Diane Czarnecki
Facilities Management Division
February 24, 2022
Page 5

Sincerely,

(b) (6)

A large black rectangular redaction box covers the signature area, with the text "(b) (6)" written in red at the top left corner of the box.

Matt Shanahan, CHMM
Project Manager

Attachments:

- Appendix A – Air Sampling Laboratory Reports
- Appendix B – Wipe Sampling Laboratory Reports

Information in Appendices A and B are not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or r6environmental@gsa.gov.

APPENDIX A – AIR SAMPLING LABORATORY REPORTS



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Air Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 22-01-04026
 Received Date: 01/28/2022
 Reported Date: 02/21/2022

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Client Number:
26-3514

Fax Number:
816-822-3494

Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
22-01-04026-001	104-A-01	02/18/2022	Arsenic (As)	668	<0.15	<0.23	
			Barium (Ba)		<0.15	<0.23	
			Cadmium (Cd)		<0.030	<0.045	
			Chromium (Cr)		<0.75	<1.2	
			Lead (Pb)		<0.15	<0.23	
			Selenium (Se)		<0.75	<1.2	
			Silver (Ag)		<0.15	<0.23	
22-01-04026-002	104-A-02	02/18/2022	Arsenic (As)	668	<0.15	<0.23	
			Barium (Ba)		<0.15	<0.23	
			Cadmium (Cd)		<0.030	<0.045	
			Chromium (Cr)		<0.75	<1.2	
			Lead (Pb)		<0.15	<0.23	
			Selenium (Se)		<0.75	<1.2	
			Silver (Ag)		<0.15	<0.23	
22-01-04026-003	104-A-03	02/18/2022	Arsenic (As)	0	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-01-04026

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

Sample Narratives:

Method: NIOSH 7300M
Analyst: Ailea Cabatbat

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

LEGEND ug = microgram ug/m³ = micrograms per cubic meter
 mL = milliliter L = Liters

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Pg. 1 of 1

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	eaahlemeyer@burnsmcd.com
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd	
PO Number	168765	Collected By	Emily Pulcher
Turn-Around Time	<input checked="" type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES AREA <small>Circle The Unit of Measurement Used cm or (in)</small>	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate		Vol.
																Mins.	L/min.		Total Liters
1	104-A-01	1/26/22 0905							Ag, As, Ba, Cd, Cr, Pb, Se						257	2.6	668	x	
2	104-A-02	0907													257	2.6	668	x	
3	104-A-03	0830													NA	NA	NA	x	
4	104-W-01	1315																12 x 12	
5	104-W-02	1317																6 x 24	
6	104-W-03	1326																12 x 12	
7	104-W-04	1333																12 x 12	
8	104-W-05	1333																NA x NA	
9																		x	
10																		x	
11																		x	
12																		x	
13																		x	
14																		x	
15																		x	

Released By: Emily Pulcher	Date: 1/26/22	Time: 1600
Signature: (b) (6)		


LAB USE ONLY – BELOW THIS LINE

Received By: Thoh

Signature: (b) (6)


Date: 1/28/22 Time: 12:15 AM PM


22-01-04026



Due Date:
02/04/2022
(Friday)
EL MM-L

Portal Contact Added

 7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

 RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com



Air Metals Analysis Report

Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Client: Burns & McDonnell Engineering
9400 Ward Pkwy.
Kansas City, MO 64114

Report Number: 22-02-02233
Received Date: 02/14/2022
Reported Date: 02/21/2022

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Client Number:
26-3514

Fax Number:
816-822-3494

Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
22-02-02233-001	104-A-01	02/18/2022	Arsenic (As)	718	<0.15	<0.21	
			Barium (Ba)		<0.15	<0.21	
			Cadmium (Cd)		<0.030	<0.042	
			Chromium (Cr)		<0.75	<1.1	
			Lead (Pb)		<0.15	<0.21	
			Selenium (Se)		<0.75	<1.1	
			Silver (Ag)		<0.15	<0.21	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-02-02233

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	------------------------------------	--------------

Sample Narratives:

Method: NIOSH 7300M
Analyst: Ailea Cabatbat

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

LEGEND ug = microgram ug/m³ = micrograms per cubic meter
 mL = milliliter L= Liters

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Pg 1 of 1

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	eapulcher@burnsmcd.com
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd	
PO Number	168765	Collected By	Emily Pulcher
Turn-Around Time	<input type="radio"/> 5 DAY <input checked="" type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time Mins.	Flow Rate L/min.	Vol. Total Liters
1	104-A-01	2/11/22 0909							Ag, As, Ba, Cd, Cr, Pb, Se						276	2.6	718	x
2									↓ I									x
3																		x
4	104-W-01	2/11/22 0910																12 x 12
5	104-W-02	2/11/22 0913																12 x 12
6	104-W-03	2/11/22 0913																NA x NA
7																		x
8																		x
9																		x
10																		x
11																		x
12																		x
13																		x
14																		x
15																		x

Released By: Emily Pulcher	Date: 2/11/22	Time: 1600
Signature: (b) (6)		

LAB USE ONLY - BELOW THIS LINE

Received By: T Stone

Signature: (b) (6)

Date: 2, 14, 22 Time: 1:35 AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010
 RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

22-02-02233

Due Date:
02/17/2022
 (Thursday)
 EL MM-L

APPENDIX B – WIPE SAMPLING LABORATORY REPORTS



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Wipe Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 22-01-04029

Received Date: 01/28/2022

Analyzed Date: 02/18/2022

Reported Date: 02/21/2022

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Client Number:
 26-3514

Laboratory Results

Fax Number:
 816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
22-01-04029-001	104-W-01	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	7.73	7.7	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	1.42	1.4	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
22-01-04029-002	104-W-02	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	0.720	0.72	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-01-04029

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Lead (Pb)	1.00	0.810	0.81	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
22-01-04029-003	104-W-03	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	3.18	3.2	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	3.62	3.6	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
22-01-04029-004	104-W-04	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.60	1.6	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	2.24	2.2	L01
		Lead (Pb)	1.00	0.635	0.64	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
22-01-04029-005	104-W-05	Arsenic (As)		<2.50	---	L01
		Barium (Ba)		<0.500	---	L01

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-01-04029

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Cadmium (Cd)		<0.100	---	L01
		Chromium (Cr)		<1.00	---	L01
		Lead (Pb)		<0.500	---	L01
		Selenium (Se)		<2.50	---	L01
		Silver (Ag)		<0.500	---	L01

Sample Narratives:

L01: MB for Se exceeded acceptance limit.

Analyst: Ailea Cabatbat

Method: Mercury (Hg): EPA SW846 7471B

All other metals: EPA SW846 3050B/6010D

Reviewed By Authorized Signatory:

(b) (6)

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 50mL volume. The reporting limit for Cadmium is 0.10ug, Barium, Lead and Silver are 0.50ug, Arsenic and Chromium are 1.0ug, and Selenium is 2.5ug.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

Legend	ug = microgram	ug/ft ² = micrograms per square foot
	mL = milliliter	ft ² = square foot

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Pg 1 of 1

Company Name		Burns & McDonnell			Account #		26-3514		
Company Address		9400 Ward Parkway			City/State/Zip		Kansas City, MO 64114		
Phone		314-302-4661			Email		eaahlemeyer@burnsmcd.com		
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd							
PO Number		168765			Collected By		Emily Pulcher		
Turn-Around Time		<input checked="" type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead							

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES AREA <small>Circle The Unit of Measurement Used cm or in</small>	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Furnace Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate		Vol.
																Mins.	L/min.		Total Liters
1	104-A-01	1/26/22 0905							Ag, As, Ba, Cd, Cr, Pb, Se						257	2.6	668	x	
2	104-A-02	0907													257	2.6	668	x	
3	104-A-03	0830													NA	NA	NA	x	
4	104-W-01	1315																12 x 12	
5	104-W-02	1317																6 x 24	
6	104-W-03	1326																12 x 12	
7	104-W-04	1333																12 x 12	
8	104-W-05	1333																NA x NA	
9																		x	
10																		x	
11																		x	
12																		x	
13																		x	
14																		x	
15																		x	

Released By:	Emily Pulcher	Date:	1/26/22	Time:	1600
Signature:	(b) (6)				

LAB USE ONLY - BELOW THIS LINE

Received By: T. Holm

Signature: (b) (6)


Date: 1/28/22 Time: 12:15 AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

22-01-04029



Due Date:
02/04/2022
(Friday)
EL MM-L



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Wipe Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 22-02-02234

Received Date: 02/14/2022

Analyzed Date: 02/19/2022

Reported Date: 02/21/2022

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Client Number:
 26-3514

Laboratory Results

Fax Number:
 816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
22-02-02234-001	104-W-01	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	1.64	1.6	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	2.74	2.7	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
22-02-02234-002	104-W-02	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	3.09	3.1	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	1.62	1.6	L01

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-02-02234

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Lead (Pb)	1.00	12.0	12	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
22-02-02234-003	104-W-03	Arsenic (As)		<2.50	---	L01
		Barium (Ba)		<0.500	---	L01
		Cadmium (Cd)		<0.100	---	L01
		Chromium (Cr)		<1.00	---	L01
		Lead (Pb)		<0.500	---	L01
		Selenium (Se)		<2.50	---	L01
		Silver (Ag)		<0.500	---	L01

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-02-02234

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
-------------------	----------------------	----------	------------------------------	------------------	-------------------------------------	--------------

Sample Narratives:

L01: LCS and LCSD percent recoveries for Se were outside of acceptable control limits.

Analyst: Ailea Cabatbat

Method: Mercury (Hg): EPA SW846 7471B

All other metals: EPA SW846 3050B/6010D

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 50mL volume. The reporting limit for Cadmium is 0.10ug, Barium, Lead and Silver are 0.50ug, Arsenic and Chromium are 1.0ug, and Selenium is 2.5ug.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

Legend	ug = microgram	ug/ft ² = micrograms per square foot
	mL = milliliter	ft ² = square foot

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Company Name		Burns & McDonnell			Account #		26-3514											
Company Address		9400 Ward Parkway			City/State/Zip		Kansas City, MO 64114											
Phone		314-302-4661			Email		eapulcher@burnsmcd.com											
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd																
PO Number		168765			Collected By		Emily Pulcher											
Turn-Around Time		<input type="radio"/> 5 DAY <input checked="" type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead																
LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES			AIR			WIPES AREA Circle The Unit of Measurement Used cm or <input type="checkbox"/> in		
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10		Total Time	Flow Rate
1	104-A-01	2/11/22 0909						Ag, As, Ba, Cd, Cr, Pb, Se						276	2.6	718	x	
2								↓ (Vertical arrow pointing down)									x	
3																		x
4	104-W-01	2/11/22 0910																12 x 12
5	104-W-02	2/11/22 0913																12 x 12
6	104-W-03	2/11/22 0913																NA x NA
7																		x
8																	x	
9																	x	
10																	x	
11																	x	
12																	x	
13																	x	
14																	x	
15																	x	
Released By:		Emily Pulcher			Date:		2/11/22			Time:		1600						
Signature:		(b) (6)																


LAB USE ONLY - BELOW THIS LINE

Received By: T Stone
 Signature: (b) (6)
 Date: 2, 14, 22 Time: 1:35 AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010
 RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

22-02-02234



Due Date:
02/17/2022
(Thursday)
EL MM-L