



June 29, 2018

Ms. Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, Missouri 64108

**RE: Goodfellow Federal Center - Metals in Air Investigation  
Building #106  
4300 Goodfellow Boulevard  
St. Louis, Missouri 63120  
OCCU-TEC Project No. 918004**

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced buildings located at the Goodfellow Federal Complex, in St. Louis, Missouri. OCCU-TEC, Inc. (OCCU-TEC) understands that the purpose of the investigation was to provide sampling data regarding pre-existing conditions noted in investigation reports previously prepared for the facility. The following report summarizes the sample collection activities and the laboratory analytical results of the samples submitted.

On April 26, 2018, Missouri licensed air sampling professionals from OCCU-TEC conducted air sampling for the presence of seven (7) of the RCRA metals including Silver, Arsenic, Barium, Cadmium, Chromium, Lead, and Selenium in Building 106.

The proposed sampling scheme, the numbers of samples, sample distribution and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by OCCU-TEC field personnel while on-site.

***Resource Conservation and Recovery Act Metals Air Sampling***

Air sampling for RCRA metals was collected on 37-millimeter (mm) cassettes with 0.8 micrometer ( $\mu\text{m}$ ) mixed cellulose ester (MCE) filters using powered air sampling pumps in accordance with National Institute for Occupational Safety and Health (NIOSH) sampling methodology. Samples were collected in a method sufficient to collect a minimum sample volume of 300 liters. Air samples were submitted under chain-of-custody to Scientific Analytical Institute, Inc. (SAI), for independent analysis of RCRA metals according to NIOSH Method 7300. SAI is accredited by the American Industrial Hygiene Association (AIHA) utilizing the Industrial Hygiene Proficiency Analytical Testing (IHPAT) program. SAI’s AIHA IHPAT Laboratory identification number is 173190.

Results of the air sampling are summarized in the table below by identifying the range of results for Building 106 for each of the seven (7) metals that were sampled. **Samples with a “<” sign indicate that the results were below the laboratory’s method reporting limit.**

Analysis	Lowest Concentration ( $\mu\text{g}/\text{m}^3$ )	Highest Concentration ( $\mu\text{g}/\text{m}^3$ )
Silver Ag	<6.2	<6.2
Arsenic As	<0.31	<0.31
Barium Ba	<0.062	<0.062
Cadmium Cd	<0.062	<0.062
Total Chromium Cr	1.7	2.0
Lead Pb	<0.31	0.46
Selenium Se	<0.62	<0.62

Results indicate that **all** of the air samples collected from Building 106 contained concentrations of RCRA metals below the OSHA Permissible Exposure Limit (PEL). Sample locations and the corresponding result are summarized in the enclosed laboratory analytical report. The air sampling professional’s Missouri Lead license is included in Appendix B.

It should be noted that this air sampling investigation was only a screening of airborne RCRA metals and should not be interpreted or used to determine compliance or non-compliance with OSHA personnel monitoring regulations.

OCCU-TEC appreciates the opportunity to work with GSA on this project. If you have any questions concerning this report, or if we may be of any additional service, please feel free to contact us.

Sincerely,

(b) (6)

Jeff T. Smith  
Senior Project Manager

(b) (6)

Kevin Heriford  
Project Manager (QA/QC)

Appendices:

- A: Laboratory Analytical Results and Chain of Custody Documentation
- B: Qualifications and Licenses

# **Appendix A**

## Laboratory Analytical Report and Chain of Custody Documentation





# Airborne Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH Method 7300



<b>Client:</b>	Occu-Tec, Inc 100 NW Business Park Ln Riverside, MO 64150	<b>Attn:</b> Justin Arnold	<b>Lab Order ID:</b> 11811087	
			<b>Date Received:</b> 05/04/2018	
			<b>Date Reported:</b> 05/14/2018	
<b>Project:</b>	918004.002		<b>Page:</b>	1 of 1

Sample ID	Description	Volume (L)	Element	Reporting Limit (µg)	Concentration (µg)	Concentration (µg/m <sup>3</sup> )
<i>Lab Sample ID</i>	<i>Lab Notes</i>					
106-MetA18-01	Guard Station West Side	323.2	Ag	2.0	<2.0	<6.2
			As	0.10	<0.10	<0.31
			Ba	0.020	<0.020	<0.062
			Cd	0.020	<0.020	<0.062
			Cr	0.20	0.65	2.0
			Pb	0.10	<0.10	<0.31
11811087ICP_1			Se	0.20	<0.20	<0.62
106 -MetA18-02	Guard Station East Side	323.2	Ag	2.0	<2.0	<6.2
			As	0.10	<0.10	<0.31
			Ba	0.020	<0.020	<0.062
			Cd	0.020	<0.020	<0.062
			Cr	0.20	0.56	1.7
			Pb	0.10	0.15	0.46
11811087ICP_2			Se	0.20	<0.20	<0.62
106 -MetA18-03	Blank	0	Ag	2.0	<2.0	--
			As	0.10	<0.10	--
			Ba	0.020	<0.020	--
			Cd	0.020	<0.020	--
			Cr	0.20	0.55	--
			Pb	0.10	<0.10	--
11811087ICP_3			Se	0.20	<0.20	--

Taylor Davis

(b) (6)

\_\_\_\_\_  
Analyst

\_\_\_\_\_  
Lab Director

This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. This report may not be used by the client to claim product endorsement by AIHA or any other agency of the U.S. government. Scientific Analytical Institute participates in the AIHA IHPAT program. IHPAT Laboratory ID: 173190. Unless otherwise noted blank sample correction was not performed on analytical results. MDLs are available upon request. Reporting limits stated above.



**Scientific Analytical Institute, Inc.**  
 4604 Dundas Dr. Greensboro, NC 27407  
 Phone: 336.292.3888 Fax: 336.292.3313  
 www.sailab.com lab@sailab.com

Lab Use Only  
 Lab Order ID: 11811087  
 Client Code: \_\_\_\_\_

Company Contact Information	
Company: <u>Occu-Tec</u>	Contact: <u>Justin Arnold</u>
Address: <u>100 NW Business Park Lane</u>	Phone <input type="checkbox"/> : <u>816-810-3276</u>
<u>Riverside, MO 64150</u>	Fax <input type="checkbox"/> : <u>816-994-3478</u>
	Email: <u>jarnold@occutec.com</u>

Billing/Invoice Information	Turn Around Times <sup>^</sup>	
SAME <input checked="" type="checkbox"/>	90 Min. <input type="checkbox"/>	48 Hours <input type="checkbox"/>
Company:	3 Hours <input type="checkbox"/>	72 Hours <input type="checkbox"/>
Contact:	6 Hours <input type="checkbox"/>	96 Hours <input type="checkbox"/>
Address:	12 Hours <input type="checkbox"/>	120 Hours <input type="checkbox"/>
	24 Hours <input type="checkbox"/>	144 <sup>+</sup> Hours <input checked="" type="checkbox"/>
	^TATs not available for certain test types	
PO Number: <u>232018061</u>		
Project Name/Number: <u>918004.002</u>		

Industrial Hygiene Test Types	
Silica as Alpha Quartz (XSZ)* <input type="checkbox"/>	With Respirable Dust (XDZ) <input type="checkbox"/>
Silica as Cristobalite (XSC)* <input type="checkbox"/>	With Respirable Dust (XDC) <input type="checkbox"/>
Silica as Tridymite (XST)* <input type="checkbox"/>	With Respirable Dust (XDT) <input type="checkbox"/>
Silica as Alpha Quartz, Cristobalite, Tridymite (XSA)* <input type="checkbox"/>	With Respirable Dust (XDA) <input type="checkbox"/>
Silica Bulk (XSI)*	<input type="checkbox"/>
Bulk Phase ID/Whole Rock (XUK)	<input type="checkbox"/>
Total Dust NIOSH Method 0500 (GTD)	<input type="checkbox"/>
Respirable Dust NIOSH Method 0600 (GRD)	<input type="checkbox"/>
PCM NIOSH 7400-A Rules (PCM)	<input type="checkbox"/>
B Rules (PCB) <input type="checkbox"/>	TWA (PTA) <input type="checkbox"/>
TEM NIOSH 7402 (Asbestos) (TNI)	<input type="checkbox"/>
Hexavalent Chromium (OSHA ID-215) (Note if from spray paint operations)	<input type="checkbox"/>
Metals (NIOSH 7300) (Specify Metals Under Comments)	<input type="checkbox"/>
Other: <u>PCRB US 43</u>	<input checked="" type="checkbox"/>
<u>NIOSH 7300 OSHA 125</u>	<input checked="" type="checkbox"/>
* Modified NIOSH 7500 OSHA ID 142	

Sample ID #	Description/Location	Volume/Area	Comments
102-McHA18-01	Guard station West Side	323.2 L	
102-McHA18-02	Guard Station East Side	323.2 L	
102-McHA18-03	BLANK		

Accepted   
 Rejected

Total # of Samples 3

Relinquished by	Date/Time	Received by	Date/Time
(b) (6)	4-30-2018	(b) (6)	3/7 10:30 AM

# **Appendix B**

## Qualifications and Licenses





**Missouri Department of Health and Senior Services**

P.O. Box 570, Jefferson City, MO 65102-0570 Phone: 573-751-6400 FAX: 573-751-6010  
RELAY MISSOURI for Hearing and Speech Impaired 1-800-735-2966 VOICE 1-800-735-2466

**Peter Lyskowski**  
Acting Director



**Jeremiah W. (Jay) Nixon**  
Governor

May 27, 2016

Justin Arnold  
Occu-Tec, Inc.  
100 NW Business Park Lane  
Riverside, MO 64150

Dear Licensee:

After review of your renewal application for a license with the Missouri Department of Health and Senior Services' Lead Licensing Program, your application for a Lead Risk Assessor license has been approved.

Enclosed is your Lead Risk Assessor license certificate and photo identification badge. Please have your identification badge with you at all times while conducting lead abatement activities.

Note the date your Lead Risk Assessor license expires. A renewal application and information will be mailed to you approximately three months before your license expiration date and will need to be completed and submitted 60 days prior to the expiration date.

A requirement of renewing your application will be attending a Lead Risk Assessor refresher class. A list of Missouri accredited lead abatement training providers will be included in your renewal packet. Additional information on training and lead abatement in general can be found at <http://health.mo.gov/safety/leadlicensing/index.php>.

Please contact the Lead Licensing Program at (573) 526-5873 or (888) 837-0927 if you have any questions concerning this letter or on lead abatement regulations in general.


Sincerely,

(b) (6)

Angie DeBroeck  
Lead Licensing Program

AKD:ss

Enclosures



[www.health.mo.gov](http://www.health.mo.gov)

Healthy Missourians for  
The Missouri Department of Health and Senior Services will be the lead



Expiration Date: N/A

Certificate Number: 7070111MOASP13670

Training Date: 7/1/2011

**Missouri State Certificate for Asbestos Related Occupations**

issued by Department of Natural Resources

P.O. Box 176

Jefferson City, MO 65102

Phone (573) 751-4817

**Justin E. Arnold**

has successfully completed the requirements for certification as a AIR SAMPLING PROFESSIONAL. This Missouri State Certification is subject to review and the director may deny, suspend or revoke the certification per RSMo chapter 643.230.

7/5/2011

Date

(b) (6)

Director of Air Pollution Control Program

