



July 22, 2020

Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center – Bldg. 103 Air Sampling  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced buildings located at the Goodfellow Federal Complex, in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide sampling data regarding pre-existing conditions noted in the investigation reports previously prepared for the facility. The following report summarizes the sample collection activities and the laboratory analytical results of the samples submitted.

#### **METHODOLOGY**

On June 18, 2020, Emily Ahlemeyer of Burns & McDonnell and Justin Arnold of OCCU-TEC conducted air sampling for the presence of seven (7) of the RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver. Sampling was conducted in various locations throughout Building 103.

The proposed sampling scheme, the number of samples, sample distribution, and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by sampling personnel while on-site.

Air sampling for RCRA metals was collected on 37-millimeter (mm) cassettes with 0.8 micrometer ( $\mu\text{m}$ ) mixed cellulose ester (MCE) filters using powered air sampling pumps in accordance with the National Institute for Occupational Safety and Health (NIOSH) sampling methodology. Samples were collected in a method sufficient to collect a minimum sample volume of 300 liters. Air samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independence analysis of RCRA metals according to NIOSH method 7300. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.

Diane Czarnecki  
 Facilities Management Division  
 July 22, 2020  
 Page 2

## RESULTS AND DISCUSSION

Results of the air sampling are summarized in the table below by identifying the range of results for Building 103 for each of the seven (7) metals that were sampled. Results indicate that all twenty-seven (27) air samples collected from Building 103 contained concentrations of RCRA metals below the OSHA Permissible Exposure Limit (PEL).

**Table 1. Summary of Air Sampling Results**

Analyte	Lowest Concentration <sup>(a)</sup> ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>	Highest Concentration <sup>(a)</sup> ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>	Permissible Exposure Limit (PEL) ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>
Arsenic	<2.2	<2.5	10
Barium	<0.41	<0.48	500
Cadmium	<0.41	<0.48	5
Chromium (Total)	<2.2	<2.5	500
Lead	<0.41	0.54	50
Selenium	<2.2	<2.5	200
Silver	<0.41	<0.48	10

Notes:

- (a) Samples with a “<” sign indicate that the results were below the reportable limit.
- (b)  $\mu\text{g}/\text{m}^3$  = micrograms per cubic meter of air.

GSA may choose to compare results with guidance limits from additional organizations for risk evaluation, including but not limited to the American Conference of Governmental Industrial Hygienists (ACGIH) and/or the World Health Organization (WHO).

A summary table of all sampling results by location is included in Appendix A. The complete laboratory report for the air sampling from EHS is attached in Appendix B. The air sampling professional’s Missouri Lead license is included in Appendix C.

## LIMITATIONS

The scope of this assessment was limited as follows. Burns & McDonnell collected samples from a select number of locations in an effort to minimize cost while providing a general overview of the air quality at the site. Sample locations do not encompass every indoor space at the Site. Additionally, samples were only analyzed for a select number of potential contaminants likely to affect the air quality at the site. Burns & McDonnell is not responsible for potential contaminants not identified in this report. This report was prepared for the sole use of GSA.




Diane Czarnecki  
Facilities Management Division  
July 22, 2020  
Page 3

Burns & McDonnell appreciates the opportunity to work with the General Services Administration on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A black rectangular redaction box covering the signature of Matt Shanahan.

Matt Shanahan, CHMM  
Project Manager

Attachments:

- Appendix A – Results Summary by Location
- Appendix B – Air Sample Laboratory Report
- Appendix C – Qualifications and Licenses

**APPENDIX A – RESULTS SUMMARY BY LOCATION**

# Appendix A

## Results Summary by Location

Goodfellow Federal Center - Building 103 - Air Sample Data					
Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
103-A-01	1st Floor, Column J3	Arsenic	< 2.2	µg/m <sup>3</sup>	10
		Barium	< 0.41	µg/m <sup>3</sup>	500
		Cadmium	< 0.41	µg/m <sup>3</sup>	5
		Chromium	< 2.2	µg/m <sup>3</sup>	500
		Lead	< 0.41	µg/m <sup>3</sup>	50
		Selenium	< 2.2	µg/m <sup>3</sup>	200
		Silver	< 0.41	µg/m <sup>3</sup>	10
103-A-02	1st Floor, Column G2	Arsenic	< 2.2	µg/m <sup>3</sup>	10
		Barium	< 0.42	µg/m <sup>3</sup>	500
		Cadmium	< 0.42	µg/m <sup>3</sup>	5
		Chromium	< 2.2	µg/m <sup>3</sup>	500
		Lead	< 0.42	µg/m <sup>3</sup>	50
		Selenium	< 2.2	µg/m <sup>3</sup>	200
		Silver	< 0.42	µg/m <sup>3</sup>	10
103-A-03	1st Floor, Column F4	Arsenic	< 2.2	µg/m <sup>3</sup>	10
		Barium	< 0.42	µg/m <sup>3</sup>	500
		Cadmium	< 0.42	µg/m <sup>3</sup>	5
		Chromium	< 2.2	µg/m <sup>3</sup>	500
		Lead	< 0.42	µg/m <sup>3</sup>	50
		Selenium	< 2.2	µg/m <sup>3</sup>	200
		Silver	< 0.42	µg/m <sup>3</sup>	10
103-A-04	1st Floor, Column D6	Arsenic	< 2.3	µg/m <sup>3</sup>	10
		Barium	< 0.44	µg/m <sup>3</sup>	500
		Cadmium	< 0.44	µg/m <sup>3</sup>	5
		Chromium	< 2.3	µg/m <sup>3</sup>	500
		Lead	0.44	µg/m <sup>3</sup>	50
		Selenium	< 2.3	µg/m <sup>3</sup>	200
		Silver	< 0.44	µg/m <sup>3</sup>	10
103-A-05	1st Floor, Column C13	Arsenic	< 2.3	µg/m <sup>3</sup>	10
		Barium	< 0.43	µg/m <sup>3</sup>	500
		Cadmium	< 0.43	µg/m <sup>3</sup>	5
		Chromium	< 2.3	µg/m <sup>3</sup>	500
		Lead	0.50	µg/m <sup>3</sup>	50
		Selenium	< 2.3	µg/m <sup>3</sup>	200
		Silver	< 0.43	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Goodfellow Federal Center - Building 103 - Air Sample Data					
Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
103-A-06	1st Floor, Column C19	Arsenic	< 2.3	µg/m <sup>3</sup>	10
		Barium	< 0.44	µg/m <sup>3</sup>	500
		Cadmium	< 0.44	µg/m <sup>3</sup>	5
		Chromium	< 2.3	µg/m <sup>3</sup>	500
		Lead	< 0.44	µg/m <sup>3</sup>	50
		Selenium	< 2.3	µg/m <sup>3</sup>	200
		Silver	< 0.44	µg/m <sup>3</sup>	10
103-A-07	1st Floor, Column D20	Arsenic	< 2.4	µg/m <sup>3</sup>	10
		Barium	< 0.45	µg/m <sup>3</sup>	500
		Cadmium	< 0.45	µg/m <sup>3</sup>	5
		Chromium	< 2.4	µg/m <sup>3</sup>	500
		Lead	0.54	µg/m <sup>3</sup>	50
		Selenium	< 2.4	µg/m <sup>3</sup>	200
		Silver	< 0.45	µg/m <sup>3</sup>	10
103-A-08	2nd Floor, Column J20	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-09	2nd Floor, Column G13	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-10	2nd Floor, Column G5	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10

# Appendix A

## Results Summary by Location

Goodfellow Federal Center - Building 103 - Air Sample Data					
Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
103-A-11	2nd Floor, Column D1	Arsenic	< 2.4	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.4	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.4	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-12	2nd Floor, Column B14	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	0.51	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-13	Field Blank	Arsenic	< 1.3	µg	--
		Barium	< 0.25	µg	--
		Cadmium	< 0.25	µg	--
		Chromium	< 1.3	µg	--
		Lead	< 0.25	µg	--
		Selenium	< 1.3	µg	--
		Silver	< 0.25	µg	--
103-A-14	1st Floor, Column B22	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	0.54	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-15	1st Floor, Column A27	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	0.53	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Goodfellow Federal Center - Building 103 - Air Sample Data					
Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
103-A-16	1st Floor, Column E31	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-17	1st Floor, Column J34	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.48	µg/m <sup>3</sup>	500
		Cadmium	< 0.48	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.48	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.48	µg/m <sup>3</sup>	10
103-A-18	1st Floor, Column H37	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-19	1st Floor, Column G39	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-20	1st Floor, Column C39	Arsenic	< 2.4	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.4	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.4	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10



## Appendix A

### Results Summary by Location

Goodfellow Federal Center - Building 103 - Air Sample Data					
Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
103-A-21	2nd Floor, Column B31	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.48	µg/m <sup>3</sup>	500
		Cadmium	< 0.48	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.48	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.48	µg/m <sup>3</sup>	10
103-A-22	2nd Floor, Column F32	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-23	2nd Floor, Column B37	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.48	µg/m <sup>3</sup>	500
		Cadmium	< 0.48	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.48	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.48	µg/m <sup>3</sup>	10
103-A-24	2nd Floor, Column C33	Arsenic	< 2.5	µg/m <sup>3</sup>	10
		Barium	< 0.47	µg/m <sup>3</sup>	500
		Cadmium	< 0.47	µg/m <sup>3</sup>	5
		Chromium	< 2.5	µg/m <sup>3</sup>	500
		Lead	< 0.47	µg/m <sup>3</sup>	50
		Selenium	< 2.5	µg/m <sup>3</sup>	200
		Silver	< 0.47	µg/m <sup>3</sup>	10
103-A-25	2nd Floor, Column G35	Arsenic	< 2.4	µg/m <sup>3</sup>	10
		Barium	< 0.46	µg/m <sup>3</sup>	500
		Cadmium	< 0.46	µg/m <sup>3</sup>	5
		Chromium	< 2.4	µg/m <sup>3</sup>	500
		Lead	< 0.46	µg/m <sup>3</sup>	50
		Selenium	< 2.4	µg/m <sup>3</sup>	200
		Silver	< 0.46	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Goodfellow Federal Center - Building 103 - Air Sample Data					
Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
103-A-26	Field Blank	Arsenic	< 1.3	µg	--
		Barium	< 0.25	µg	--
		Cadmium	< 0.25	µg	--
		Chromium	< 1.3	µg	--
		Lead	< 0.25	µg	--
		Selenium	< 1.3	µg	--
		Silver	< 0.25	µg	--
103-A-27	Field Blank	Arsenic	< 1.3	µg	--
		Barium	< 0.25	µg	--
		Cadmium	< 0.25	µg	--
		Chromium	< 1.3	µg	--
		Lead	< 0.25	µg	--
		Selenium	< 1.3	µg	--
		Silver	< 0.25	µg	--

Notes:

<sup>1</sup>Limits equal to the Occupational Safety and Health Administration (OSHA) Permissible Exposure Limits (PELs)

**APPENDIX B – AIR SAMPLE LABORATORY REPORT**



Environmental Hazards Services, L.L.C.  
 7469 Whitepine Rd  
 Richmond, VA 23237  
 Telephone: 800.347.4010

## Air Metals Analysis Report

Client: Burns & McDonnell Engineering  
 9400 Ward Pkwy.  
 Kansas City, MO 64114

Report Number: 20-06-02669  
 Received Date: 06/22/2020  
 Reported Date: 06/23/2020

Project/Test Address: 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Client Number:  
26-3514

Fax Number:  
816-822-3494

# Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
20-06-02669-001	103-A-01	06/22/2020	Arsenic (As)	612.3	<1.3	<2.2	
			Barium (Ba)		<0.25	<0.41	
			Cadmium (Cd)		<0.25	<0.41	
			Chromium (Cr)		<1.3	<2.2	
			Lead (Pb)		<0.25	<0.41	
			Selenium (Se)		<1.3	<2.2	
			Silver (Ag)		<0.25	<0.41	
20-06-02669-002	103-A-02	06/22/2020	Arsenic (As)	607.3	<1.3	<2.2	
			Barium (Ba)		<0.25	<0.42	
			Cadmium (Cd)		<0.25	<0.42	
			Chromium (Cr)		<1.3	<2.2	
			Lead (Pb)		<0.25	<0.42	
			Selenium (Se)		<1.3	<2.2	
			Silver (Ag)		<0.25	<0.42	
20-06-02669-003	103-A-03	06/22/2020	Arsenic (As)	604.7	<1.3	<2.2	
			Barium (Ba)		<0.25	<0.42	
			Cadmium (Cd)		<0.25	<0.42	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-02669

Project/Test Address: 168765; Goodfellow IH Services; 4300  
Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
			Chromium (Cr)		<1.3	<2.2	
			Lead (Pb)		<0.25	<0.42	
			Selenium (Se)		<1.3	<2.2	
			Silver (Ag)		<0.25	<0.42	
20-06-02669-004I	103-A-04	06/22/2020	Arsenic (As)	580.2	<1.3	<2.3	
			Barium (Ba)		<0.25	<0.44	
			Cadmium (Cd)		<0.25	<0.44	
			Chromium (Cr)		<1.3	<2.3	
			Lead (Pb)		0.26	0.44	
			Selenium (Se)		<1.3	<2.3	
			Silver (Ag)		<0.25	<0.44	
20-06-02669-005I	103-A-05	06/22/2020	Arsenic (As)	586.7	<1.3	<2.3	
			Barium (Ba)		<0.25	<0.43	
			Cadmium (Cd)		<0.25	<0.43	
			Chromium (Cr)		<1.3	<2.3	
			Lead (Pb)		0.30	0.50	
			Selenium (Se)		<1.3	<2.3	
			Silver (Ag)		<0.25	<0.43	
20-06-02669-006I	103-A-06	06/22/2020	Arsenic (As)	570.9	<1.3	<2.3	
			Barium (Ba)		<0.25	<0.44	
			Cadmium (Cd)		<0.25	<0.44	
			Chromium (Cr)		<1.3	<2.3	
			Lead (Pb)		<0.25	<0.44	
			Selenium (Se)		<1.3	<2.3	
			Silver (Ag)		<0.25	<0.44	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-02669

Project/Test Address: 168765; Goodfellow IH Services; 4300  
Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
20-06-02669-007I	103-A-07	06/22/2020	Arsenic (As)	559.1	<1.3	<2.4	
			Barium (Ba)		<0.25	<0.45	
			Cadmium (Cd)		<0.25	<0.45	
			Chromium (Cr)		<1.3	<2.4	
			Lead (Pb)		0.30	0.54	
			Selenium (Se)		<1.3	<2.4	
			Silver (Ag)		<0.25	<0.45	
20-06-02669-008I	103-A-08	06/22/2020	Arsenic (As)	534.4	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-009I	103-A-09	06/22/2020	Arsenic (As)	540	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-010I	103-A-10	06/22/2020	Arsenic (As)	533.2	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-02669

Project/Test Address: 168765; Goodfellow IH Services; 4300  
Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-011I	103-A-11	06/22/2020	Arsenic (As)	543.2	<1.3	<2.4	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.4	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.4	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-012I	103-A-12	06/22/2020	Arsenic (As)	538.5	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		0.28	0.51	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-013I	103-A-13	06/22/2020	Arsenic (As)	0	<1.3	---	
			Barium (Ba)		<0.25	---	
			Cadmium (Cd)		<0.25	---	
			Chromium (Cr)		<1.3	---	
			Lead (Pb)		<0.25	---	
			Selenium (Se)		<1.3	---	
			Silver (Ag)		<0.25	---	
20-06-02669-014I	103-A-14	06/22/2020	Arsenic (As)	540.4	<1.3	<2.5	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-02669

Project/Test Address: 168765; Goodfellow IH Services; 4300  
Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		0.29	0.54	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-015I	103-A-15	06/22/2020	Arsenic (As)	534.6	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		0.28	0.53	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-016I	103-A-16	06/22/2020	Arsenic (As)	540	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-017I	103-A-17	06/22/2020	Arsenic (As)	530.4	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.48	
			Cadmium (Cd)		<0.25	<0.48	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.48	



# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-02669

Project/Test Address: 168765; Goodfellow IH Services; 4300  
Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.48	
20-06-02669-018I	103-A-18	06/22/2020	Arsenic (As)	540	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-019I	103-A-19	06/22/2020	Arsenic (As)	540	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-020I	103-A-20	06/22/2020	Arsenic (As)	541.8	<1.3	<2.4	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.4	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.4	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-021I	103-A-21	06/22/2020	Arsenic (As)	530.6	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.48	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-02669

Project/Test Address: 168765; Goodfellow IH Services; 4300  
Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
			Cadmium (Cd)		<0.25	<0.48	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.48	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.48	
20-06-02669-022I	103-A-22	06/22/2020	Arsenic (As)	536.4	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.47	
20-06-02669-023I	103-A-23	06/22/2020	Arsenic (As)	526.1	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.48	
			Cadmium (Cd)		<0.25	<0.48	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.48	
			Selenium (Se)		<1.3	<2.5	
			Silver (Ag)		<0.25	<0.48	
20-06-02669-024I	103-A-24	06/22/2020	Arsenic (As)	535.3	<1.3	<2.5	
			Barium (Ba)		<0.25	<0.47	
			Cadmium (Cd)		<0.25	<0.47	
			Chromium (Cr)		<1.3	<2.5	
			Lead (Pb)		<0.25	<0.47	
			Selenium (Se)		<1.3	<2.5	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-02669

Project/Test Address: 168765; Goodfellow IH Services; 4300  
Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
			Silver (Ag)		<0.25	<0.47	
20-06-02669-0251	103-A-25	06/22/2020	Arsenic (As)	551.5	<1.3	<2.4	
			Barium (Ba)		<0.25	<0.46	
			Cadmium (Cd)		<0.25	<0.46	
			Chromium (Cr)		<1.3	<2.4	
			Lead (Pb)		<0.25	<0.46	
			Selenium (Se)		<1.3	<2.4	
			Silver (Ag)		<0.25	<0.46	
20-06-02669-0261	103-A-26	06/22/2020	Arsenic (As)	0	<1.3	---	
			Barium (Ba)		<0.25	---	
			Cadmium (Cd)		<0.25	---	
			Chromium (Cr)		<1.3	---	
			Lead (Pb)		<0.25	---	
			Selenium (Se)		<1.3	---	
			Silver (Ag)		<0.25	---	
20-06-02669-0271	103-A-27	06/22/2020	Arsenic (As)	0	<1.3	---	
			Barium (Ba)		<0.25	---	
			Cadmium (Cd)		<0.25	---	
			Chromium (Cr)		<1.3	---	
			Lead (Pb)		<0.25	---	
			Selenium (Se)		<1.3	---	
			Silver (Ag)		<0.25	---	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-02669

Project/Test Address: 168765; Goodfellow IH Services; 4300  
Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	------------------------------------	--------------

Sample Narratives:

Method: NIOSH 7300M  
Analyst: Brittany Meyer

(b) (6)

Reviewed By Authorized Signatory:

*Tasha Eaddy*  
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 25mL volume. The reporting limit is 0.05ug for Beryllium, 25ug for Aluminum, Calcium, Iron and Zinc, 1.3ug for Arsenic, Chromium, Magnesium, Antimony and Selenium, and 0.25ug for all other metals.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

LEGEND                    ug = microgram                    ug/m<sup>3</sup> = micrograms per cubic meter  
                                  mL = milliliter                    L= Liters



# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Company Name		Burns & McDonnell			Account #		26-3514											
Company Address		9400 Ward Parkway			City/State/Zip		Kansas City, MO 64114											
Phone		816-349-6646			Email		mshanahan@burnsmcd.com											
Project Name / Testing Address		Goodfellow IH Services / 4300 Goodfellow Blvd.																
PO Number		168765			Collected By		Emily Anhemeyer & Justin Arnold											
Turn-Around Time		<input checked="" type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead																
LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES			AIR			WIPES  AREA Circle The Unit of Measurement Used cm or in		
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10		Total Time	Flow Rate
1	103-A-16	6/18/2020 1234							Aq, As, Ba, Cd, Cr, Pb, Se						213	2.54	540.0	x
2	103-A-17	1235													213	2.49	530.4	x
3	103-A-18	1236													213	2.54	540.0	x
4	103-A-19	1237													213	2.54	540.0	x
5	103-A-20	1239													215	2.52	541.8	x
6	103-A-21	1241													217	2.45	530.6	x
7	103-A-22	1245													215	2.50	536.4	x
8	103-A-23	1248													213	2.47	526.1	x
9	103-A-24	1250													212	2.53	535.3	x
10	103-A-25	1253													218	2.53	551.5	x
11	103-A-26	0931													NA	NA	NA	x
12	103-A-27	0932													NA	NA	NA	x
13																		x
14																		x
15																		x
Released By:		Emily Anhemeyer			Date:		6/19/2020			Time:		4:00 PM						
Signature:		(b) (6)																

LAB USE ONLY - BELOW THIS LINE

Received By: T Stone  
 Signature: (b) (6)  
 Date: 6/22/20 Time: 1:03  AM  PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010  
 RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

2669

**EHS**

*Laboratories*

Attach Laboratory Label Here

## **APPENDIX C – QUALIFICATIONS AND LICENSES**



**STATE OF MISSOURI**  
**DEPARTMENT OF HEALTH AND SENIOR SERVICES**

**LEAD OCCUPATION LICENSE REGISTRATION**

Issued to:

**Justin E. Arnold**

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Risk Assessor**  
Category of License

Issuance Date: **6/11/2020**  
Expiration Date: **6/11/2022**  
License Number: **120611-300003622**



(b) (6)

Randall W. Williams, MD, FACOG  
Director  
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102