



July 23, 2020

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, MO 64108

Re: Goodfellow Federal Center
Metals in Settled Dust Sampling – Building 105L
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 105L located at the Goodfellow Federal Center (GFC) in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

INTRODUCTION

Per historical use and previous characterization, Burns & McDonnell was contracted to perform settled dust sampling for the analysis of seven (7) of the Resource Conservation and Recovery Act (RCRA) target metals (arsenic, barium, cadmium, chromium, lead, selenium, and silver) from various surfaces within buildings. The purpose of this testing was to further characterize the presence and concentration of target metals in common tenant-occupied areas of the building.

The proposed sampling scheme, the number of samples, the sample distribution and general methodology was developed by GSA and Burns & McDonnell. Specific sample locations were determined by sampling personnel while on-site.

Settled dust wipe sampling at Bldg. 105L was conducted on June 25, 2020 by Emily Ahlemeyer of Burns & McDonnell and Jeff Smith of OCCU-TEC.

METALS IN SETTLED DUST SAMPLING

Metals in settled dust sampling was conducted primarily within tenant-occupied areas. Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination*. ASTM Standard E1728 is consistent with the methodology described in the Housing and Urban Development Guidelines and 40 CFR 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.



Diane Czarnecki
Facilities Management Division
July 23, 2020
Page 2

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed by building occupants. A representative surface area of approximately one square foot (1 SF) was measured and delineated with plastic templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth “S” pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container. Dust wipe samples were submitted to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for Inductively Coupled Plasma (ICP) analysis of metals analysis using Environmental Protection Agency (EPA) method SW846 3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Laboratory Accreditation Program (LAP) identification number LAP-100420.

Whereas the Occupational Safety and Health Administration (OSHA) has not established regulatory limits for surface concentrations of metals, the OSHA Technical Manual Section II: Chapter 2 (III.A) describes a method for calculating “housekeeping” standards, as recommended acceptable surface limits. Brookhaven’s IH75190 procedure uses the housekeeping standards to derive a lower, “clean area limit” for non-operational areas that can be accessed or contacted without special training or precautions. Burns & McDonnell calculated clean area limits for metals not included in the Brookhaven procedure, specifically barium, chromium (total), selenium and silver. Wipe results were compared to the Brookhaven procedure’s clean area limits for each metal.

Results of the dust wipe samples collected from the building indicate that three (3) of the eight (8) samples contained concentrations of target metals above laboratory reporting limits. The following table identifies the range of results for each of the seven metals that were analyzed. Samples with a “<” sign indicate that the results were below the lab’s reportable limit.

Diane Czarnecki
 Facilities Management Division
 July 23, 2020
 Page 3

Table 1. Summary of Dust Wipe Results

Analyte	Lowest Concentration ^(a) (µg/sq. ft) ^(b)	Highest Concentration ^(a) (µg/sq. ft) ^(b)	Clean Area Limit ^(c) µg/sq. ft ^(b)
Silver	<2.0	<2.0	62
Arsenic	<2.0	<2.0	62
Barium	<2.0	23	3,094
Cadmium	<2.0	<2.0	31
Chromium (Total)	<2.0	<2.0	3,094
Lead	<2.0	20	10 ^(d)
Selenium	<5.0	<5.0	1,236

- (a) Samples with a “<” sign indicate that the results were below the reportable limit.
- (b) µg/sq. ft = micrograms per square foot of surface area.
- (c) Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [PEL (µg/m³) x 10 m³/100cm²] / 15.
- (d) Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

One (1) sample exceeded the lead clean area limit. Sample 105L-W-07 resulted in a lead concentration of 20 µg/sq. ft. The remaining target metal sample results were below housekeeping and clean area limits, as recommended and described by OSHA and the Brookhaven Procedure.

Burns & McDonnell appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)


Matt Shanahan, CHMM
 Project Manager

- Attachments:
- Appendix A – Sample Summary Table
 - Appendix B – Laboratory Analysis Report
 - Appendix C – Licenses

APPENDIX A – SAMPLE SUMMARY TABLE

Appendix A
Sample Summary Table

Goodfellow Federal Center - Building # 105L - Wipe Sample Data

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
105L-W-01	Projection Booth	Top of video equipment	Silver	< 2.0	µg/ft ²	62
			Arsenic	< 2.0	µg/ft ²	62
			Barium	< 2.0	µg/ft ²	3,094
			Cadmium	< 2.0	µg/ft ²	31
			Chromium	< 2.0	µg/ft ²	3,094
			Lead	< 2.0	µg/ft ²	10
			Selenium	< 5.0	µg/ft ²	1,236
105L-W-02	Stage Area	Floor in vestibule east of stage	Silver	< 2.0	µg/ft ²	62
			Arsenic	< 2.0	µg/ft ²	62
			Barium	11	µg/ft ²	3,094
			Cadmium	< 2.0	µg/ft ²	31
			Chromium	< 2.0	µg/ft ²	3,094
			Lead	7.4	µg/ft ²	10
			Selenium	< 5.0	µg/ft ²	1,236
105L-W-03	Hallway	Floor by north exit	Silver	< 2.0	µg/ft ²	62
			Arsenic	< 2.0	µg/ft ²	62
			Barium	< 2.0	µg/ft ²	3,094
			Cadmium	< 2.0	µg/ft ²	31
			Chromium	< 2.0	µg/ft ²	3,094
			Lead	< 2.0	µg/ft ²	10
			Selenium	< 5.0	µg/ft ²	1,236

Appendix A
Sample Summary Table

Goodfellow Federal Center - Building # 105L - Wipe Sample Data

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
105L-W-04	Room 104	Classroom table top	Silver	< 2.0	µg/ft ²	62
			Arsenic	< 2.0	µg/ft ²	62
			Barium	< 2.0	µg/ft ²	3,094
			Cadmium	< 2.0	µg/ft ²	31
			Chromium	< 2.0	µg/ft ²	3,094
			Lead	< 2.0	µg/ft ²	10
			Selenium	< 5.0	µg/ft ²	1,236
105L-W-05	Mens Restroom	Floor under sink	Silver	< 2.0	µg/ft ²	62
			Arsenic	< 2.0	µg/ft ²	62
			Barium	< 2.0	µg/ft ²	3,094
			Cadmium	< 2.0	µg/ft ²	31
			Chromium	< 2.0	µg/ft ²	3,094
			Lead	< 2.0	µg/ft ²	10
			Selenium	< 5.0	µg/ft ²	1,236
105L-W-06	Janitors Closet	Floor under shelving	Silver	< 2.0	µg/ft ²	62
			Arsenic	< 2.0	µg/ft ²	62
			Barium	2.7	µg/ft ²	3,094
			Cadmium	< 2.0	µg/ft ²	31
			Chromium	< 2.0	µg/ft ²	3,094
			Lead	< 2.0	µg/ft ²	10
			Selenium	< 5.0	µg/ft ²	1,236

Appendix A
Sample Summary Table

Goodfellow Federal Center - Building # 105L - Wipe Sample Data

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
105L-W-07	Storage Room	Floor, east side of stage	Silver	< 2.0	µg/ft ²	62
			Arsenic	< 2.0	µg/ft ²	62
			Barium	23	µg/ft ²	3,094
			Cadmium	< 2.0	µg/ft ²	31
			Chromium	< 2.0	µg/ft ²	3,094
			Lead	20	µg/ft ²	10
			Selenium	< 5.0	µg/ft ²	1,236
105L-W-08	Field Blank	--	Silver	< 2.0	µg	--
			Arsenic	< 2.0	µg	--
			Barium	< 2.0	µg	--
			Cadmium	< 2.0	µg	--
			Chromium	< 2.0	µg	--
			Lead	< 2.0	µg	--
			Selenium	< 5.0	µg	--

* Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [$PEL (\mu\text{g}/\text{m}^3) \times 10 \text{ m}^3/100\text{cm}^2$] / 15. Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

Indicates results at or above the Clean Area Limit

APPENDIX B – LABORATORY ANALYSIS REPORT



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Wipe Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 20-06-03504
Received Date: 06/29/2020
Analyzed Date: 07/01/2020
Reported Date: 07/02/2020

Project/Test Address: 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Client Number:
 26-3514

Laboratory Results

Fax Number:
 816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
20-06-03504-001	105L-W-01	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-03504-002	105L-W-02	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	10.8	11	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-03504

Project/Test Address: 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Lead (Pb)	1.00	7.45	7.4	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-03504-003	105L-W-03	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-03504-004	105L-W-04	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-03504-005	105L-W-05	Arsenic (As)	1.00	<2.00	<2.0	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-03504

Project/Test Address: 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-03504-006	105L-W-06	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	2.71	2.7	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-03504-007	105L-W-07	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	22.9	23	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	20.0	20	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-03504

Project/Test Address: 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-03504-008	105L-W-08	Arsenic (As)		<2.00	---	
		Barium (Ba)		<2.00	---	
		Cadmium (Cd)		<2.00	---	
		Chromium (Cr)		<2.00	---	
		Lead (Pb)		<2.00	---	
		Selenium (Se)		<5.00	---	
		Silver (Ag)		<2.00	---	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-06-03504

Project/Test Address: 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
-------------------	----------------------	----------	------------------------------	------------------	-------------------------------------	--------------

Sample Narratives:

Analyst: Brittany Meyer

Method: Mercury (Hg): EPA SW846 7471B

All other metals: EPA SW846 3050B/6010D

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 100mL volume. The reporting limit for Mercury is 0.10ug, Aluminum, Iron and Zinc are 50ug, Antimony and Selenium are 5.0ug and 2.0ug for all other metals.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

Legend	ug = microgram	ug/ft ² = micrograms per square foot
	mL = milliliter	ft ² = square foot

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	816-349-6646	Email	mshanahan@burnsmcd.com
Project Name / Testing Address: Goodfellow IH Services / 4300 Goodfellow Blvd.			
PO Number	168765	Collected By	Jeff Smith
Turn-Around Time	<input checked="" type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES AREA Circle The Unit of Measurement Used cm or (in)	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate		Vol.
																Mins.	L/min.		Total Liters
1	105L-W-01	6/25/2020 1349							Ag, As, Ba, Cd, Cr, Pb, Se									12 x 12	
2	105L-W-02	1355																12 x 12	
3	105L-W-03	1400																12 x 12	
4	105L-W-04	1405																12 x 12	
5	105L-W-05	1410																12 x 12	
6	105L-W-06	1415																12 x 12	
7	105L-W-07	1419																12 x 12	
8	105L-W-08	-																NA x NA	
9																		x	
10																		x	
11																		x	
12																		x	
13																		x	
14																		x	
15																		x	

Released By: Emily Anlemeyer	Date: 6/26/2020	Time: 4:00 PM
Signature: (b) (6)		

LAB USE ONLY - BELOW THIS LINE

Received By: TS Stone

Signature: (b) (6)

Date: 6/29/20 Time: 11:29 AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

20-06-03504

Due Date:
07/02/2020
(Thursday)
EL

APPENDIX C – LICENSES

**STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES**

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Jeffrey T. Smith

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **3/16/2019**
Expiration Date: **3/16/2021**
License Number: **010316-200089640**



(b) (6)

Randall W. Williams, MD, FACOG
Director
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102