

October 24, 2018

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service - Heartland Region
U.S. General Services Administration
2300 Main Street, Kansas City, MO 64108

**RE: Goodfellow Federal Center
Metals in Settled Dust Sampling – Building 103
4300 Goodfellow Boulevard
St. Louis, Missouri 63120
OCCU-TEC Project No. 918004.002**

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 103 located at the Goodfellow Federal Center (GFC), in St. Louis, Missouri. OCCU-TEC, Inc. (OCCU-TEC) understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

On September 20, 2018, a team of OCCU-TEC personnel including a Missouri licensed lead risk assessor conducted settled dust sampling for the presence of seven of the Resource Conservation and Recovery Act (RCRA) target metals (lead, arsenic, barium, cadmium, total chromium, selenium, and silver) from various surfaces within mechanical rooms, basements, penthouses, stairwells leading to and from basements or penthouses, and the sub-floor below the raised flooring. The purpose of this testing was to further characterize the presence and concentration of target metals in areas of the buildings that have had little or no previous testing.

The proposed sampling scheme, the number of samples, the sample distribution and general methodology was developed by GSA and OCCU-TEC. Specific sample locations were determined by OCCU-TEC personnel while on-site.

Metals in Settled Dust Sampling

Metals in settled dust sampling was conducted within mechanical rooms, basements, penthouses, stairwells leading to and from basements or penthouses, and the sub-floor below raised flooring.

Dust wipe sampling was conducted in accordance with ASTM Standard E1728-16: Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination. ASTM Standard E1728-16 is consistent with the methodology described in the Housing and Urban Development Guidelines and 40 CFR 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed during routine janitorial work, and planned maintenance or renovation projects within the building. A representative surface area of approximately one square foot (1 SF) was measured and delineated with pre-fabricated, disposable templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM standards. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth "S" pattern over a measured sampling area. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. The wipe samples were then placed into labeled, clean laboratory-supplied plastic centrifuge tubes with screw on caps. Dust wipe samples were submitted to Scientific Analytical Institute, Inc. (SAI) in Greensboro, North Carolina for Inductively Coupled Plasma (ICP) analysis of metals analysis using Environmental Protection Agency (EPA) method SW846 350B/7420.

Results of the dust wipe samples collected from the building indicate that all the 20 samples contained concentrations of target metals above laboratory detection limits. The following table identifies the range of results for each of the seven metals that were analyzed. **Samples with a "<" sign indicate that the results were below the reportable limit.**

| Analysis | Lowest Concentration (µg/sq. ft.) | Highest Concentration (µg/sq. ft.) |
|----------------|-----------------------------------|------------------------------------|
| Silver | <0.15 | 3.70 |
| Arsenic | <0.25 | 0.33 |
| Barium | 2.80 | 240.00 |
| Cadmium | 0.08 | 31.00 |
| Total Chromium | 0.33 | 84.00 |
| Lead | 1.00 | 730.00 |
| Selenium | <2.50 | <50.00 |

* Please note, these results may indicate higher than expected reporting limits due to interferences from other metals. Please refer to the laboratory reports for specific information.

Many of the samples collected contained target metals above the Brookhaven recommended levels. Based on the results of the sampling, all the subject building areas should be presumed to contain measurable levels of RCRA metals and proper precautions should be taken upon entry and exit of the subject areas to protect workers and limit the spread of dust to the outside environment.

OCCU-TEC appreciates the opportunity to work with GSA on this project. If you have any questions concerning this report, or if we may be of any additional service, please feel free to contact us.

Sincerely,

(b) (6)
[Redacted Signature]

Jeff T. Smith
Senior Project Manager

(b) (6)
[Redacted Signature]

Kevin Heriford
Project Manager (QA/QC)

Appendices:

- A - Sample Summary Table
- B - Laboratory Analysis Reports
- C - Licenses

Appendix

A

Sample Summary Table

Goodfellow Federal Center - Building # 103 - Wipe Sample Data

| Sample Number | Location | Area Description | Analyte | Result | Units | Recommended Limits |
|---------------|--|-------------------------------|----------|---------|--------------------|--------------------|
| 103-01 | Switch Gear Room - Column A8 | Floor | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 5.70 | µg/ft ² | |
| | | | Cadmium | 0.10 | µg/ft ² | ** 31 |
| | | | Chromium | 0.46 | µg/ft ² | |
| | | | Lead | 3.20 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-02 | 2nd Floor Mechanical Room - Column A-6 | Floor | Silver | 3.70 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 14.00 | µg/ft ² | |
| | | | Cadmium | 0.18 | µg/ft ² | ** 31 |
| | | | Chromium | 8.20 | µg/ft ² | |
| | | | Lead | 7.70 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-03 | 1st Floor - at Column D-14 | Floor (under raised flooring) | Silver | 0.23 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 13.00 | µg/ft ² | |
| | | | Cadmium | 0.81 | µg/ft ² | ** 31 |
| | | | Chromium | 3.60 | µg/ft ² | |
| | | | Lead | 21.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-04 | 1st Floor - at Column E-6 | Floor (under raised flooring) | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 2.80 | µg/ft ² | |
| | | | Cadmium | 0.14 | µg/ft ² | ** 31 |
| | | | Chromium | 0.33 | µg/ft ² | |
| | | | Lead | 1.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-05 | 2nd Floor - at Column H-12 | Floor (under raised flooring) | Silver | 0.47 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 14.00 | µg/ft ² | |
| | | | Cadmium | 0.25 | µg/ft ² | ** 31 |
| | | | Chromium | 10.00 | µg/ft ² | |
| | | | Lead | 8.10 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 13.00 | µg/ft ² | |
| 103-06 | 2nd Floor - at Column C-20 | Floor (under raised flooring) | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 5.10 | µg/ft ² | |
| | | | Cadmium | 0.08 | µg/ft ² | ** 31 |
| | | | Chromium | 3.00 | µg/ft ² | |
| | | | Lead | 4.30 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |

| Sample Number | Location | Area Description | Analyte | Result | Units | Recommended Limits |
|---------------|---------------------------------------|-------------------------------|----------|---------|--------------------|--------------------|
| 103-07 | 2nd Floor Mechanical Room - ColumnE-7 | Top of switch gear | Silver | 0.51 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 5.10 | µg/ft ² | |
| | | | Cadmium | 1.30 | µg/ft ² | ** 31 |
| | | | Chromium | 1.10 | µg/ft ² | |
| | | | Lead | 4.50 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-08 | Stairwell to Penthouse A | Middle Landing | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 4.60 | µg/ft ² | |
| | | | Cadmium | 0.39 | µg/ft ² | ** 31 |
| | | | Chromium | 1.00 | µg/ft ² | |
| | | | Lead | 7.70 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-09 | Stairs to Penthouse A | Top Landing | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | 0.33 | µg/ft ² | ** 62 |
| | | | Barium | 11.00 | µg/ft ² | |
| | | | Cadmium | 1.00 | µg/ft ² | ** 31 |
| | | | Chromium | 4.80 | µg/ft ² | |
| | | | Lead | 20.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 13.00 | µg/ft ² | |
| 103-10 | Stairs to Basement at Column J-21 | Middle Landing | Silver | < 0.75 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 2.50 | µg/ft ² | ** 62 |
| | | | Barium | 100.00 | µg/ft ² | |
| | | | Cadmium | 2.20 | µg/ft ² | ** 31 |
| | | | Chromium | 53.00 | µg/ft ² | |
| | | | Lead | 280.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 25.00 | µg/ft ² | |
| 103-11 | Stairs to Basement at Column A-21 | Lower Landing | Silver | < 0.75 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 2.50 | µg/ft ² | ** 62 |
| | | | Barium | 210.00 | µg/ft ² | |
| | | | Cadmium | 4.60 | µg/ft ² | ** 31 |
| | | | Chromium | 51.00 | µg/ft ² | |
| | | | Lead | 710.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 50.00 | µg/ft ² | |
| 103-12 | 1st Floor - at Column G-32 | Floor (under raised flooring) | Silver | 0.42 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 25.00 | µg/ft ² | ** 62 |
| | | | Barium | 240.00 | µg/ft ² | |
| | | | Cadmium | 31.00 | µg/ft ² | ** 31 |
| | | | Chromium | 41.00 | µg/ft ² | |
| | | | Lead | 730.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |

| Sample Number | Location | Area Description | Analyte | Result | Units | Recommended Limits |
|---------------|------------------------|------------------------|----------|---------|--------------------|--------------------|
| 103-13 | Stairs for Penthouse E | Middle Landing | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 15.00 | µg/ft ² | |
| | | | Cadmium | 4.30 | µg/ft ² | ** 31 |
| | | | Chromium | 2.40 | µg/ft ² | |
| | | | Lead | 13.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-14 | Stairs to Penthouse E | Top Landing | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 13.00 | µg/ft ² | |
| | | | Cadmium | 7.30 | µg/ft ² | ** 31 |
| | | | Chromium | 2.40 | µg/ft ² | |
| | | | Lead | 18.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-15 | Penthouse E | Floor | Silver | 1.40 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 2.50 | µg/ft ² | ** 62 |
| | | | Barium | 120.00 | µg/ft ² | |
| | | | Cadmium | 3.40 | µg/ft ² | ** 31 |
| | | | Chromium | 34.00 | µg/ft ² | |
| | | | Lead | 310.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 13.00 | µg/ft ² | |
| 103-16 | Penthouse D | Top of Dry Transformer | Silver | 0.22 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 1.30 | µg/ft ² | ** 62 |
| | | | Barium | 30.00 | µg/ft ² | |
| | | | Cadmium | 1.70 | µg/ft ² | ** 31 |
| | | | Chromium | 5.30 | µg/ft ² | |
| | | | Lead | 22.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-17 | Penthouse B | Floor | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | 0.31 | µg/ft ² | ** 62 |
| | | | Barium | 33.00 | µg/ft ² | |
| | | | Cadmium | 0.34 | µg/ft ² | ** 31 |
| | | | Chromium | 22.00 | µg/ft ² | |
| | | | Lead | 17.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-18 | Penthouse C | Floor | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 27.00 | µg/ft ² | |
| | | | Cadmium | 1.50 | µg/ft ² | ** 31 |
| | | | Chromium | 84.00 | µg/ft ² | |
| | | | Lead | 31.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 13.00 | µg/ft ² | |

| Sample Number | Location | Area Description | Analyte | Result | Units | Recommended Limits |
|---------------|-----------------------------------|------------------|----------|---------|--------------------|--------------------|
| 103-19 | 1st Floor - North Mechanical Room | Chiller | Silver | 0.74 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 1.30 | µg/ft ² | ** 62 |
| | | | Barium | 39.00 | µg/ft ² | |
| | | | Cadmium | 0.79 | µg/ft ² | ** 31 |
| | | | Chromium | 7.70 | µg/ft ² | |
| | | | Lead | 48.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |
| 103-20 | 1st Floor -North Mechanical Room | Floor | Silver | < 0.75 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 52.00 | µg/ft ² | |
| | | | Cadmium | 0.67 | µg/ft ² | ** 31 |
| | | | Chromium | 19.00 | µg/ft ² | |
| | | | Lead | 24.00 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 13.00 | µg/ft ² | |
| 103-21 | Field Blank | | Silver | < 0.15 | µg/ft ² | * 139/9.3 |
| | | | Arsenic | < 0.25 | µg/ft ² | ** 62 |
| | | | Barium | 1.00 | µg/ft ² | |
| | | | Cadmium | < 0.05 | µg/ft ² | ** 31 |
| | | | Chromium | < 0.10 | µg/ft ² | |
| | | | Lead | < 0.25 | µg/ft ² | ** 200/40 |
| | | | Selenium | < 2.50 | µg/ft ² | |

* Recommended Limits based on Table 3 (BNL Surface Wipe Criteria for Metals) of the Brookhaven Surface Wipe Sampling Procedure (IH75190), Rev 19: 3/4/14

** Recommended Limits based on Attachment 9.3 (Required & Recommended Surface Wipe Criteria) - Brookhaven Surface Wipe Sampling Procedure (IH75190), Rev 23: 6/23/17

Indicates results at or above REL

Appendix

B

Laboratory
Analytical
Reports



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



| | | |
|---|----------------------------|--|
| Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150 Project: 918004.002 Building 103 | Attn: Justin Arnold | Lab Order ID: 51824510 Date Received: 09/24/2018 Date Reported: 10/16/2018 Page: 1 of 7 |
|---|----------------------------|--|

| Sample ID | Description | Area (ft ²) | *Element | Reporting Limit (µg) | Concentration (µg) | Concentration (µg/ft ²) |
|---------------|---|-------------------------|----------|----------------------|--------------------|-------------------------------------|
| Lab Sample ID | Lab Notes | | | | | |
| 103-01 | Switch Gear Room Column A 8 Floor | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.050 | 5.7 | 5.7 |
| | | | Cd | 0.050 | 0.095 | 0.095 |
| | | | Cr | 0.10 | 0.46 | 0.46 |
| 51824510IPW_1 | | | Pb | 0.25 | 3.2 | 3.2 |
| | | | Se | 2.5 | < 2.5 | < 2.5 |
| 103-02 | 2 nd Floor Mechanical Room Floor Col A 6 | 1 | Ag | 0.15 | 3.7 | 3.7 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.25 | 14 | 14 |
| | | | Cd | 0.050 | 0.18 | 0.18 |
| | | | Cr | 0.10 | 8.2 | 8.2 |
| 51824510IPW_2 | | | Pb | 0.25 | 7.7 | 7.7 |
| | | | Se | 2.5 | < 2.5 | < 2.5 |
| 103-03 | 1 st Floor Under Raised Floor Col D 14 | 1 | Ag | 0.15 | 0.23 | 0.23 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.25 | 13 | 13 |
| | | | Cd | 0.050 | 0.81 | 0.81 |
| | | | Cr | 0.10 | 3.6 | 3.6 |
| 51824510IPW_3 | | | Pb | 0.25 | 21 | 21 |
| | | | Se | 2.5 | < 2.5 | < 2.5 |

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



| | | |
|--|----------------------------|----------------------------------|
| Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150 | Attn: Justin Arnold | Lab Order ID: 51824510 |
| Project: 918004.002 Building 103 | | Date Received: 09/24/2018 |
| | | Date Reported: 10/16/2018 |
| | | Page: 2 of 7 |

| Sample ID | Description | Area (ft ²) | *Element | Reporting Limit (µg) | Concentration (µg) | Concentration (µg/ft ²) |
|---------------|---|-------------------------|----------|----------------------|--------------------|-------------------------------------|
| Lab Sample ID | Lab Notes | | | | | |
| 103-04 | 1 st Floor Under Raised Floor Col E 6 | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.050 | 2.8 | 2.8 |
| | | | Cd | 0.050 | 0.14 | 0.14 |
| | | | Cr | 0.10 | 0.33 | 0.33 |
| 51824510IPW_4 | | | Pb | 0.25 | 1.0 | 1.0 |
| | | | Se | 2.5 | < 2.5 | < 2.5 |
| 103-05 | 2 nd Floor Under Raised Floor Col H 12 | 1 | Ag | 0.15 | 0.47 | 0.47 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.25 | 14 | 14 |
| | | | Cd | 0.050 | 0.25 | 0.25 |
| | | | Cr | 0.10 | 10. | 10. |
| 51824510IPW_5 | | | Pb | 0.25 | 8.1 | 8.1 |
| | | | Se* | 13 | < 13 | < 13 |
| 103-06 | 2 nd Floor Under Raised Floor Col C 20 | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.050 | 5.1 | 5.1 |
| | | | Cd | 0.050 | 0.076 | 0.076 |
| | | | Cr | 0.10 | 3.0 | 3.0 |
| 51824510IPW_6 | | | Pb | 0.25 | 4.3 | 4.3 |
| | | | Se | 2.5 | < 2.5 | < 2.5 |

*Se – elevated RL possibly due to high levels of Al interference

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



| | | |
|---|----------------------------|--|
| Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150 Project: 918004.002 Building 103 | Attn: Justin Arnold | Lab Order ID: 51824510 Date Received: 09/24/2018 Date Reported: 10/16/2018 Page: 3 of 7 |
|---|----------------------------|--|

| Sample ID | Description | Area (ft ²) | *Element | Reporting Limit (µg) | Concentration (µg) | Concentration (µg/ft ²) |
|---------------|--|-------------------------|---------------|----------------------|--------------------|-------------------------------------|
| Lab Sample ID | Lab Notes | | | | | |
| 103-07 | 2 nd Floor Mech Room top of Switch Gear E 7 | 1 | Ag | 0.15 | 0.51 | 0.51 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.25 | 5.1 | 5.1 |
| | | | Cd | 0.050 | 1.3 | 1.3 |
| | | | Cr | 0.10 | 1.1 | 1.1 |
| | | | 51824510IPW_7 | | | Pb |
| | | | Se | 2.5 | < 2.5 | < 2.5 |
| 103-08 | Stairs to Penthouse A Middle Landing | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.050 | 4.6 | 4.6 |
| | | | Cd | 0.050 | 0.39 | 0.39 |
| | | | Cr | 0.10 | 1.0 | 1.0 |
| | | | 51824510IPW_8 | | | Pb |
| | | | Se | 2.5 | < 2.5 | < 2.5 |
| 103-09 | Stairs to Penthouse A Top Landing | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | 0.33 | 0.33 |
| | | | Ba | 0.25 | 11 | 11 |
| | | | Cd | 0.050 | 1.0 | 1.0 |
| | | | Cr | 0.10 | 4.8 | 4.8 |
| | | | 51824510IPW_9 | | | Pb |
| | | | Se* | 13 | < 13 | < 13 |

*Se – elevated RL possibly due to high levels of Al interference

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



| | | |
|--|----------------------------|----------------------------------|
| Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150 | Attn: Justin Arnold | Lab Order ID: 51824510 |
| Project: 918004.002 Building 103 | | Date Received: 09/24/2018 |
| | | Date Reported: 10/16/2018 |
| | | Page: 4 of 7 |

| Sample ID | Description | Area (ft ²) | *Element | Reporting Limit (µg) | Concentration (µg) | Concentration (µg/ft ²) |
|---------------|---|-------------------------|----------------|----------------------|--------------------|-------------------------------------|
| Lab Sample ID | Lab Notes | | | | | |
| 103-10 | Stairs to Basement Middle Landing J 21 | 1 | Ag* | 0.75 | < 0.75 | < 0.75 |
| | | | As* | 2.5 | < 2.5 | < 2.5 |
| | | | Ba | 2.5 | 100 | 100 |
| | | | Cd | 0.050 | 2.2 | 2.2 |
| | | | Cr | 1.0 | 53 | 53 |
| | | | 51824510IPW_10 | | | Pb |
| | | | Se* | 25 | < 25 | < 25 |
| 103-11 | Stairs to Basement Lower Landing A 21 | 1 | Ag* | 0.75 | < 0.75 | < 0.75 |
| | | | As* | 2.5 | < 2.5 | < 2.5 |
| | | | Ba | 2.5 | 210 | 210 |
| | | | Cd | 0.050 | 4.6 | 4.6 |
| | | | Cr | 1.0 | 51 | 51 |
| | | | 51824510IPW_11 | | | Pb |
| | | | Se* | 50. | < 50. | < 50. |
| 103-12 | 1 st Floor Under Raised Floor G 32 | 1 | Ag | 0.15 | 0.42 | 0.42 |
| | | | As* | 25 | < 25 | < 25 |
| | | | Ba | 5.0 | 240 | 240 |
| | | | Cd | 0.50 | 31 | 31 |
| | | | Cr | 1.0 | 41 | 41 |
| | | | 51824510IPW_12 | | | Pb |
| | | | Se | 2.5 | < 2.5 | < 2.5 |

*Ag – elevated RL possibly due to high levels of Er and/or Fe interference *As – elevated RL possibly due to high levels of Pd interference
*Se – elevated RL possibly due to high levels of Al interferences

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



| | | |
|--|----------------------------|----------------------------------|
| Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150 | Attn: Justin Arnold | Lab Order ID: 51824510 |
| Project: 918004.002 Building 103 | | Date Received: 09/24/2018 |
| | | Date Reported: 10/16/2018 |
| | | Page: 5 of 7 |

| Sample ID | Description | Area (ft ²) | *Element | Reporting Limit (µg) | Concentration (µg) | Concentration (µg/ft ²) |
|---------------|--------------------------------------|-------------------------|----------------|----------------------|--------------------|-------------------------------------|
| Lab Sample ID | Lab Notes | | | | | |
| 103-13 | Stairs to Penthouse E Middle Landing | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.25 | 15 | 15 |
| | | | Cd | 0.050 | 4.3 | 4.3 |
| | | | Cr | 0.10 | 2.4 | 2.4 |
| | | | 51824510IPW_13 | | Pb | 0.25 |
| | | Se | 2.5 | < 2.5 | < 2.5 | |
| 103-14 | Stairs to Penthouse E Top Landing | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.25 | 13 | 13 |
| | | | Cd | 0.050 | 7.3 | 7.3 |
| | | | Cr | 0.10 | 2.4 | 2.4 |
| | | | 51824510IPW_14 | | Pb | 0.25 |
| | | Se | 2.5 | < 2.5 | < 2.5 | |
| 103-15 | Penthouse E Floor | 1 | Ag | 0.15 | 1.4 | 1.4 |
| | | | As* | 2.5 | < 2.5 | < 2.5 |
| | | | Ba | 2.5 | 120 | 120 |
| | | | Cd | 0.050 | 3.4 | 3.4 |
| | | | Cr | 0.50 | 34 | 34 |
| | | | 51824510IPW_15 | | Pb | 5.0 |
| | | Se* | 13 | < 13 | < 13 | |

*As – elevated RL possibly due to high levels of Pd interference

*Se – elevated RL possibly due to high levels of Al interferences

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



| | | |
|--|----------------------------|----------------------------------|
| Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150 | Attn: Justin Arnold | Lab Order ID: 51824510 |
| Project: 918004.002 Building 103 | | Date Received: 09/24/2018 |
| | | Date Reported: 10/16/2018 |
| | | Page: 6 of 7 |

| Sample ID | Description | Area (ft ²) | *Element | Reporting Limit (µg) | Concentration (µg) | Concentration (µg/ft ²) |
|----------------|-----------------------------------|----------------------------|----------|----------------------------|-----------------------|--|
| Lab Sample ID | Lab Notes | | | | | |
| 103-16 | Penthouse D Dry Transformer | 1 | Ag | 0.15 | 0.22 | 0.22 |
| | | | As* | 1.3 | < 1.3 | < 1.3 |
| | | | Ba | 0.50 | 30. | 30. |
| | | | Cd | 0.050 | 1.7 | 1.7 |
| | | | Cr | 0.10 | 5.3 | 5.3 |
| 51824510IPW_16 | | | Pb | 0.25 | 22 | 22 |
| | | | Se | 2.5 | < 2.5 | < 2.5 |
| 103-17 | Penthouse B Floor | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | 0.31 | 0.31 |
| | | | Ba | 0.50 | 33 | 33 |
| | | | Cd | 0.050 | 0.34 | 0.34 |
| | | | Cr | 1.0 | 22 | 22 |
| 51824510IPW_17 | | | Pb | 0.25 | 17 | 17 |
| | | | Se | 2.5 | < 2.5 | < 2.5 |
| 103-18 | Penthouse C Floor | 1 | Ag | 0.15 | < 0.15 | < 0.15 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 0.50 | 27 | 27 |
| | | | Cd | 0.050 | 1.5 | 1.5 |
| | | | Cr | 1.0 | 84 | 84 |
| 51824510IPW_18 | | | Pb | 0.25 | 31 | 31 |
| | | | Se* | 13 | < 13 | < 13 |

*As – elevated RL possibly due to high levels of Pd interference

*Se – elevated RL possibly due to high levels of Al interferences

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



| | | |
|--|----------------------------|----------------------------------|
| Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150 | Attn: Justin Arnold | Lab Order ID: 51824510 |
| Project: 918004.002 Building 103 | | Date Received: 09/24/2018 |
| | | Date Reported: 10/16/2018 |
| | | Page: 7 of 7 |

| Sample ID | Description | Area (ft ²) | *Element | Reporting Limit (µg) | Concentration (µg) | Concentration (µg/ft ²) |
|----------------|---|-------------------------|----------|----------------------|--------------------|-------------------------------------|
| Lab Sample ID | Lab Notes | | | | | |
| 103-19 | 1 st Floor N Chiller Mech Room | 1 | Ag | 0.15 | 0.74 | 0.74 |
| | | | As* | 1.3 | < 1.3 | < 1.3 |
| | | | Ba | 0.50 | 39 | 39 |
| | | | Cd | 0.050 | 0.79 | 0.79 |
| | | | Cr | 0.10 | 7.7 | 7.7 |
| 51824510IPW_19 | | | Pb | 1.3 | 48 | 48 |
| | | | Se | 2.5 | < 2.5 | < 2.5 |
| 103-20 | 1 st Floor N Mech Room Floor | 1 | Ag* | 0.75 | < 0.75 | < 0.75 |
| | | | As | 0.25 | < 0.25 | < 0.25 |
| | | | Ba | 1.0 | 52 | 52 |
| | | | Cd | 0.050 | 0.67 | 0.67 |
| | | | Cr | 0.50 | 19 | 19 |
| 51824510IPW_20 | | | Pb | 0.25 | 24 | 24 |
| | | | Se* | 13 | < 13 | < 13 |
| 103-21 | BLANK | - | Ag | 0.15 | < 0.15 | - |
| | | | As | 0.25 | < 0.25 | - |
| | | | Ba | 0.050 | 1.0 | - |
| | | | Cd | 0.050 | < 0.050 | - |
| | | | Cr | 0.10 | < 0.10 | - |
| 51824510IPW_21 | | | Pb | 0.25 | < 0.25 | - |
| | | | Se | 2.5 | < 2.5 | - |

*Ag – elevated RL possibly due to high levels of Er and/or Fe interference *As – elevated RL possibly due to high levels of Pd interference
*Se – elevated RL possibly due to high levels of Al interferences

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Scientific Analytical Institute, Inc.

4604 Dundas Dr. Greensboro, NC 27407
Phone: 336.292.3888 Fax: 336.292.3313
www.sailab.com lab@sailab.com

Lab Use Only
Lab Order ID: 51824510
Client Code: _____

| Company Contact Information | |
|------------------------------------|---|
| Company: OCCU-TEC Inc. | Contact: Justin Arnold |
| Address: 100 NW Business Park Lane | Phone <input type="checkbox"/> : 816-810-3276 |
| Riverside, Mo 64150 | Fax <input type="checkbox"/> : 816-994-3478 |
| | Email : jarnold@occutec.com |

| Industrial Hygiene Test Types | |
|--|---|
| Silica as Alpha Quartz (XSZ)* <input type="checkbox"/> | With Respirable Dust (XDZ) <input type="checkbox"/> |
| Silica as Cristobalite (XSC)* <input type="checkbox"/> | With Respirable Dust (XDC) <input type="checkbox"/> |
| Silica as Tridymite (XST)* <input type="checkbox"/> | With Respirable Dust (XDT) <input type="checkbox"/> |
| Silica as Alpha Quartz, Cristobalite, Tridymite (XSA)* <input type="checkbox"/> | With Respirable Dust (XDA) <input type="checkbox"/> |
| Silica Bulk (XSI)* <input type="checkbox"/> | |
| Bulk Phase ID/Whole Rock (XUK) <input type="checkbox"/> | |
| Total Dust NIOSH Method 0500 (GTD) <input type="checkbox"/> | |
| Respirable Dust NIOSH Method 0600 (GRD) <input type="checkbox"/> | |
| PCM NIOSH 7400-A Rules (PCM) <input type="checkbox"/> | |
| B Rules (PCB) <input type="checkbox"/> | TWA (PTA) <input type="checkbox"/> |
| TEM NIOSH 7402 (Asbestos) (TNI) <input type="checkbox"/> | |
| Hexavalent Chromium (OSHA ID-215) (Note if from spray paint operations) <input type="checkbox"/> | |
| Metals (NIOSH 7300) (Specify Metals Under Comments) <input type="checkbox"/> | |
| Other 6010 C <input checked="" type="checkbox"/> | |
| * Modified NIOSH 7500/OSHA ID 142 | |

| Billing/Invoice Information | Turn Around Times [^] | |
|--|--|--|
| SAME <input checked="" type="checkbox"/> | 90 Min. <input type="checkbox"/> | 48 Hours <input type="checkbox"/> |
| Company: | 3 Hours <input type="checkbox"/> | 72 Hours <input type="checkbox"/> |
| Contact: | 6 Hours <input type="checkbox"/> | 96 Hours <input type="checkbox"/> |
| Address: | 12 Hours <input type="checkbox"/> | 120 Hours <input type="checkbox"/> |
| | 24 Hours <input type="checkbox"/> | 144 ⁺ Hours <input checked="" type="checkbox"/> |
| | [^] TATs not available for certain test types | |

PO Number: _____
Project Name/Number: 918004.002 Building 103

| Sample ID # | Description/Location | Volume/Area | Comments |
|-------------|---|-------------|----------------------------|
| 103-01 | Switch Gear Room Column A/B Floor | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-02 | 2 nd floor Mechanical Room Floor Col A/C | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-03 | 1 st floor Under Raised Floor Col D14 | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-04 | 1 st floor Under Raised Floor Col E6 | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-05 | 2 nd floor Under Raised Floor Col H12 | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-06 | 2 nd floor Under Raised Floor Col C20 | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-07 | 2 nd floor Mech Room top of Switch gear E7 | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-08 | Stairs to Penthouse A middle landing | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-09 | Stairs to Penthouse A Top landing | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-10 | Stairs to basement middle landing J21 | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-11 | Stairs to basement lower landing A21 | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-12 | 1 st floor Under raised floor G32 | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |
| 103-13 | Stairs to Penthouse E middle landing | 1SF | Ag, As, Ba, Cd, Cr, Pb, Se |

Total # of Samples _____

| | | | |
|--------------------------|-----------|---------|---------------|
| Relinquished by: (b) (6) | Date/Time | (b) (6) | Date/Time |
| | | | 9-24 10:30 |

Accepted
Rejected

Page 1 of 2

Appendix

C

Qualifications and
Licenses

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Justin E. Arnold

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **6/11/2018**
Expiration Date: **6/11/2020**
License Number: **120611-300003622**

(b) (6)



Randall W. Williams, MD, FACOG
Director
Department of Health and Senior Services