

October 10, 2018

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service - Heartland Region
U.S. General Services Administration
2300 Main Street, Kansas City, MO 64108

**RE: Goodfellow Federal Center
Metals in Settled Dust Sampling – Building 105L
4300 Goodfellow Boulevard
St. Louis, Missouri 63120
OCCU-TEC Project No. 918004.002**

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 105L located at the Goodfellow Federal Center (GFC), in St. Louis, Missouri. OCCU-TEC understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

On September 14, 2018, a team of OCCU-TEC personnel including a Missouri licensed lead risk assessor conducted settled dust sampling for the presence of seven of the Resource Conservation and Recovery Act (RCRA) target metals (lead, arsenic, barium, cadmium, total chromium, selenium, and silver) from various surfaces within mechanical rooms, basements, penthouses, stairwells leading to and from basements or penthouses, and the sub-floor below the raised flooring. The purpose of this testing was to further characterize the presence and concentration of target metals in areas of the buildings that have had little or no previous testing.

The proposed sampling scheme, the number of samples, the sample distribution and general methodology was developed by GSA and OCCU-TEC. Specific sample locations were determined by OCCU-TEC personnel while on-site.

Metals in Settled Dust Sampling

Metals in settled dust sampling was conducted within mechanical rooms, basements, penthouses, stairwells leading to and from basements or penthouses, and the sub-floor below raised flooring.

Dust wipe sampling was conducted in accordance with ASTM Standard E1728-16: Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination. ASTM Standard E1728-16 is consistent with the methodology described in the Housing and Urban Development Guidelines and 40 CRF 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed during routine janitorial work, and planned maintenance or renovation projects within the building. A representative surface area of approximately one square foot (1 SF) was measured and delineated with pre-fabricated, disposable templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM standards. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth "S" pattern over a measured sampling area of approximately 1 SF. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. The wipe samples were then placed into labeled, clean laboratory-supplied plastic centrifuge tubes with screw on caps. Dust wipe samples were submitted to Scientific Analytical Institute, Inc. (SAI) in Greensboro, North Carolina for Inductively Coupled Plasma (ICP) total analysis of metals analysis according to Environmental Protection Agency (EPA) method SW846 350B/7420.

Results of the dust wipe samples collected from the building indicate that both of the samples contained concentrations of target metals above laboratory detection limits. The following table identifies the range of results for each of the seven metals that were sampled. **Samples with a "<" sign indicate that the results were below the reportable limit.**

Analysis	Lowest Concentration (µg/sq. ft.)	Highest Concentration (µg/sq. ft.)
Silver	6.50	7.00
Arsenic	<0.25	2.30
Barium	5.40	45.00
Cadmium	<0.05	2.60
Total Chromium	9.80	27.00
Lead	2.50	57.00
Selenium	<0.50	<2.50

- Please note, these results may indicate higher than expected reporting limits due to interferences from other metals. Please refer to the laboratory reports for specific information.

One of the samples collected contained target metals above the regulatory or recommended levels. Based on the results of the sampling, all the subject building areas should be presumed to contain measurable levels of RCRA metals and proper precautions should be taken upon entry and exit of the subject areas to protect workers and limit the spread of dust to the outside environment.

OCCU-TEC appreciates the opportunity to work with GSA on this project. If you have any questions concerning this report, or if we may be of any additional service, please feel free to contact us.

Sincerely,

(b) (6)
[Redacted Signature]

Jeff T. Smith
Senior Project Manager

(b) (6)
[Redacted Signature]

Jay Hurst
Director of Operations (QA/QC)

Appendices:

- A - Sample Summary Table
- B - Laboratory Analysis Reports
- C - Licenses

Appendix

A

Sample Summary Table

Goodfellow Federal Center - Building #105L - Wipe Sample Data

Sample Number	Location	Area Description	Analyte	Result	Units	Recommended Limits
105L-01	Mechanical Room	Top of air-handling unit in SE corner of room	Silver	6.50	µg/ft ²	* 139/9.3
			Arsenic	< 0.25	µg/ft ²	** 62
			Barium	5.40	µg/ft ²	
			Cadmium	< 0.05	µg/ft ²	** 31
			Chromium	9.80	µg/ft ²	
			Lead	2.50	µg/ft ²	** 200/40
			Selenium	< 0.50	µg/ft ²	
105L-02	Mechanical Room	Floor - Southeast Corner behind AHU	Silver	7.00	µg/ft ²	* 139/9.3
			Arsenic	2.30	µg/ft ²	** 62
			Barium	45.00	µg/ft ²	
			Cadmium	2.60	µg/ft ²	** 31
			Chromium	27.00	µg/ft ²	
			Lead	57.00	µg/ft ²	** 200/40
			Selenium	< 2.50	µg/ft ²	
105L-03	Field Blank		Silver	< 0.50	µg/ft ²	* 139/9.3
			Arsenic	< 0.25	µg/ft ²	** 62
			Barium	0.59	µg/ft ²	
			Cadmium	< 0.05	µg/ft ²	** 31
			Chromium	< 0.50	µg/ft ²	
			Lead	< 0.25	µg/ft ²	** 200/40
			Selenium	< 0.50	µg/ft ²	

* Recommended Limits based on Table 3 (BNL Surface Wipe Criteria for Metals) of the Brookhaven Surface Wipe Sampling Procedure (IH75190), Rev 19: 3/4/14

** Recommended Limits based on Attachment 9.3 (Required & Recommended Surface Wipe Criteria) - Brookhaven Surface Wipe Sampling Procedure (IH75190), Rev 23: 6/23/17

Indicates results at or above REL

Appendix

B

Laboratory
Analytical
Reports



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150	Attn: Justin Arnold	Lab Order ID: 51824373
Project: 918004.002 Bldg 105 L		Date Received: 09/20/2018
		Date Reported: 10/05/2018
		Page: 1 of 1

Sample ID	Description	Area (ft ²)	*Element	Reporting Limit (µg)	Concentration (µg)	Concentration (µg/ft ²)
Lab Sample ID	Lab Notes					
105L-01	Top of AHU unit	1	Ag	0.50	6.5	6.5
			As	0.25	< 0.25	< 0.25
			Ba	0.050	5.4	5.4
			Cd	0.050	< 0.050	< 0.050
			Cr	0.50	9.8	9.8
51824373IPW_1			Pb	0.25	2.5	2.5
			Se	0.50	< 0.50	< 0.50
105L-02	Floor – SE corner	1	Ag	0.50	7.0	7.0
			As*	1.3	2.3	2.3
			Ba	0.50	45	45
			Cd	0.050	2.6	2.6
			Cr	2.5	27	27
51824373IPW_2			Pb	2.5	57	57
			Se*	2.5	< 2.5	< 2.5
105L-03	Field Blank	-	Ag	0.50	< 0.50	-
			As	0.25	< 0.25	-
			Ba	0.050	0.59	-
			Cd	0.050	< 0.050	-
			Cr	0.50	< 0.50	-
51824373IPW_3			Pb	0.25	< 0.25	-
			Se	0.50	< 0.50	-

*As – elevated RL possibly due to high levels of Pd interference

*Se – elevated RL possibly due to high levels of Al interference

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Scientific Analytical Institute, Inc.

4604 Dundas Dr. Greensboro, NC 27407
 Phone: 336.292.3888 Fax: 336.292.3313
 www.sailab.com lab@sailab.com

Lab Use Only
 Lab Order ID: 51824373
 Client Code: _____

Company Contact Information	
Company: OCCU-TEC Inc.	Contact: Justin Arnold
Address: 100 NW Business Park Lane	Phone ☐: 816-810-3276
Riverside, Mo 64150	Fax ☐: 816-994-3478
	Email :jarnold@occutec.com

Industrial Hygiene Test Types	
Silica as Alpha Quartz (XSZ)* ☐ With Respirable Dust (XDZ) ☐	
Silica as Cristobalite (XSC)* ☐ With Respirable Dust (XDC) ☐	
Silica as Tridymite (XST)* ☐ With Respirable Dust (XDT) ☐	
Silica as Alpha Quartz, Cristobalite, Tridymite (XSA)* ☐ With Respirable Dust (XDA) ☐	
Silica Bulk (XSI)*	☐
Bulk Phase ID/Whole Rock (XUK)	☐
Total Dust NIOSH Method 0500 (GTD)	☐
Respirable Dust NIOSH Method 0600 (GRD)	☐
PCM NIOSH 7400-A Rules (PCM)	☐
B Rules (PCB) ☐ TWA (PTA) ☐	
TEM NIOSH 7402 (Asbestos) (TNI)	☐
Hexavalent Chromium (OSHA ID-215) (Note if from spray paint operations)	☐
Metals (NIOSH 7300) (Specify Metals Under Comments)	☐
Other 6010 C	☒

* Modified NIOSH 7500/OSHA ID 142

Billing/Invoice Information	Turn Around Times^	
SAME ☒	90 Min. ☐	48 Hours ☐
Company:	3 Hours ☐	72 Hours ☐
Contact:	6 Hours ☐	96 Hours ☐
Address:	12 Hours ☐	120 Hours ☐
	24 Hours ☐	144+ Hours ☒
^TATs not available for certain test types		
PO Number:		
Project Name/Number: 918004.002 Bldg 105L		

Sample ID #	Description/Location	Volume/Area	Comments
			Ag, As, Ba, Cd, Cr, Pb, Se
105L-01	Top of AHU unit	1 SF	Ag, As, Ba, Cd, Cr, Pb, Se
105L-02	Floor - SE corner	1 SF	Ag, As, Ba, Cd, Cr, Pb, Se
105L-03	Field Blank	—	Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se

Accepted ☒
 Rejected ☐

Total # of Samples _____			
Relinquished by (b) (6)	Date/Time 9-17-20	Received by (b) (6)	Date/Time 9-20 10:30

Appendix

C

Qualifications and
Licenses

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Jeffrey T. Smith

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **3/16/2017**
Expiration Date: **3/16/2019**
License Number: **010316-200089640**

(b) (6)

Randall W. Williams, MD, FACOG
Acting Director
Department of Health and Senior Services



Lead Licensing Program, PO Box 570, Jefferson City, MO 65102