

October 12, 2018

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service - Heartland Region
U.S. General Services Administration
2300 Main Street, Kansas City, MO 64108

**RE: Goodfellow Federal Center
Metals in Settled Dust Sampling – Building 108B
4300 Goodfellow Boulevard
St. Louis, Missouri 63120
OCCU-TEC Project No. 918004.002**

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 108B located at the Goodfellow Federal Center (GFC), in St. Louis, Missouri. OCCU-TEC understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

On September 13, 2018, a team of OCCU-TEC personnel including a Missouri licensed lead risk assessor conducted settled dust sampling for the presence of seven of the Resource Conservation and Recovery Act (RCRA) target metals (lead, arsenic, barium, cadmium, total chromium, selenium, and silver) from various surfaces within mechanical rooms, basements, penthouses, stairwells leading to and from basements or penthouses, and the sub-floor below the raised flooring. The purpose of this testing was to further characterize the presence and concentration of target metals in areas of the buildings that have had little or no previous testing.

The proposed sampling scheme, the number of samples, the sample distribution and general methodology was developed by GSA and OCCU-TEC. Specific sample locations were determined by OCCU-TEC personnel while on-site.

Metals in Settled Dust Sampling

Metals in settled dust sampling was conducted within mechanical rooms, basements, penthouses, stairwells leading to and from basements or penthouses, and the sub-floor below raised flooring.

Dust wipe sampling was conducted in accordance with ASTM Standard E1728-16: Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination. ASTM Standard E1728-16 is consistent with the methodology described in the Housing and Urban Development Guidelines and 40 CRF 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed during routine janitorial work, and planned maintenance or renovation projects within the building. A representative surface area of approximately one square foot (1 SF) was measured and delineated with pre-fabricated, disposable templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM standards. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth "S" pattern over a measured sampling area of approximately 1 SF. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. The wipe samples were then placed into labeled, clean laboratory-supplied plastic centrifuge tubes with screw on caps. Dust wipe samples were submitted to Scientific Analytical Institute, Inc. (SAI) in Greensboro, North Carolina for Inductively Coupled Plasma (ICP) total analysis of metals analysis according to Environmental Protection Agency (EPA) method SW846 350B/7420.

Results of the dust wipe samples collected from the building indicate that all the four samples contained concentrations of target metals above laboratory detection limits. The following table identifies the range of results for each of the seven metals that were sampled. **Samples with a "<" sign indicate that the results were below the reportable limit.**

Analysis	Lowest Concentration (µg/sq. ft.)	Highest Concentration (µg/sq. ft.)
Silver	<0.72	0.92
Arsenic	2.00	3.30
Barium	47.00	180.00
Cadmium	4.40	20.00
Total Chromium	31.00	47.00
Lead	130.00	290.00
Selenium	<1.00	<2.50

- Please note, these results may indicate higher than expected reporting limits due to interferences from other metals. Please refer to the laboratory reports for specific information.

All of the samples collected contained target metals above the regulatory or recommended levels. Based on the results of the sampling, all the subject building areas should be presumed to contain measurable levels of RCRA metals and proper precautions should be taken upon entry and exit of the subject areas to protect workers and limit the spread of dust to the outside environment.

OCCU-TEC appreciates the opportunity to work with GSA on this project. If you have any questions concerning this report, or if we may be of any additional service, please feel free to contact us.

Sincerely,

(b) (6)

Jeff T. Smith
Senior Project Manager

(b) (6)

Jay Hurst
Director of Operations (QA/QC)

Appendices:

- A - Sample Summary Table
- B - Laboratory Analysis Reports
- C - Licenses

Appendix

A

Sample Summary Table

Goodfellow Federal Center - Building # 108B - Wipe Sample Data

Sample Number	Location	Area Description	Analyte	Result	Units	Recommended Limits
108B-01	East Equipment Room	Floor - Northeast Corner	Silver	0.92	µg/ft ²	* 139/9.3
			Arsenic	2.00	µg/ft ²	** 62
			Barium	48.00	µg/ft ²	
			Cadmium	5.20	µg/ft ²	** 31
			Chromium	47.00	µg/ft ²	
			Lead	150.00	µg/ft ²	** 200/40
			Selenium	< 1.00	µg/ft ²	
108B-02	East Equipment Room	Floor - Northwest Corner	Silver	0.58	µg/ft ²	* 139/9.3
			Arsenic	3.10	µg/ft ²	** 62
			Barium	74.00	µg/ft ²	
			Cadmium	4.40	µg/ft ²	** 31
			Chromium	37.00	µg/ft ²	
			Lead	130.00	µg/ft ²	** 200/40
			Selenium	< 1.00	µg/ft ²	
108B-03	East Equipment Room	Work desk - West	Silver	< 0.72	µg/ft ²	* 139/9.3
			Arsenic	3.30	µg/ft ²	** 62
			Barium	47.00	µg/ft ²	
			Cadmium	20.00	µg/ft ²	** 31
			Chromium	31.00	µg/ft ²	
			Lead	290.00	µg/ft ²	** 200/40
			Selenium	< 2.50	µg/ft ²	
108B-04	East Equipment Room	Floor - South	Silver	0.71	µg/ft ²	* 139/9.3
			Arsenic	2.30	µg/ft ²	** 62
			Barium	180.00	µg/ft ²	
			Cadmium	14.00	µg/ft ²	** 31
			Chromium	31.00	µg/ft ²	
			Lead	140.00	µg/ft ²	** 200/40
			Selenium	< 2.50	µg/ft ²	
108B-05	Field Blank		Silver	< 0.50	µg/ft ²	* 139/9.3
			Arsenic	< 0.25	µg/ft ²	** 62
			Barium	0.51	µg/ft ²	
			Cadmium	< 0.05	µg/ft ²	** 31
			Chromium	< 0.50	µg/ft ²	
			Lead	< 0.25	µg/ft ²	** 200/40
			Selenium	< 0.50	µg/ft ²	

* Recommended Limits based on Table 3 (BNL Surface Wipe Criteria for Metals) of the Brookhaven Surface Wipe Sampling Procedure (IH75190), Rev 19: 3/4/14

** Recommended Limits based on Attachment 9.3 (Required & Recommended Surface Wipe Criteria) - Brookhaven Surface Wipe Sampling Procedure (IH75190), Rev 23: 6/23/17

Indicates results at or above REL

Appendix

B

Laboratory
Analytical
Reports



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150	Attn: Justin Arnold	Lab Order ID: 51824260
Project: 918004.002 Bldg 108 B		Date Received: 09/20/2018
		Date Reported: 10/02/2018
		Page: 1 of 2

Sample ID	Description	Area (ft ²)	*Element	Reporting Limit (µg)	Concentration (µg)	Concentration (µg/ft ²)
Lab Sample ID	Lab Notes					
108B-01	Floor – NE corner	1	Ag	0.50	0.92	0.92
			As*	1.3	2.0	2.0
			Ba	2.5	48	48
			Cd	0.050	5.2	5.2
			Cr	2.5	47	47
			Pb	1.3	150	150
51824260IPW_1			Se*	1.0	< 1.0	< 1.0
108B-02	Floor – NW corner	1	Ag	0.50	0.58	0.58
			As*	1.3	3.1	3.1
			Ba	5.0	74	74
			Cd	0.050	4.4	4.4
			Cr	2.5	37	37
			Pb	1.3	130	130
51824260IPW_2			Se*	1.0	< 1.0	< 1.0
108B-03	Desk - West	1	Ag	0.50	0.72	0.72
			As*	2.5	3.3	3.3
			Ba	2.5	47	47
			Cd	0.25	20.	20.
			Cr	2.5	31	31
51824260IPW_3			Pb	2.5	290	290
			Se*	2.5	< 2.5	< 2.5

*As – elevated RL possibly due to high levels of Pd interference

*Se – elevated RL possibly due to high levels of Al interference

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Dust Wipe Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH 7300/EPA SW-846 3050B



Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150	Attn: Justin Arnold	Lab Order ID: 51824260
Project: 918004.002 Bldg 108 B		Date Received: 09/20/2018
		Date Reported: 10/02/2018
		Page: 2 of 2

Sample ID	Description	Area (ft ²)	*Element	Reporting Limit (µg)	Concentration (µg)	Concentration (µg/ft ²)
Lab Sample ID	Lab Notes					
108B-04	Floor – South	1	Ag	0.50	0.71	0.71
			As*	1.3	2.3	2.3
			Ba	5.0	180	180
			Cd	0.25	14	14
			Cr	2.5	31	31
51824260IPW_4			Pb	1.3	140	140
			Se*	2.5	< 2.5	< 2.5
108B-05	Field Blank	-	Ag	0.50	< 0.50	-
			As	0.25	< 0.25	-
			Ba	0.050	0.51	-
			Cd	0.050	< 0.050	-
			Cr	0.50	< 0.50	-
51824260IPW_5			Pb	0.25	< 0.25	-
			Se	0.50	< 0.50	-

*As – elevated RL possibly due to high levels of Pd interference

*Se – elevated RL possibly due to high levels of Al interference

Melissa Ferrell

Analyst

(b) (6)

Lab Director

* SAI is AIHA ELLAP accredited for Pb only for dust wipe metals.

Unless otherwise noted blank sample correction was not performed on analytical results. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. MDLs are available upon request. Time-weighted average (TWA) calculations are based on customer supplied data and valid only for samples included in the specified TWA group. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190.



Scientific Analytical Institute, Inc.
 4604 Dundas Dr. Greensboro, NC 27407
 Phone: 336.292.3888 Fax: 336.292.3313
 www.sailab.com lab@sailab.com

Lab Use Only
 Lab Order ID: 51824260
 Client Code: _____

Company Contact Information	
Company: OCCU-TEC Inc.	Contact: Justin Arnold
Address: 100 NW Business Park Lane	Phone <input type="checkbox"/> : 816-810-3276
Riverside, Mo 64150	Fax <input type="checkbox"/> : 816-994-3478
	Email :jarnold@occutec.com

Industrial Hygiene Test Types	
Silica as Alpha Quartz (XSZ)* <input type="checkbox"/>	With Respirable Dust (XDZ) <input type="checkbox"/>
Silica as Cristobalite (XSC)* <input type="checkbox"/>	With Respirable Dust: (XDC) <input type="checkbox"/>
Silica as Tridymite (XST)* <input type="checkbox"/>	With Respirable Dust (XDT) <input type="checkbox"/>
Silica as Alpha Quartz, Cristobalite, Tridymite (XSA)* <input type="checkbox"/>	With Respirable Dust (XDA) <input type="checkbox"/>
Silica Bulk (XSI)* <input type="checkbox"/>	
Bulk Phase ID/Whole Rock (XUK) <input type="checkbox"/>	
Total Dust NIOSH Method 0500 (GTD) <input type="checkbox"/>	
Respirable Dust NIOSH Method 0600 (GSD) <input type="checkbox"/>	
PCM NIOSH 7400-A Rules (PCM) <input type="checkbox"/>	
B Rules (PCB) <input type="checkbox"/>	TWA (PTA) <input type="checkbox"/>
TEM NIOSH 7402 (Asbestos) (TN!) <input type="checkbox"/>	
Hexavalent Chromium (OSHA ID-215) (Note if from spray paint operations) <input type="checkbox"/>	
Metals (NIOSH 7300) (Specify Metals Under Comments) <input type="checkbox"/>	
Other 6010 C <input checked="" type="checkbox"/>	

* Modified NIOSH 7500/OSHA ID 142

Billing/Invoice Information	Turn Around Times [^]	
SAME <input checked="" type="checkbox"/>	90 Min. <input type="checkbox"/>	48 Hours <input type="checkbox"/>
Company:	3 Hours <input type="checkbox"/>	72 Hours <input type="checkbox"/>
Contact:	6 Hours <input type="checkbox"/>	96 Hours <input type="checkbox"/>
Address:	12 Hours <input type="checkbox"/>	120 Hours <input type="checkbox"/>
	24 Hours <input type="checkbox"/>	144 ⁺ Hours <input checked="" type="checkbox"/>
	[^] TATs not available for certain test types	
PO Number:		
Project Name/Number: 918004.002	Bldg 108B	

Sample ID #	Description/Location	Volume/Area	Comments
			Ag, As, Ba, Cd, Cr, Pb, Se
108B-01	Floor - NE corner	1 SF	Ag, As, Ba, Cd, Cr, Pb, Se
108B-02	Floor - NW corner	1 SF	Ag, As, Ba, Cd, Cr, Pb, Se
108B-03	Desk - West	1 SF	Ag, As, Ba, Cd, Cr, Pb, Se
108B-04	Floor - South	1 SF	Ag, As, Ba, Cd, Cr, Pb, Se
108B-05	Field Blank	—	Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se
			Ag, As, Ba, Cd, Cr, Pb, Se

Accepted
 Rejected

Total # of Samples _____

Relinquished by	Date/Time	Received by	Date/Time
(b) (6)	9-17-18 0900	(b) (6)	9/20 10:30a

Appendix

C

Qualifications and
Licenses

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Jeffrey T. Smith

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **3/16/2017**
Expiration Date: **3/16/2019**
License Number: **010316-200089640**



(b) (6)

Randall W. Williams, MD, FACOG
Acting Director
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102