

GENERAL SERVICES ADMINISTRATION
PUBLIC BUILDINGS SERVICE
SUPPLEMENTAL LEASE AGREEMENT

SUPPLEMENTAL
AGREEMENT
NO. 1

DATE

2-1-11

TO LEASE NO.
GS-05B-18276

ADDRESS OF PREMISES

Skylight Office Tower
1660 West Second Street
Cleveland, Ohio 44113-1454

THIS AGREEMENT, made and entered into this date by and between SKYLIGHT Office Tower SPE, LLC whose address is 50 Public Square, Suite 1360 Cleveland, OH 44113

hereinafter called the Lessor, and the UNITED STATES OF AMERICA, hereinafter called the Government:

WHEREAS, the parties hereto desire to amend the above Lease. NOW THEREFORE, these parties for the consideration hereinafter mentioned covenant and agree that the said Lease is amended, effective 4/5/2010, as follows:

Sections 8.15 and 8.16 of the SFO are hereby deleted in their entirety and replaced with the following:

8.15 DATA DISTRIBUTION (AUG 2008)

A. TENANT IMPROVEMENT INFORMATION:

The Lessor shall purchase and install the data cable and outlets as part of the tenant improvement costs. The Lessor shall safely conceal data outlets and the associated wiring used to transmit data to workstations shall be in floor ducts, walls, columns, or below access flooring. When cable consists of multiple runs, the Lessor shall provide ladder-type or other acceptable cable trays to prevent cable coming into contact with suspended ceilings or sprinkler piping. Cable trays shall form a loop around the perimeter of the Government-demised area such that they are within a 30-foot horizontal distance of any single drop.

8.16 ELECTRICAL, TELEPHONE, DATA FOR SYSTEMS FURNITURE (AUG 2008)

A. TENANT IMPROVEMENT INFORMATION:

1. The Lessor shall provide as part of the Tenant Improvement Allowance separate data, telephone, and electric junction boxes for the base feed connections to Government-provided modular or systems furniture, when such feeds are supplied via wall outlets or floor penetrations. When overhead feeds are used, junction boxes shall be installed for electrical connections. Raceways shall be provided throughout the furniture panels to distribute the electrical, telephone, and data cable. The Lessor shall provide all electrical service wiring and connections to the furniture at designated junction points. Each electrical junction shall contain an 8-wire feed consisting of 3 general-purpose 120-V circuits with 1 neutral and 1 ground wire, and a 120-V isolated-ground circuit with 1 neutral and 1 isolated-ground wire. A 20-ampere circuit shall have no more than 8 general-purpose receptacles or 4 isolated-ground "computer" receptacles.
2. The Lessor shall purchase and install the data cable and telecommunications cable as part of the tenant improvement costs. Said cable shall be installed and connected to systems furniture by the Lessor/contractor with the assistance and/or advice of the Government or computer vendor. The Lessor shall provide wall-mounted data and telephone junction boxes, which shall include rings and pull strings to facilitate the installation of the data and telecommunications cable. When cable consists of multiple runs, the Lessor shall provide ladder-type or other acceptable cable trays to prevent cable coming into contact with suspended ceilings or sprinkler piping. Cable trays shall form a loop around the perimeter of the Government-demised area such that they are within a 30-foot horizontal distance of any single drop. Said cable trays shall provide access to both telecommunications data closets and telephone closets.
3. The Lessor shall furnish and install suitably sized junction boxes in the vicinity of the "feeding points" of the furniture panels. All "feeding points" shall be shown on Government-approved design intent drawings. The Lessor shall temporarily cap off the wiring in the junction boxes until the furniture is installed. The Lessor shall make all connections in the power panel and shall keep the circuit breakers off. The Lessor shall identify each circuit with the breaker number and shall identify the computer hardware to be connected to it. The Lessor shall identify each breaker at the panel and identify the devices that it serves.
4. The Lessor's electrical contractor must connect power poles or base feeds in the junction boxes to the furniture electrical system and test all pre-wired receptacles in the systems furniture. Other Government contractors will be installing the data cable in the furniture panels for the terminal and printer locations, installing the connectors on the terminal/printer ends of the cable, and continuity testing each cable. Work shall be coordinated and performed in conjunction with the furniture, telephone, and data cable installers. Much of this work may occur over a weekend on a schedule that requires flexibility and on-call visits. The Lessor must coordinate the application of Certification of Occupancy with furniture installation.

All other terms and conditions of the lease shall remain in force and effect.

IN WITNESS WHEREOF, the parties subscribed their names as of the above date.

Continued on Page 2

LESSOR Skylight Office Tower SPE, LLC

BY




Vice President

Duane F. Bishop, Jr.

(Title)

IN PRESE



*50 Public Square
Cleveland, OH 44113*

(Address)

UNITED STATES GOVERNMENT ADMINISTRATION

BY



Contracting Officer
(Official Title)